SWT

01.12.2008

For Construction

SYMBOL LEGEND

- SPLIT SWITCHED RECEPTACLE
- GFI GROUND FAULT INTERRUPT RECEPTACLE
- WP WATER PROOF EXTERIOR RECEPTACLE
- DUPLEX RECEPTACLE
- QUADPLEX RECEPTACLE
- JUNCTION BOX
- D DIMMER SWITCH
- 4 4-WAY SWITCH
- 3 3-WAY SWITCH
- SINGLE POLE SWITCH
- S SURFACE MOUNT CEILING FIXTURE
- RECESSED LOW VOLTAGE DOWNLIGHT FIXTURE
- RECESSED FIXTURE
- CEILING MOUNT PENDANT FIXTURE
- WALL MOUNT UPLIGHT FLOOD FIXTURE
- WALL MOUNT SCONCE FIXTURE
- F FLOURESCENT FIXTURE
- F BATH CEILING FAN
- BATH CEILING FAN/LIGHT
- TRACK FOR LOW VOLTAGE LIGHTING
- UNDER COUNTER LIGHTING
- EXTERIOR FLOOD FIXTURE
- CEILING FAN
- TELEPHONE JACK
- TV CABLE PORT (TV OR INTERNET)
- SMOKE ALARM (HARDWIRED)
- THERMOSTAT
- DOORBELL
- GARAGE DOOR OPENER
- SMOKE ALARM (HARDWIRED) PROVIDE IN ALL SLEEPING ROOMS ON CEILING, 1'-0" FROM WALL.
- CARBON MONOXIDE SENSOR

NOTES:
1. ALL WORK TO CONFORM TO NATIONAL ELECTRIC CODE
2. ALL ELECTRICAL OULETS IN WET LOCATIONS TO BE GFI
3. ALL OUTLETS TO BE LOCATED PER APPLICABLE CODE
4. PROVIDE BLOCKING FOR LIGHTING FIXTURE HOUSINGS AS REQUIRED
5. LIGHTS TO BE ON DIMMERS AS SHOWN
6. CLOSET LIGHTS TO BE MOUNTED INSIDE CLOSET ON WALL ABOVE DOOR
7. LOCATE SMOKE ALARMS PER APPLICABLE CODE

1 2nd Floor
SCALE: 1/4" = 1'-0"

2 3rd floor - Alternative 1
SCALE: 1/4" = 1'-0"

3 3rd floor - Alternative 2 (with wood collar ties)
SCALE: 1/4" = 1'-0"

KAPLAN THOMPSON ARCHITECTS
424 Fore St., Portland, ME 04101
207-842-2888 fax:842-2828

Project:
Sweet Residence
Alterations for Julian Sweet
187 Vaughan St. #2
Portland, ME 04102

Drawing: RCP & Lighting Plan
Scale:
Drawn by: RTL
Date: January 12, 2009
Revised: #Rev. A

E-1.1