

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 111 Vaughn St		Owner: Boutin, Stephen		Phone: 773-6412		Permit No: 980732	
Owner Address: 5AA 04101		Lessee/Buyer's Name:		Phone:		BusinessName:	
Contractor Name:		Address:		Phone:			
Past Use: 1-100		Proposed Use:		COST OF WORK: \$ 450.00		PERMIT FEE: \$ 25.00	
				FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type:	
Proposed Project Description: Lower existing bulkhead & expand deck & rail system not exceeding footprints		Signature:		Signature:		Zone: CBL:	
Permit Taken By: PG		Date Applied For: 30 June 1998		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied: <input type="checkbox"/>		Zoning Approval: Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	

PERMIT ISSUED
Permit Issued:
JUL - 7 1998
CITY OF PORTLAND

**PERMIT ISSUED
WITH REQUIREMENTS**

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

- Zoning Appeal**
- Variance
 - Miscellaneous
 - Conditional Use
 - Interpretation
 - Approved
 - Denied

- Historic Preservation**
- Not in District or Landmark
 - Does Not Require Review
 - Requires Review

- Action:**
- Approved
 - Approved with Conditions
 - Denied

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT		ADDRESS:		DATE: 01 JUL 1998		PHONE:	
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE						PHONE:	

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

CEO DISTRICT 3

BUILDING PERMIT REPORT

DATE: 7 July 98 ADDRESS: 171 Vaughan St, #63-G-019
REASON FOR PERMIT: EXTERIOR RENOVATIONS
BUILDING OWNER: S. Foote
CONTRACTOR: SAA ↑
PERMIT APPLICANT: SAA ↑
USE GROUP R-3 BOCA 1996 CONSTRUCTION TYPE 3B

CONDITION(S) OF APPROVAL

This Permit is being issued with the understanding that the following conditions are met:

Approved with the following conditions: *1, *2, *8, *10, *26, *29

- ✓ 1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
- ✓ 2. Before concrete for foundation is placed, approval from the ~~Development Review Coordinator and Inspection Services~~ must be obtained. (A 24 hour notice is required prior to inspection)
- 2.5 Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material.
3. Precaution must be taken to protect concrete from freezing.
4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993).
7. Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's building code.
- ✓ 8. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42" , except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 34" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2".
9. Headroom in habitable space is a minimum of 7'6".
- ✓ 10. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread. 7" maximum rise.
11. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6' 8")
12. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension

**THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE
PERMIT IS ISSUED**

**Building or Use Permit Pre-Application
Additions/Alterations/Accessory Structures
To Detached Single Family Dwelling**

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

NOTEIf you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.**

Location/Address of Construction: 171 VAUGHAN ST. PORTLAND 04102

Tax Assessor's Chart, Block & Lot Number Chart# <u>063</u> Block# <u>G</u> Lot# <u>019</u>		Owner: <u>STEPHEN W. FOOTE</u>	Telephone#: <u>773-6622</u>
Owner's Address: <u>171 VAUGHAN ST.</u>		Lessee/Buyer's Name (If Applicable)	Cost Of Work: <u>\$ 450.</u> Fee <u>\$ 25.-</u>
Proposed Project Description:(Please be as specific as possible) <u>LOWER EXISTING BULKHEAD & EXPANDING DECK + RAIL SYSTEM NOT EXCEEDING FOOTPRINT</u>			
Contractor's Name, Address & Telephone <u>SELF</u>		Rec'd By:	

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.


- All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II.
- All plumbing must be conducted in compliance with the State of Maine Plumbing Code.
- All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.
- HVAC(Heating, Ventilation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code.

You must Include the following with you application:

- 1) A Copy of Your Deed or Purchase and Sale Agreement
- 2) A Copy of your Construction Contract, if available
- 3) A Plot Plan (Sample Attached)

If there is expansion to the structure, a complete plot plan (Site Plan) must include:

- The shape and dimension of the lot, all existing buildings (if any), the proposed structure and the distance from the actual property lines. Structures include decks porches, a bow windows cantilever sections and other overhangs, as well as, sheds, pools, garages and any other accessory structures.
- Scale and required zoning district setbacks



4) Building Plans (Sample Attached)

A complete set of construction drawings showing all of the following elements of construction:

- Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.

Certification

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant: Stephen W. Foote Date:

Site Review Fee: \$150.00/Building Permit Fee: \$25.00 for the 1st \$1000.cost plus \$5.00 per \$1,000.00 construction cost thereafter.

Applicant: Stephen Foote

Date: 7/2/98

Address: 171 Vaughan

C-B-L: 63-G-19

CHECK-LIST AGAINST ZONING ORDINANCE

Date - existing -

Zone Location - R-4

Interior or corner lot -

Proposed Use/Work -

Sewage Disposal -

Lot Street Frontage -

Front Yard - NA

Rear Yard - 25' req - New Section 21.5' shown - using Section 14-433 that allows up to

Side Yard - 10' req - 11.5' shown

Projections -

Width of Lot -

Height -

Lot Area -

Lot Coverage/ Impervious Surface -

Area per Family -

Off-street Parking -

Loading Bays -

Site Plan -

Shoreland Zoning/ Stream Protection - NA

Flood Plains - NA


COMMENTS

7/13/98 - Called owner - left message -

8/18/98 MR. FOOTEWILL REDUCE THE DECK
ON THE LEFT TO FIT ON THE EXISTING
BUCKHEAD FOOT PRINT + USE THE
BUCK HEAD FOUNDATION TO HOLD THE
DECK INSTEAD OF SONOR TUBES.
All Out

11/15/00 - work finished and appears to meet permit requirements

Close permit # 980732
CBE # 63-G-19





	Type	Inspection Record	Date
Foundation:	_____	_____	_____
Framing:	_____	_____	_____
Plumbing:	_____	_____	_____
Final:	_____	_____	_____
Other:	_____	_____	_____

171 VAUGHAN

"BILCO" BULKHEAD DOORS, SHOWN BELOW, WOULD BE LOWERED, AND COVERED BY DECK EXTENSION ILLUSTRATED IN ELEVATION SHOWN AT RIGHT.
 SCALE = ONE SQUARE = 3" - □



□ → SHOWS AREA TO BE ALTERED



Joist - 2x6 @ 16" oc
 Deck 5/4
 balis 1 1/2" 4" oc
 Guard 36"

2x6
 1 1/2" Fency Lattice
 (ALSO OVERS BULKHEAD)
 GRADE

17-1 VAUGHAN - PROPOSAL

PROJECT WOULD ENTAIL LOWERING EXISTING BULKHEAD TO GRADE LEVEL, AND EXTENDING THE EXISTING PORCH TO ENLARGE DECK SPACE - NOT TO EXCEED CURRENT FOOTPRINT. DECK SURFACE WOULD BE HINGED AGAINST THE HOUSE TO ALLOW BULKHEAD TO BE OPENED.

ALL MATERIALS TO BE STANDARD, PRESSURE-TREATED LUMBER. PROJECT NOT TO EXCEED \$450. AND WILL BE OWNER-BUILT.

THE STRUCTURE IS NOT VISIBLE FROM THE STREET.

SCALE ■ ONE SQUARE = 6" - □

→ SHOWS AREA DISCUSSED ABOVE

