2122102 Met on the W/ and builder went over T+R, HANDROIS. Also,
Aced 1) GRASPABLE HANDROIL 2. CLOSE-IN Storage AREA 3. REINFORCE
Storage of Rear. JR.

2128/02 Final inspection. Revolations complete. READY FIR 5/6 GR



Department of Building Inspection

## Certificate of Occupancy

LOCATION 966 Congress St

CBL 064 A001001

Issued to Union Station Lmt Partnership/Leighton, Chris

Date of Issue 02/28/2002

— changed as to use under Building Permit No. 02-0060 , has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Retail Space(drum shop)

Use Group M Type 3b (Boca 1999)

Limiting Conditions: This Certificate covers the retail space only, and the alterations completed by permit #02-0060

This certificate supersedes certificate issued

Approved:

Date) Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.