New bathroom-need a minimum of 12" clearance at the door latch for ADA compliance

CITY OF PORTLAND, MAINE RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 08/24/16