

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
COWCATCHER LLC

Located at
222 ST JOHN ST (SUITE 215)

PERMIT ID: 2014-02832 **ISSUE DATE:** 01/20/2015 **CBL:** 064 A002001

has permission to **"Spa Lotta d/b/a Southern Maine Electrolysis" Aesthetician and Electrolysis - no change of use adding aesthetician to existing Electrolysis Office. Certificate of Occupancy needed for State License Board**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
Suite 215 - Personal Service.

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-02832	Date Applied For: 12/09/2014	CBL: 064 A002001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Aesthetician and Electrolysis Office - suite 215		Proposed Project Description: "Spa Lotta d/b/a Southern Maine Electrolysis" Aesthetician and Electrolysis - no change of use adding aesthetician to existing Electrolysis Office. Certificate of Occupancy needed for State License Board		
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 01/20/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Separate permits shall be required for any new signage.				
Dept: Building	Status: Approved w/Conditions	Reviewer: Tammy Munson	Approval Date: 12/23/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This permit authorizes a change in ownership ONLY. Construction activity was not applied for or reviewed as a part of this permit.				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 01/16/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Shall comply with NFPA 101, Chapter 39, Existing Business Occupancies.				
2) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.				
3) Shall meet the requirements of 2009 NFPA 1 Fire Code.				
4) All construction shall comply with City Code Chapter 10.				