



ELECTRICAL CONNECTION LIST

TAG	TYPE	AMPERAGE	VOLTAGE	FUSE	NEMA RATING
E-1	LOCAL DISCONNECT	400A	480V	250A	1
E-2	POWER CO. DISCONNECT	400A	480V	250A	3R

CURRENT TRANSFORMERS

MANUFACTURER	MODEL	CURRENT RATIO	ACCURACY	DIAMETER	BURDEN CAPACITY
FLEXCORE	FC-2000/5-R411	2000/5	1%	RECTANGLE-R411	25VA

REVISIONS

REV.	DESCRIPTION	DATE

CONSULTANT:
SALAMONE & ASSOCIATES, P.C.
 CONSULTING ENGINEERS
 3035 Whitney Avenue
 Hamden, Connecticut 06518
 Phone: (203) 281-8895 Fax: (203) 287-8728

DISCLAIMER
 THE INFORMATION INDICATED HERewith IS THE SOLE PROPERTY OF SALAMONE & ASSOCIATES, P.C. AND ANY REPRODUCTION BY ANY METHOD IN PART IS STRICTLY PROHIBITED WITHOUT WRITTEN PERMISSION OF SALAMONE & ASSOCIATES, P.C.

NOTES:

PROJECT TITLE
 CONTRACT DOCUMENTS FOR COGENERATION SYSTEM AT THE
CUMBERLAND COUNTY JAIL
 50 COUNTY WAY, PORTLAND, MAINE

DRAWING TITLE
ELECTRICAL ONE LINE RISER

JOB NUMBER	3151.01
PROJECT MANAGER	JAS
ENGINEER/DESIGNER	FB
DRAWN BY	ST
SCALE	AS NOTED
DATE	OCTOBER 31, 2012

CAD FILE:

SEAL: STATE OF MAINE PROFESSIONAL ENGINEER
 DRAWING NO. **E-2**

ELECTRICAL ONE-LINE RISER
 SCALE: NONE