

CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
 Portland, Maine 04101

Inspection Violations

Owner/Manager GORSKI PATRICIA N		Inspector Jodine Adams	Inspection Date 06/23/2004
Location 254 VALLEY ST	CBL 064 D011001	Status Re-Inspect 30 Days	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-111.4	Interior	1	back u	Kitchen	
Violation: Maintenance of plumbing fixtures.					
Notes: kitchen sink leaking water at plumbing					
2) 6-113.5	Interior	1	back u	Kitchen	
Violation: Maintenance of lighting fixtures					
Notes: light not properly secured or wired above kitchen sink					
3) 6-108.2	Interior	1	back u	Kitchen	
Violation: Interior floors, walls, ceilings and doors					
Notes: kitchen floor has contact paper due to floor lifting and chipping. Broken, loose or chipped tiles will need to be replaced					
4) 6-108.2	Interior	1	back u	Kitchen	
Violation: Interior floors, walls, ceilings and doors					
Notes: kitchen pantry ceiling in cabinet missing					

Comments: