

CLOSED  
PROPERTY

SOLD

25 Hemlock St  
Portland ME  
04102

(207) 799-1834  
Stephen R Brown  
Colorado?

065A010

4 units as per Ann

Corelogic

1-800-873-4532

1-800-426-1466

Aaron from Corelogic

11:00A 12/9/2011

Will transmit high priority e-mail  
to mortgage holder.

1<sup>st</sup> case # 2011-10-2404

2<sup>nd</sup> case # 2012-02-3294

Heat  
Power  
Water  
Hot Water

Smokes  
Egress

Stephen R Brown  
38 Day Rd.  
Gorham, ME  
04038

289-5049

Copy to cap.

- Electrical
- the keeping

~~#~~

3 floor unit (illegal)

10/12 - 1<sup>st</sup> insp

unit #3

2<sup>nd</sup> floor - no egress - needs smokes

unit #1

no smokes - Elect Heat clearance

unit #4

2<sup>nd</sup> floor - no egress - no smokes

unit #2

1<sup>st</sup> floor - no smokes - elect violations

Case creation date

Trash & Possible structure

10/6/2011 \*10/12/2011

Bsmnt. water heater. gas.  
pipe pitched dn. CO issue