



FIXTURES W/ WALL MOUNT BRACKET FOR SIGNATURE ELEMENTS TO BE INSTALLED. INSTALL AND ADJUST FIXTURES TO FOCUS LIGHT ONLY ON THE HEARTH SIGNATURE SIGN. MOUNT FIXTURE SO THAT IT IS NOT VISIBLE ABOVE PARAPET. (TYP. FOR CCT LP-1:15/SEE SHEET E2.0 FOR FIXTURE SCHEDULE)

INSTALL BALLAST BOX FOR ELECTRONIC BALLASTS, MOUNTED TO INNER PARAPET WALL (TYP. FOR CCT LP-1:17) VERIFY MOUNTING WITH AOM.

NOTE: PROVIDE WP (GFI) RECEPTACLES TO ALL WIRE TO AP2-24

RESTAURANT LOCATION:
 1332 US ROUTE 302
 PORTLAND, ME

PREPARED FOR:
McDonald's USA, LLC
 McDONALD'S PLAZA
 OAK BROOK, ILLINOIS
 60521

SHEET NUMBER:
E1.3

SHEET TITLE:
ROOF ELEC. PLAN

CONSULTANT:
ENGINEERING ADVANTAGE, INC.
 2 PARK ST.
 BOSTON, MASSACHUSETTS 02122
 PHONE: (617) 288-3969
 FAX: (617) 825-8922

Landry ARCHITECTS
 389 Main Street - Salem, NH 03079
 T 603.890.6414 F 603.894.4356

DRAWN BY: CJC DATE ISSUED: 08/14/07
 CHECKED BY: LAF SCALE: AS NOTED
 DATE DRAWN: 04/17/07 JOB NUMBER: M-1035

REVISIONS		
NO.	DATE	BY
1		
2		
3		
4		
5		
6		
7		