332 SAINT JOHN STREET

ZONE	DEVICE	DESCRIPTION	TEST RESULTS
L1S01	DUCT DETECTOR	PLAY PLACE AREA	
L1S02	DUCT DETECTOR	DINIG AREA	
L1S03	DUCT DETECTOR	KITCHEN	
L1S04	SMOKE DETECTOR	ABOVE FACP	
L1M05	ANSUL SYSTEM	FILLET STATION	SEE NOTE 2
L1M06	ANSUL SYSTEM	CLAM GRILL	SEE NOTE 2
L1M07	ANSUL SYSTEM	FRY STATION	SEE NOTE 2
L1M08	PULL STATION	BACK DOOR	PASS
L1M09	SPRINKLER	WATERFLOW	SEE NOTE 1
L1M10	SPRINKLER	GATE VALVE TAMPER	SEE NOTE 1
L1M11	PULL STATION	PLAY PLACE EXIT	PASS
L1M12	PULL STATION	RIGHT FRONT DOOR	PASS
L1M13	PULL STATION	LEFT FRONT DOOR	PASS
L1M14	RELAY	OUTSIDE STROBE	
L1M15	RELAY	TROUBLE TO AES RADIO	
L1M16	RELAY	ALARM TO AES RADIO	

DEVICE	DESCRIPTION	TEST RESULTS
HORN/STROBE	BREAKROOM	PASS
HORN/STROBE	KITCHEN BY OFFICE	PASS
HORN/STROBE	MEN'S BATHROOM	PASS
HORN/STROBE	KITCHEN BY CLAM GRILL	PASS
HORN/STROBE	MEN'S BATHROOM	PASS
HORN/STROBE	WOMEN'S BATHROOM	PASS
HORN/STROBE	DINING BY SODA MACHINE	PASS
HORN/STROBE	DINING BY FACP	PASS
HORN/STROBE	DINING BY BATHROOMS	PASS
HORN/STROBE	FRONT PLAY PLACE	PASS
HORN/STROBE	CENTER PLAY PLACE	PASS
HORN/STROBE	REAR PLAY PLACE	PASS
OUTSIDE STROBE	OUTSIDE ENTRANCE BY FACP	PASS

NOTES		
1. TESTED BY SPRINKLER COMPANY		
2. TESTED BY HOOD COMPANY		