
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager BROWN BARRY J		Inspector Jon Rioux	Inspection Date 4/20/2007
Location 947 CONGRESS ST	CBL 065 C002001	Status Re-Inspect 10 Days	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 12-79	Exterior				
Violation:	Junk Vehicles				
Notes:	Remove the discarded, junked motor vehicle [ME Com. 703-726] damaged by fire within ten (10) days of this notice.				
2)	Exterior				
Violation:					
Notes:	12-19(b) Any person owning, operating or being in charge of any commercial property shall require that solid waste and recyclable material be stored in suitable containers. This shall include removing waste storage near The Inn at St. John's window within ten (10) days of this notice.				
3) 6-113.5	Exterior				
Violation:	Maintenance of lighting fixtures				
Notes:	Repair the "tagged-out" building electrical service connection so that it is in good and safe working condition and in accordance with the electrical code of the city within ten (10) days of this notice. Note: a Master Electrician is required.				

Comments: