



Permitting and Inspections Department  
Michael A. Russell, MS, Director

Jonathan Rioux, Inspections Director

01/29/2018

Sent Via: Regular, Certified Mail # 70141820000140470867 & Hand Delivered

Nancy E. Hurst  
1876 Harpswell Neck Rd  
Harpswell, ME 04079

Located At: 325 St John Street  
CBL: 065 C004001  
RE: Lang's Express  
Business I.D. # 552

#### Notice of Violation

Langs Express:

An evaluation of the above-reference property by the City's Permitting and Inspections and Fire Departments on 01/29/2018 revealed that your business fails to comply with Section 11.2, 11.4, 11.6 of NFPA 96 adopted by the City of Portland. Specifically, your Type I Hood system is out of compliance and must be repaired, upgraded, maintained, and tested in accordance with NFPA 96.

Attached is a list of violations, and corrected plan of action that must be submitted to the Fire Prevention Bureau for review, no later than 02/15/2018.

Given the present circumstances of this NFPA 96 Commercial Kitchen System Violation and how it relates to food service establishment, you must:

1. Immediately discontinue use of the Type I kitchen exhaust hood system;
2. Immediately submit an updated menu for review and approval to the City's Inspections Division that contains only cooked or uncooked food items that do not emit grease laden vapors; and
3. Schedule a walkthrough inspection with a City Health Inspector to review your revised menu and food preparation requirements.

A reinspection of your food service establishment will occur on 01/31/18 to verify that the kitchen exhaust hood system is no longer in use.

The City's Corporation Counsel's Office has been alerted to the existence of this matter and if you do not remedy these issues as required by this Notice of Violation they may pursue legal action including civil penalties, as provided for in Section 10-25 of the City of Portland Code of Ordinances.

Portland, Maine




Yes. Life's good here.

Permitting and Inspections Department  
Michael A. Russell, MS, Director

Jonathan Rioux, Inspections Director

If you have any question or concerns please contact me at (207) 874-8703.

Sincerely,



Jonathan Rioux,  
Inspections Director

cc: John Brennan, Captain/ Fire Prevention Officer  
Eric Cobb, Code Enforcement Officer/ Health Inspector