



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 327 St. John St. (CBL#065-C-006)

Issued to Dunkin Donuts (Diane Resnick)

Date of Issue May 3, 2000

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 000092, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire Structure

APPROVED OCCUPANCY

Use Group A-3
Type 2 B
Retail
Boca 96

Limiting Conditions:

This certificate supersedes certificate issued

Approved:

5/3/00
(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

COMMENTS

05/02/00 - Final inspection w/ Sam H / LT MacDougal / Steve Wentworth - some electrical issues to be resolved - switch plates missing and wires not clipped correctly - also indirect waste line has no air gap - will cut pipe to meet requirements - Did Rough in plumbing w/ Jon Reed in April - Marland did preconstruction 4/2/00 but wrote it on sepn permit - will check on 05/03 to finish and close out permit. Jim

Inspection Record		Date
Type		
Foundation:	_____	_____
Framing:	_____	_____
Plumbing:	_____	_____
Final:	_____	_____
Other:	_____	_____