

CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
 Portland, Maine 04101

Inspection Violations

Owner/Manager LIBBYTOWN PROERTIES LLC		Inspector Marland Wing	Inspection Date 08/25/2005
Locatation 317 VALLEY ST	CBL 065 D002001	Status	Inspection Type Building Permit-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-108.4	Exterior	1		Side Landing	
Violation: Stairways, stairwells, stairs, porches.					
Notes: rotted board					
2) 6-108.3	Exterior			Cellar	
Violation: Exterior windows, doors and skylights					
Notes: window missing glass					
3) 6-108.4	Interior	1/2/3		Hallway	
Violation: Stairways, stairwells, stairs, porches.					
Notes: missing hand rail					
4) 6-113.5	Interior	3	3	Pantry	
Violation: Maintenance of lighting fixtures					
Notes: ceiling loose light fixture					

Comments: