



Inspection Services  
P. Samuel Hoffses  
Chief



MORCAU Elec.  
Kelley Assoc.

Planning and Urban Development  
Joseph E. Gray Jr.  
Director

## CITY OF PORTLAND

February 2, 1996

Dan Herbert  
Edward Herbert & Sons  
9 Gould Road  
Lewiston, Maine 04240

RE: 930 Congress Street  
Portland, Maine

Dear Mr. Herbert,

Your application to make interior renovations to the third floor has been reviewed and a permit is herewith issued subject to the requirements listed below.


No Certificate of Occupancy will be issued until all requirements of this letter are met.

### Building and Fire Code Requirements

1. The renovations requires State Fire Marshall approval. *check*
2. The sprinkler system shall be maintained to NFPA 13 Standards.
3. The fire alarm system shall be maintained to NFPA 72 Standards.
4. All means of egress shall be provided with signs and an emergency back-up system.
5. Portable fire extinguishers shall be provided in accordance with NFPA 10.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,

  
Marge Schmuckal  
Asst. Chief, Code Enforcement Division

cc: Lt. McDougall, PFD

COMMENTS

2.26.91c Bath (Plumbing) on site during minor demolition. No suspension  
 on site. Showers elec. to be sunk. all piping for  
 plumbing to be above ceiling (existing) any new work  
 will not require a permit. Kelly Associates to do  
 WMA. Notified them that I still have not rec'd.  
 State Fire Marshall's approval discussed with them of  
 approval w. bath. up pending for address.  
 3/6/91c Still have no state fire Marshall's approval. Rough Plumbing  
 inspection - ok. Copper for dryer installed also tested.  
 Minor interior wall changes completed to a point of  
 Smeared and being taped.

Final report. Final inspection



	Type	Inspection Record	Date
Foundation:			
Framing:			
Plumbing:			
Final:			
Other:			