



CUNNINGHAM
SECURITY SYSTEMS

June 3, 2019

Fire Prevention Bureau
Portland Fire Department
380 Congress Street
Portland, ME 04101
Fax#: (207) 874-8410

To Whom It May Concern:

This letter is to inform you that on April 10, 2019, we completed the installation, programming and testing of the new fire alarm system located in the building at 12 Forest Street, Portland, ME. This new fire alarm control panel, communicator, and all system devices were installed, programmed and test to NFPA 72 standards with all signals sent to and received at our central monitoring station. All these devices were found to be fully functional at that time. We have been monitoring this new fire alarm system and receiving daily test signals from this system since this date.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,

Ronald S. Snider, Manager

cc: Acct. File