Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 6/19/2013

PS	PULL STATION
S	SMOKE DETECTOR
R	HEAT DETECTOR RATE OF RISE
F	HEAT DETECTOR FIXED TEMP
RT	REMOTE TEST/INDICATOR
DS	DUCT SMOKE DETECTOR
VD	VISUAL ONLY
AV	AUDIO / VISUAL
NZM 100	ZONE MODULE
NC-100	CONTROL MODULE
NMM	MONITOR MODULE 100=4 SQUARE, 100p=mininod
NC 100r	RELAY MODULE
STS	SPRINKLER TAMPER
SPS	SPRINKLER PRESSURE
SFS	SPRINKLER FLOW
DH	DOOR HOLDER 120V AC
CD	CARBON MONOXIDE DETECTOR

FIRST FLOOR PLAN
3/16" = 1-0'

FIRST FLOOR PLAN
919 CONGRESS ST.

DATE: 1.31.2013
DRAWN BY: BB

A-101