	Owner:	čia, ju	Phone:	5 to 17. 14.	Permit No: 99 055 2
Owner Address:	Lessee/Buyer's Name:	Phone:	Business	Name:	PERMIT ISSUED
Contractor Name:	Address:	Phone:			Parmit Issued.
Past Use:	Proposed Use:	COST OF WORK	i:	PERMIT FEE:	JUN 2 1999
Entry Const	naun in	FIRE DEPT. ☐ Â	Approved enied	INSPECTION: Use Group: Type:	CITY OF PORTLAND
		Signature:	همد سرواند	Signature:	Zone: CBL:
Proposed Project Description:		~.5		S DISTRICT (P.A.D.)	Zoning Approval:
na en, Mander Rear de benancione de la martie de la Mander a Provincia	er later (was a file the	A	Approved Approved w Denied	vith Conditions:	☐ Shoreland
Permit Taken By:	Date Applied For:	Signature.		Date.	☐ Site Plan maj ☐minor ☐mm ☐
 Building permits do not include plumbing, se Building permits are void if work is not started tion may invalidate a building permit and sto 	d within six (6) months of the date of	f issuance. False informa-			☐ Conditional Use ☐ Interpretation ☐ Approved ☐ Denied
				MIT ISSUED	Historic Preservation ☐ Not in District or Landmark ☐ Does Not Require Review ☐ Requires Review
				MIT ISSUED EQUIREMENTS	☐ Not in District or Landmark ☐ Does Not Require Review
I hereby certify that I am the owner of record of the authorized by the owner to make this application a if a permit for work described in the application is	as his authorized agent and I agree to	o conform to all applicable	WITH R	EQUIREMENTS record and that I have been is jurisdiction. In addition	□ Not in District or Landmark □ Does Not Require Review □ Requires Review Action: □ Approved □ Approved with Conditions □ Denied
· ·	e named property, or that the propose as his authorized agent and I agree to issued, I certify that the code official	o conform to all applicable al's authorized representativ	e owner of relaws of thi	EQUIREMENTS record and that I have been is jurisdiction. In addition	□ Not in District or Landmark □ Does Not Require Review □ Requires Review Action: □ Approved □ Approved with Conditions □ Denied
authorized by the owner to make this application a if a permit for work described in the application is	e named property, or that the propose as his authorized agent and I agree to issued, I certify that the code official	o conform to all applicable al's authorized representativ	e owner of relaws of thi	EQUIREMENTS record and that I have been is jurisdiction. In addition	□ Not in District or Landmark □ Does Not Require Review □ Requires Review Action: □ Approved □ Approved with Conditions □ Denied
authorized by the owner to make this application a if a permit for work described in the application is	e named property, or that the propose as his authorized agent and I agree to issued, I certify that the code official	o conform to all applicable al's authorized representative code(s) applicable to such p	e owner of relaws of thi	EQUIREMENTS record and that I have been is jurisdiction. In addition	□ Not in District or Landmark □ Does Not Require Review □ Requires Review Action: □ Approved □ Approved with Conditions □ Denied

(205) 054 0502

Child Chedred platform + fining around platform OK to close primate music Type Foundation: Framing:	COMMENTS	
Inspection Record Type Poundation: Framing:		
Inspection Record Type Foundation: Framing:		
Inspection Record Type Foundation: Framing:	0/11/44 Checled platform + faving around statform	
Type Date Foundation: Framing:	OK to Clive penul	
Type Date Foundation: Framing:	- Wing	
Type Date Foundation: Framing:		
Type Date Foundation: Framing:	I (* D. 1	
Foundation: Framing:		Date
	Foundation:	
Plumbing	Framing:Plumbing:	

Final: ______
Other: _____

BUILDING PERMIT REPORT
DATE: 2/June/99 ADDRESS: 940 Congress 57. CBL: 065-64003
DATE: 2/June/99 ADDRESS: 940 Congress 57. CBL: 065-6+003 REASON FOR PERMIT: To Construct deck on grade (P.T. Wood)
BUILDING OWNER: ANThon & Regios
PERMIT APPLICANT: /Contractor Dan Bauchen
USE GROUP A-3 BOCA 1996 CONSTRUCTION TYPE 5 B
CONDITION(S) OF APPROVAL
This permit is being issued with the understanding that the following conditions are met:
Approved with the following conditions: */ *// * 13 *23 *23 *32 *33
This permit does not excuse the applicant from meeting applicable State and Federal rules and laws. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained.

(A 24 hour notice is required prior to inspection)

- Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 3. 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2
- 4. Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6' o.c. between bolts. (Section 2305.17)
- 5. Waterproofing and damp proofing shall be done in accordance with Section 1813.0 of the building code.
- Precaution must be taken to protect concrete from freezing. Section 1908.0 6.
- It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify 7. that the proper setbacks are maintained.
- 8. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4, Section 407.0 of the BOCA/1996)
- All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993). Chapter 12 & NFPA 211
- Sound transmission control in residential building shall be done in accordance with Chapter 12, Section 1214.0 of the City's Building Code.
- **X** 11. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2, M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 3e4" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0) - Handrails shall be on both sides of stairway. (Section 1014.7)
 - Headroom in habitable space is a minimum of 7'6". (Section 1204.0)
- **1**3. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 %" maximum rise. All other Use Group minimum 11" tread, 7" maximum rise. (Section 1014.0)
 - 14. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6'8") 1014.4
 - 15. Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. (Section 1018.6)
 - Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits 16. directly from the apartment to the building exterior with no communications to other apartment units. (Section 1010.1)
 - 17. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) (Section 710.0)

- 18. The boiler shall be protected by enclosing with (1)hour fire rated construction including fire doors and ceiling, or by providing automatic extinguishment. (Table 302.1.1)
- 19. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 &19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required) Section 920.3.2. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved

type. (Section 921.0)

- 21. The Fire Alarm System shall maintained to NFPA #72 Standard.
- 22. The Sprinkler System shall maintained to NFPA #13 Standard.
- All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023.0 & 1024.0 of the City's Building Code. (The BOCA National Building Code/1996)
 - 24. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
 - 25. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification the Division of Inspection Services.
- 26. Ventilation shall meet the requirements of Chapter 12 Sections 1210.0 of the City's Building Code. (Crawl spaces & attics).
- All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade. No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.
 - 28. All requirements must be met before a final Certificate of Occupancy is issued.
 - 29. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code (the BOCA National Building Code/1996).
 - 30. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993). (Chapter M-16)
 - 31. Please read and implement the attached Land Use Zoning report requirements.
- X 32. Boring, cutting and notching shall be done in accordance with Sections 2305.4.4, 2305.5.1 and 2305.5.3 of the City's Building Code.
 - 33. Glass and glazing shall meet the requirements of Chapter 24 of the building code.

36.

zti McDougall, PFD Marga Schmuckal, Zoning Administrator

es, Building Inspector

PSH 12-14-98 // // // S

35.

**On the basis of plans submitted and conditions placed on these plans any deviations shall require a separate approval.



Dept. of Planning and Urban Development Joseph E. Gray, Jr. Director

CITY OF PORTLAND

June 1, 1999

Anthony Regios 19 Veranda Drive Gorham, ME 04038

RE: 940 Congress St., Portland, ME., CBL 065-G-003

Dear Sir:

After my review of your building permit application dated May 20, 1999, and placed on my desk for review on May 27, 1999, I found the following items that <u>DO NOT</u> meet building code requirements. Therefore, not allowing me to issue your building permit.

- 1. The proposed floor joists are 2"x6" spanning 12'. The minimum requirement for a span of 12' carrying a 125 PSF live load (assembly platform) would be 2"x12" at 12" O.C.
- 2. Your application did not show any type of foundation 10" piers on footings 4' below grade with anchors between footing, piers and framing would be a minimum requirement.
- 3. The proposed ramp does not have any details Section 1016.0 of the building code has these requirements.
- 4. The proposed guard around the deck does not meet the requirement of Section 1021.0 of the building code (Section 1021.3 opening limitations).


Please call me if you have any questions on these requirements.


P. pampel Hoffses

Sincerely,

Building Inspections

Hune 199 Talked with owner and contrador The 2x6 Joist will be resting the entire Length and The ground - No opening between grade on sorsts. All Material To be P.T. Wood All





GREYHOUND

VAller 131 DRIVEWAY FRONT ENTRAVE REAR EXIT 3' RESTAURANT PARKING LOT 10 / 541 PIZZA APT DOOR PROPOSED DECK VILLA INTERIOR 24 OPEN PASSAGE 3004 G' FENCE/WALL Shows 34 RAISED OPEN AIR DECK LOUNCE 50' RAMP FROM GROUND TO 94 RAISED DECK REAR EXIT 3 2 PAVENENT 11 APT DOOR FRONT ENTRANCE SERVICE GATE 25% 6' FENCE/WALL 101 20' for rear (equired only)

GREYHOUND CHANLINK FENCE

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

Building or Use Permit Pre-Application Attached Single Family Dwellings/Two-Family Dwelling

Multi-Family or Commercial Structures and Additions Thereto

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

NOTE**If you or the property owner owes real estate or personal property taxes or user charges on ANY PROPERTY within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Addressof Construction (include Portion of Building):	7 940 CONDRESS ST.	04/02		
Total Square Footage of Proposed Structure	Square Footage of Lot	2484		
Tax Assessor's Chart, Block & Lot Number	Owner:	Telephone#:		
Chart# 065 Block# G Lot# 002	Anthony Regios	839-7014		
Owner's Address: 19 Veranda Dr	Lessee/Buyer's Name (If Applicable)	Cost Of Work: Fee		
Gorham, Mc. 04038	N/A	\$ 4000.00 \$40		
Proposed Project Description: (Please be as specific as possible) Wth wall Fence to	Raised, open air deck accomadate outdoor o	to be enclosed		
Contractor's Name, Address & Telephone Don Brancher 12 K	ennedy Once Bidd Ford	283 . 8508 Rec'd By		
Current Use:	Proposed Use:			
Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.				

•All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II. • All plumbing must be conducted in compliance with the State of Maine Plumbing Code.

•All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.

•HVAC(Heating, Ventililation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code.

You must Include the following with you application:

1) ACopy of Your Deed or Purchase and Sale Agreement 2) A Copy of your Construction Contract, if available

3) A Plot Plan/Site Plan

Minor or Major site plan review will be required for the above proposed projects. The attached checklist outlines the minimum standards for a site plan.

4) Building Plans

Unless exempted by State Law, construction documents must be designed by a registered design profes

A complete set of construction drawings showing all of the following elements of construction:

- Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.

Certification

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant:	Colo	Rein	Date:	<u> </u>	20/	99
		0 0			-0 /	

Building Permit Fee: \$25.00 for the 1st \$1000.cost plus \$5.00 per \$1,000.00 construction cost thereafter. Additional Site review and related fees are attached on a separate addendum

DEPT. OF BUILDING INSPECTION

APPLICATION FOR EXEMPTION FROM SITE PLAN REVIEW

the thirt is		<u> </u>			
Applicant	Application	Application Date			
Applicant's Mailing Address		ame/Description			
Consultant/Agent/Phone Number	Address of Proposed Site				
Sonsultand regiment mone realmost	Address of Proposed Site				
Description of Proposed Development:					
	· **	· · · · · · · · · · · · · · · · · · ·			
Please Attach Sketch/Plan of Proposal/Development	Applicant's Assessment (Yes, No, N/A)	Planning Office Use Only			
	(165, NO, N/A)	Ose Omy			
Criteria for Exemptions:					
See Section 14-523 (4)					
		/			
a) Within Existing Structures; No New Buildings,					
Demolitions or Additions					
		No.			
o) Footprint Increase Less Than 500 Sq. Ft.					
c) No New Curb Cuts, Driveways, Parking Areas		<u> </u>			
D. Cooks and Cities all a in Cooks Cookidant					
d) Curbs and Sidewalks in Sound Condition/ Comply with ADA					
	-	<u> </u>			
e) No Additional Parking / No Traffic Increase					
f) No Stormwater Problems		\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \			
	,				
g) Sufficient Property Screening					
	•				
h) Adequate Utilities		V. Landon			
Planning Office Use Only:					
Exemption Granted Partial Exemp	tion Exemption Denied	<u> </u>			
	-				
Planner's Signature	Date				