

389 Congress St.Rm 315  
Portland, ME 04101  
Phone: (207)874-8700  
Fax: (207)874-8716

# facsimile transmittal


**To:** Richard Curtis **From:** Mike Nugent

**Fax:** 774-4016 **Date:** October 1, 2002

**Phone:** **Pages:** 1

**Re:** 930 Cumberland Ave.(065-H002)

Urgent  For Review  Please Comment  Please Reply  Please Recycle



I have commenced the review of the above project and need the following information:

- 1) The structural plans (page S1.1 & S1.2) are not stamped.
- 2) Attached is Section 1705 of the BOCA Code. Astatement of Special

Inspections must be submitted for review prior to the issuance of the permit.

.....