


•
•
•
•
•
•
•

389 Congress St.Rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal

To: Guy Labrecque
From: Mike Nugent
Fax: 774-4016
Date: August 14, 2002
Phone: 774-4441
Pages: 1
Re: Carvel Building /H.P.Hood (066 A010) **CC:** Paul Becker

Urgent For Review Please Comment Please Reply Please Recycle



• • • • •
In reviewing the plans for the Bottle Manufacturing Facility, I have a few questions;

- 1) The second means of Egress seem to be an overhead door. I find no provisions in Section 1017.4 of the BOCA Code that allow an overhead door as a means of egress doorway. The other door appears to go to a restroom, according to the submission.
- 2) We had discussed an existing headroom issue on the catwalk door, how much headroom did we end up with?
- 3) A Statement of Special Inspections is required pursuant to Section 1705. for the applicable components of construction.

• • • • •