



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 125 St James St 066-D-004

Issued to The Goodman Company Date of Issue 30 April 1997

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 970057, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

Warehouse/Office/Showroom

Limiting Conditions: TEMPORARY:

The three (3) ceiling mounted heating units installed under Permit #970367, dated 29 April 1997, that did not meet the structural load capacity of the existing roof structure be corrected no later than 30 May 1997.

This certificate supersedes certificate issued

Approved:

4-30-97 *[Signature]*

(Date)

Inspector

[Signature]

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.