


970367

FILL IN AND SIGN WITH INK



APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine,

To the INSPECTOR OF BUILDINGS, PORTLAND, ME. 28 April 1997

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 125 St James St Use of Building Comm No. Stories 1 New Building Existing "
Name and address of owner of appliance Myles Goodman
Installer's name and address Gerber Co. Charles D. Aceto Telephone 77-52402
P.O. Box 764 Ptld, ME 04104

General Description of Work

To install Oil fired forced hot air heating system

IF HEATER, OR POWER BOILER

Location of appliance Ground Level Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? #2 oil
Minimum distance to burnable material, from top of appliance or casing top of furnace n/a
From top of smoke pipe none From front of appliance none From sides or back of appliance none
Size of chimney flue 10" Other connections to same flue no
If gas fired, how vented? Rated maximum demand per hour 3 @ 100,000
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? Yes 1 @ 125,000

IF OIL BURNER

Name and type of burner Beckett Labelled by underwriters' laboratories? Yes
Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 2"
Location of oil storage Ground level Number and capacity of tanks 2-275
Low water shut off Make No.
Will all tanks be more than five feet from any flame? Yes How many tanks enclosed? none
Total capacity of any existing storage tanks for furnace burners 2-275

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Charles D. Aceto Oil & Solid Fuel #1380
Cost of Work: 25,000.00 XXXXXXXXXX XXXXXX 145.00

- 1. Name of applicant
2. Name of contractor
3. Name of inspector
4. Name of owner
5. Remedy
6. Main line control
7. High limit control
8. Main line control
9. Low water shut off
10. High limit control
11. High limit control
12. Valves in supply line
13. Capacity of tanks
14. Tank register & support
15. Oil gauge
16. Instruction copy
17. Oil leaks
18. Adequate venting
19. Adequate venting
20. Adequate venting

APPROVED:

PERMIT ISSUED WITH REQUIREMENTS

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?
Signature of Installer Charles D. Aceto

Signature of Assessor Charles D. Aceto