CITY OF PORTLAND, MAINE
PLANNING & URBAN DEVELOPMENT
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 02/29/16

Covered Porch @ rear of house

Staircase approx. 9 ft by 4 ft per e-mail from applicant

Stair Framing Detail

72x48 Landing

2x8 Framing attached to house w/ (2) 4x4 Posts

460 Saint John St
Rear porch egress stair
CBL 066 F019001

42" Guard covered with Lattice

60" ± from grade

Handrail on side of house

(4) 2x12 Stringers evenly spaced
10.5" Step w/ 3/4-1 1/4 nosing
6" risers

Stringer