



... Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION
84 HACKETT MILLS ROAD
P.O. BOX 156
POLAND, ME 04274
207-998-2551

Job Name : West Attic
Drawing : FP-03
Location : NATHAN CLIFFORD RESIDENCE
Remote Area : #4
Contract : 020714-1
Data File : West Attic.WXF

HYDRAULIC CALCULATIONS
for

Project name: West Attic
Location: NATHAN CLIFFORD RESIDENCE
Drawing no: FP-03
Date: 4/29/14

Design

Remote area number: #4
Remote area location: WEST ATTIC
Occupancy classification: LIGHT HAZARD
Density: .1 - Gpm/SqFt
Area of application: 1950 - SqFt
Coverage per sprinkler: 130 - SqFt
Type of sprinklers calculated: QUICK RESPONSE UPRIGHTS
No. of sprinklers calculated: 18
In-rack demand: N/A - GPM
Hose streams: 0 - GPM
Total water required (including hose streams): 297 - GPM @ 71 - Psi
Type of system: DRY SYSTEM
Volume of dry or preaction system: 250 - Gal

Water supply information

Date: 4-30-14
Location: TEST HYDRANT ON FALMOUTH ST. IN FRONT OF BUILDING
Source: PORTLAND WATER DISTRICT

Name of contractor: HIGH TECH FIRE PROTECTION
Address: 84 HACKETT MILLS ROAD / P.O. BOX 156 / POLAND, ME 04274
Phone number: 207-998-2551
Name of designer: ED POULIN
Authority having jurisdiction: STATE OF MAINE / CITY OF PORTLAND
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
West Attic

Page 2
Date 4-30-14

City Water Supply:
C1 - Static Pressure : 84
C2 - Residual Pressure: 82
C2 - Residual Flow : 1162

Demand:
D1 - Elevation : 24.687
D2 - System Flow : 296.561
D2 - System Pressure : 71.050
Hose (Demand) : _____
D3 - System Demand : 296.561
Safety Margin : 12.791



Fittings Used Summary

HIGH TECH FIRE PROTECTION
West Attic

Page 3
Date 4-30-14

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Dvc	Dry Vic 768 NXT					3	9	8	17		21		22	50							
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
West Attic

Page 4
Date 4-30-14

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
500	69.0	5.6	7.78	na	15.62	0.1	130	7.0
501	69.0	5.6	7.92	na	15.76	0.1	130	7.0
502	69.0	5.6	8.43	na	16.26	0.1	130	7.0
510	69.0	5.6	8.28	na	16.11	0.1	130	7.0
511	69.0	5.6	8.43	na	16.26	0.1	130	7.0
512	69.0	5.6	8.96	na	16.77	0.1	130	7.0
513	69.0		9.93	na				
520	69.0	5.6	8.6	na	16.42	0.1	130	7.0
521	69.0	5.6	8.75	na	16.57	0.1	130	7.0
522	69.0	5.6	9.31	na	17.09	0.1	130	7.0
523	69.0		10.31	na				
524	69.0		10.92	na				
525	64.0		13.98	na				
530	69.0	5.6	7.07	na	14.89	0.1	130	7.0
531	69.0	5.6	7.19	na	15.02	0.1	130	7.0
532	69.0	5.6	7.65	na	15.49	0.1	130	7.0
540	69.0	5.6	7.0	na	14.82	0.1	130	7.0
541	69.0	5.6	7.13	na	14.95	0.1	130	7.0
542	69.0	5.6	7.58	na	15.42	0.1	130	7.0
543	69.0		9.02	na				
544	64.0		14.79	na				
550	69.0	5.6	12.0	na	19.4	0.1	130	7.0
551	69.0	5.6	12.2	na	19.56	0.1	130	7.0
552	69.0	5.6	12.96	na	20.16	0.1	130	7.0
553	69.0		14.33	na				
554	69.0		14.97	na				
555	64.0		18.77	na				
545	64.0		19.23	na				
4D	64.0		32.73	na				
1D	10.0		62.98	na				
TOD	10.0		64.75	na				
BOD	3.0		69.4	na				
BASE	3.0		70.1	na				
UG	0.0		75.32	na				
HS1	0.0		76.09	na				
HS2	0.0		76.13	na				
TEST	12.0		71.05	na				

The maximum velocity is 13.97 and it occurs in the pipe between nodes 544 and 545

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
West Attic

Page 5
Date 4-30-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
500 to 501	15.62	1.682 100.0		0.0 0.0	12.000 0.0	7.783 0.0			K Factor = 5.60	
501 to 502	15.62	0.0116		0.0	12.000	0.139			Vel = 2.26	
501 to 502	15.77	1.682 100.0		0.0 0.0	12.000 0.0	7.922 0.0			K Factor = 5.60	
502 to 513	31.39	0.0421		0.0	12.000	0.505			Vel = 4.53	
502 to 513	16.25	1.682 100.0	1E	3.533 0.0	13.000 3.533	8.427 0.0			K Factor = 5.60	
	47.64	0.0912		0.0	16.533	1.507			Vel = 6.88	
	0.0 47.64						9.934		K Factor = 15.12	
510 to 511	16.11	1.682 100.0		0.0 0.0	12.000 0.0	8.281 0.0			K Factor = 5.60	
511 to 512	16.11	0.0122		0.0	12.000	0.147			Vel = 2.33	
511 to 512	16.26	1.682 100.0		0.0 0.0	12.000 0.0	8.428 0.0			K Factor = 5.60	
512 to 513	32.37	0.0446		0.0	12.000	0.535			Vel = 4.67	
512 to 513	16.77	1.682 100.0	1T	7.065 0.0	3.000 7.066	8.963 0.0			K Factor = 5.60	
	49.14	0.0965		0.0	10.066	0.971			Vel = 7.10	
513 to 523	47.64	2.635 100.0		0.0 0.0	10.000 0.0	9.934 0.0				
	96.78	0.0380		0.0	10.000	0.380			Vel = 5.69	
	0.0 96.78						10.314		K Factor = 30.14	
520 to 521	16.42	1.682 100.0		0.0 0.0	12.000 0.0	8.601 0.0			K Factor = 5.60	
521 to 522	16.42	0.0127		0.0	12.000	0.153			Vel = 2.37	
521 to 522	16.57	1.682 100.0		0.0 0.0	12.000 0.0	8.754 0.0			K Factor = 5.60	
522 to 523	32.99	0.0462		0.0	12.000	0.554			Vel = 4.76	
522 to 523	17.09	1.682 100.0	1T	7.065 0.0	3.000 7.066	9.308 0.0			K Factor = 5.60	
	50.08	0.0999		0.0	10.066	1.006			Vel = 7.23	
523 to 524	96.78	2.635 100.0	1E	5.879 0.0	1.500 5.879	10.314 0.0				
	146.86	0.0821		0.0	7.379	0.606			Vel = 8.64	
524 to 525	0.0	2.635 100.0	1E	5.879 0.0	5.000 5.879	10.920 2.166				
	146.86	0.0822		0.0	10.879	0.894			Vel = 8.64	
525 to 544	0.0	2.635 100.0		0.0 0.0	9.900 0.0	13.980 0.0				
	146.86	0.0821		0.0	9.900	0.813			Vel = 8.64	
	0.0 146.86						14.793		K Factor = 38.18	
530 to 531	14.89	1.682 100.0		0.0 0.0	12.000 0.0	7.066 0.0			K Factor = 5.60	
	14.89	0.0106		0.0	12.000	0.127			Vel = 2.15	

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
West Attic

Page 6
Date 4-30-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
531 to 532	15.01 29.9	1.682 100.0 0.0385		0.0 0.0 0.0	12.000 0.0 12.000	7.193 0.0 0.462			K Factor = 5.60 Vel = 4.32	
532 to 543	15.50 45.4	1.682 100.0 0.0834	1E 1T	3.533 7.065 0.0	5.750 10.599 16.349	7.655 0.0 1.363			K Factor = 5.60 Vel = 6.56	
	0.0 45.40						9.018		K Factor = 15.12	
540 to 541	14.82 14.82	1.682 100.0 0.0105		0.0 0.0 0.0	12.000 0.0 12.000	7.000 0.0 0.126			K Factor = 5.60 Vel = 2.14	
541 to 542	14.95 29.77	1.682 100.0 0.0382		0.0 0.0 0.0	12.000 0.0 12.000	7.126 0.0 0.458			K Factor = 5.60 Vel = 4.30	
542 to 543	15.42 45.19	1.682 100.0 0.0827	1E 1T	3.533 7.065 0.0	6.750 10.599 17.349	7.584 0.0 1.434			K Factor = 5.60 Vel = 6.52	
543 to 544	45.40 90.59	1.682 100.0 0.2991	1T	7.065 0.0 0.0	5.000 7.066 12.066	9.018 2.166 3.609			Vel = 13.08	
544 to 545	146.85 237.44	2.635 100.0 0.1999	2V 1X	8.426 10.582 0.0	3.200 19.009 22.209	14.793 0.0 4.439			Vel = 13.97	
	0.0 237.44						19.232		K Factor = 54.14	
550 to 551	19.40 19.4	1.682 100.0 0.0173		0.0 0.0 0.0	12.000 0.0 12.000	11.997 0.0 0.208			K Factor = 5.60 Vel = 2.80	
551 to 552	19.56 38.96	1.682 100.0 0.0628		0.0 0.0 0.0	12.000 0.0 12.000	12.205 0.0 0.753			K Factor = 5.60 Vel = 5.63	
552 to 553	20.16 59.12	1.682 100.0 0.1359	1T	7.065 0.0 0.0	3.000 7.066 10.066	12.958 0.0 1.368			K Factor = 5.60 Vel = 8.54	
553 to 554	0.0 59.12	1.682 100.0 0.1359	1E	3.533 0.0 0.0	1.200 3.533 4.733	14.326 0.0 0.643			Vel = 8.54	
554 to 555	0.0 59.12	1.682 100.0 0.1358	1T	7.065 0.0 0.0	5.000 7.066 12.066	14.969 2.166 1.639			Vel = 8.54	
555 to 545	0.0 59.12	2.635 100.0 0.0153	2V 1X	8.426 10.582 0.0	11.000 19.009 30.009	18.774 0.0 0.458			Vel = 3.48	
545 to 4D	237.44 296.56	3.26 100.0 0.1069	4V	19.184 0.0 0.0	107.000 19.184 126.184	19.232 0.0 13.495			Vel = 11.40	
4D to 1D	0.0 296.56	3.26 100.0 0.1070	4V	19.184 0.0 0.0	45.000 19.184 64.184	32.727 23.387 6.865			Vel = 11.40	

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
West Attic

Page 7
Date 4-30-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1D to TOD	0.0 296.56	4.26 100.0 0.0291	2V 12.78 0.0 0.0	48.000 12.780 60.780	62.979 0.0 1.766		Vel = 6.68		
TOD to BOD	0.0 296.56	4.26 100.0 0.0291	1Dvc 19.734 1T 18.795 1B 11.277	6.000 49.806 55.806	64.745 3.032 1.622		Vel = 6.68		
BOD to BASE	0.0 296.56	4.26 120.0 0.0207	1V 8.954 1X 21.067 0.0	4.000 30.021 34.021	69.399 0.0 0.705		Vel = 6.68		
BASE to UG	0.0 296.56	4.26 120.0 0.0208	1V 8.954 1Zia 0.0 0.0	1.000 8.954 9.954	70.104 5.008 0.207		* Fixed loss = 3.709 Vel = 6.68		
UG to HS1	0.0 296.56	6.16 140.0 0.0026	2E 40.168 1T 43.037 1G 4.304	210.000 87.509 297.509	75.319 0.0 0.770		Vel = 3.19		
HS1 to HS2	0.0 296.56	8.23 100.0 0.0012	1T 29.011 0.0 0.0	10.000 29.010 39.010	76.089 0.0 0.046		Vel = 1.79		
HS2 to TEST	0.0 296.56	6.14 100.0 0.0049	1G 2.273 1E 10.608 0.0	10.000 12.881 22.881	76.135 -5.197 0.112		Vel = 3.21		
	0.0 296.56				71.050		K Factor = 35.18		