



Permitting and Inspections Department
Michael A. Russell, MS, Director

October 25, 2017

NATHAN CLIFFORD LLC
100 COMMERCIAL ST STE 414
PORTLAND, ME 04101

CBL: 066A A001001
Located at: 172 FALMOUTH ST

Certified Mail 70141820000140495310

Dear NATHAN CLIFFORD LLC,

POSTING NOTICE

An evaluation of the above-referenced property on 10/20/2017 revealed that the structure fails to comply with Section 6-120.1 of the Housing Code of the City of Portland.

Attached is a list of the violations.

Based on that list, and pursuant to Section 6-120.3, this office declares the dwelling unit is unfit for human habitation. A re-inspection of the premises will occur on 11/29/2017, at which time the dwelling unit must be totally vacated and secured from vandalism.

Failure to comply will result in this office referring the matter to the City of Portland Corporation Counsel for legal action and possible civil penalties, as provided for in Section 1-15 of the Code in Title 30-A of M.R.S.A ss 4452.

This constitutes an appealable decision pursuant to Section 6-127 of the Code. Please feel free to contact me if you have any questions or would like to discuss this matter further.

Sincerely,

A handwritten signature in black ink, appearing to read "Doug Morin".

Doug Morin
CEO/Plan Review
(207) 874-8705

CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400

NOTICE OF VIOLATION AND ORDER TO CORRECT

October 25, 2017

Location 172 FALMOUTH ST	CBL 066A A001001	Inspection Date 10/20/2017
Inspector Doug Morin	Inspection Type FP Complaint	Status Violations Exist

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 11/15/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 101- 7.5.1.1.1 EXIT(S) OBSTRUCTED; Where exits are not immediately accessible from an open floor area, continuous passageways, aisles, or corridors leading directly to every exit shall be maintained and shall be arranged to provide for each occupant to not less than two exits by separate ways of travel, unless otherwise provided in 7.5.1.1.3 and 7.5.1.1.4. Enclosed Egress Stairwell damaged from motor vehicle crash.	
NFPA 70- ARTICLE 110.12 EXPOSED WIRES; Internal parts of electrical equipment, including busbars, wiring terminals, insulators, and other surfaces, shall not be damaged or contaminated by foreign materials such as paint, plaster, cleaners, abrasives, or corrosive residues. There shall be no damaged parts that may adversely affect safe operation or mechanical strength of the equipment such as parts that are broken, bent, cut, or deteriorated by corrosion, chemical reaction, or overheating. Conduit and junction boxes damaged from motor vehicle crash	
FINAL DATE OF COMPLETED VIOLATION(S)	___/___/___
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	___/___/___

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

Date Responsible Party

Date Responsible Party

SEEN AND AGREED

Date Fire Prevention Bureau