

CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
 389 Congress Street
 Portland, Maine 04101

Inspection Violations

Owner/Manager BIXLER JANET I		Inspector Tammy Munson	Inspection Date 8/4/2006
Location 63 PAYSON ST	CBL 066A A017001	Status Posting Notice	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-120.1 thru 5	Exterior			Various locations	
Violation: Posted against occupancy.					
Notes: Remove/secure all structural Hazards					
2) 6-108.1	Exterior			Various locations	
Violation: Foundations cellars, exterior walls, roofs					
Notes: Secure Building from entry & Vandalism					
3) 6-108.1	Exterior			Various locations	
Violation: Foundations cellars, exterior walls, roofs					
Notes: Structure shall be made substantially weather tight					
Comments: All violations must be corrected within 5 Days. All applicable permits shall be applied for & issued prior to restoration.					