

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

| | | | | | | | |
|--|--|--|--|---|--|--|--|
| Location of Construction: 80 Roberts Street | | Owner: J. Ouellette | | Phone: | | Permit No: 971104 | |
| Owner Address: | | Lessee/Buyer's Name: Henry Griffin | | Phone: 874-2463 | | Business Name: | |
| Contractor Name: | | Address: | | Phone: | | Permit Issued: OCT 15 1997 CITY OF PORTLAND | |
| Past Use: 3 unit dwelling | | Proposed Use: Same w/ fire-escape reno | | COST OF WORK: \$ 450.00 | | PERMIT FEE: \$ 25.00 | |
| | | | | FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied | | INSPECTION: Use Group: Type: | |
| Proposed Project Description: erect fire-escape as per plans | | Signature: [Signature] | | Signature: [Signature] | | Zone: CBL: CLA-F-1 | |
| | | PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) | | Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied | | Zoning Approval: Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/> | |
| Permit Taken By: Vicki Dover | | Date Applied For: 9/29/97 | | Signature: _____ | | Date: _____ | |

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

Mail to H. Griffin
80 Roberts St., Rm Apt 1
Portland 04102

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT **Henry Griffin** ADDRESS: _____ DATE: **9/29/97** PHONE: **874-2463**

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE _____ PHONE: _____

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

PERMIT ISSUED WITH REQUIREMENTS

- Zoning Appeal**
- Variance
 - Miscellaneous
 - Conditional Use
 - Interpretation
 - Approved
 - Denied

- Historic Preservation**
- Not in District or Landmark
 - Does Not Require Review
 - Requires Review

- Action:**
- Approved
 - Approved with Conditions
 - Denied

Date: _____

CEO DISTRICT



City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

| | | | | | |
|---|--|---|--|--|--|
| Location of Construction: 80 Roberts Street | | Owner: J. Ouellette | | Phone: | |
| Owner Address: | | Lessee/Buyer's Name: Henry Griffin | | Phone: 874-2463 | |
| Contractor Name: | | Address: | | Phone: | |
| Past Use: 3 unit dwelling | | Proposed Use: Same w/ fire escape reno <i>construct Roof Walkway</i> | | COST OF WORK: \$450.00 | |
| | | | | PERMIT FEE: \$25.00 | |
| Proposed Project Description: <i>Roof Walkway</i> erect fire escape as per plans | | Signature: <i>[Signature]</i> | | INSPECTION: Use Group <i>A2</i> Type <i>5B</i> Signature: <i>[Signature]</i> | |
| Permit Taken By: Vicki Dover | | Date Applied For: 9/29/97 | | PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____ | |



Zone: *R-5* CBL: *66A-F-1*
 Zoning Approval: *3 units of per only for this*
 Special Zone or Reviews:
 Shoreland *Section of*
 Wetland *Access - not*
 Flood Zone *to expand*
 Subdivision *any where*
 Site Plan maj minor mm
else - d - 8/17/97
 Zoning Appeal
 Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

Mail to H. Griffin
 80 Roberts St., ~~RXX~~ Apt 1
 Portland 04102



CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

Henry W. Griffin *same* 9/29/97 874-2463
 SIGNATURE OF APPLICANT Henry Griffin ADDRESS: DATE: PHONE:


RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

Historic Preservation
 Not in District or Landmark
 Does Not Require Review
 Requires Review
 Action:
 Approved
 Approved with Conditions
 Denied
 Date: *9/30/97*
[Signature]
 CEO DISTRICT *#5*
D Jordan

COMMENTS

2/6/04 - Closed by T. Mackley - all conditions of the permit appear to be met.



CBC # 66-AF-1

permit # 971104

| | Type | Inspection Record | Date |
|-------------|-------|-------------------|-------|
| Foundation: | _____ | _____ | _____ |
| Framing: | _____ | _____ | _____ |
| Plumbing: | _____ | _____ | _____ |
| Final: | _____ | _____ | _____ |
| Other: | _____ | _____ | _____ |



CITY OF PORTLAND, MAINE

FINANCE DEPARTMENT
TREASURY AND COLLECTION DIVISION
SEWER USER FUND

P.O. BOX 544, 1 CANAL PLAZA
PORTLAND, MAINE 14112

PHONE
874-8300

Quollette, Jacelyn R YEAR 96A1
ACCOUNT NO. 011890

CBL ACCOUNT
*97 SEP 28 PM 1:02
THANK YOU
CITY OF PORTLAND*

| | |
|----------|-----------|
| SEWER | 284.91 |
| INTEREST | 27.13 |
| TOTAL | \$ 311.34 |

This bill becomes a receipt when perforated "PAID".
KEEP YOUR RECEIPT. The payment of this bill does
not prevent the collection of previous unpaid taxes.

BUILDING PERMIT REPORT


DATE: 10/14/97 ADDRESS: 80 Roberts St
REASON FOR PERMIT: Erect Fire Escaps
BUILDING OWNER: J. Quелlette
CONTRACTOR: Henry Griffin
PERMIT APPLICANT: Henry Griffin APPROVAL: *1, *8, *10, *11, *16 *30 DENIED
USE GROUP R-2 BOCA 1996 CONSTRUCTION TYPE 5B

CONDITION(S) OF APPROVAL

- * 1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
3. Precaution must be taken to protect concrete from freezing.
4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993).
7. Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's building code.
8. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 34" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".)
9. Headroom in habitable space is a minimum of 7'6".
10. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. (All other Use group minimum 11" tread, 7" maximum rise.)
- * 11. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6' 8")
12. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
13. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
14. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's.
15. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
- * 16. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms

In each story within a dwelling unit, including basements
In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required)


- 17. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type.
- 18. The Fire Alarm System shall be maintained to NFPA #72 Standard.
- 19. The Sprinkler System shall maintained to NFPA #13 Standard.
- 20. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)
- 21. **No construction or demolition work shall begin until you have obtained permits for dumpsters or containers. A work Stop Order shall be issued if this requirement is not met.**
- 22. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
- 23. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
- 24. This permit does not excuse the applicant from obtaining any license which may be needed from the City Clerk's office.
- 25. Ventilation shall meet the requirements of Chapter 12 Sections 1210. of the City's Building Code.
- 26. All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade.
- 27. All requirements must be met before a final Certificate of Occupancy is issued.
- 28. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code. (The BOCA National Building Code/1996).
- 29. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993).
- 30. *Fire escape shall discharge at ground level*
- 31. *This building is a (3) Three dwelling unit, only - This per - m/c does not authorize any additional dwelling units*
- 32.
- 33.
- 34.



P. Samuel Hoffes, Code Enforcement

cc: Lt. McDougall, PFD
Marge Schumuckal

W. J. McOy

CLYDE COUNTY, MINN.
DEPT. OF SHERIFFS & RECEPTION






PRIV
fire
escape

ROBERTS ST

FALMOUTH ST



DEPT. OF BUILDING INSPECTION
CITY OF BURLINGTON
28 11 01

APPRX 15'

≈ 50'

← ≈ 30' →

BACK DECK

Front Porch