

CITY OF PORTLAND
FIRE PREVENTION BUREAU
380 Congress Street, Portland, Maine 04101
fireprevention@portlandmaine.gov
(207) 874-8400



NOTICE OF VIOLATION AND ORDER TO CORRECT

July 31, 2017

Responsible Party 1: LUCY MILLS 68 ROBERTS ST PORTLAND ME 04102		
Location 68 ROBERTS ST	CBL 066A F004001	Inspection Date 7/10/2017
Inspector Paul Halverson	Inspection Type FP Routine Inspection	Status

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 8/15/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 1- 19.1.2 INSIDE STORAGE NOT ORDERLY; Persons owning or having control of any property shall not allow any combustible waste material to accumulate in any area or in any manner that creates a fire hazard to life or property. Excess storage in basement	COMPLETE as of 8/1
NFPA 101- 9.6.10.1.1 SMOKE DETECTOR REQUIRED; Where required by another section of this code, single-station and multiple-station smoke alarms shall be in accordance with NFPA 72, National Fire Alarm Code, shall be provided in all occupiable areas in environments that are suitable for proper smoke detector operation. 1st floor bedroom	8/31/17
FINAL DATE OF COMPLETED VIOLATION(S)	8/31/17
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	___/___/___

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.


VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

8/3/17
Date


Responsible Party

Date

Responsible Party

SEEN AND AGREED

8/16/17
Date

CAPT. JPB 
Fire Prevention Bureau