

**NFPA 13R sprinkler check list**

- Is this check list applicable? yes
- What edition of NFPA 13R is the designed to? boiler fire suppression
- Building construction type: 3 story wooden frame apartment building
- Will the sprinkler system provide complete or partial coverage of the building? partial
- Will covered exterior balconies, decks and ground floor patios be sprinklered? no
- Size of riser assembly: 2 sprinklers
- Fire department connection- number of 2 1/2" inlets: 2
- Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: eastern fire
- Is the nearest fire hydrant within 100 ft. of the FDC? yes
- The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? yes

**NFPA 13 sprinkler check list**

- Is this check list applicable? no
- What edition of NFPA 13 is the designed to? \_\_\_\_\_
- Building construction type: \_\_\_\_\_
- Will the sprinkler system provide complete or partial coverage of the building? \_\_\_\_\_
- System type (See NFPA 13:3.4): \_\_\_\_\_
- NFPA 13 Occupancy Classification (Hazard): \_\_\_\_\_
- Is the structure high-rise (see NFPA 101:3.3.32.7)? \_\_\_\_\_
- Size of riser assembly: \_\_\_\_\_
- Fire department connection- number of 2 1/2" inlets: \_\_\_\_\_
- Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: \_\_\_\_\_
- Is the nearest fire hydrant within 100 ft. of the FDC? \_\_\_\_\_
- The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? \_\_\_\_\_

**NFPA 14 standpipe check list**

- Is this check list applicable? no
- What edition of NFPA 14 is the designed to? \_\_\_\_\_