Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 04/08/16

NFPA 13R sprinkler check list

- ☐ Is this check list applicable? yes
- ☐ What edition of NFPA 13R is the designed to? boiler fire suppression
- ☐ Building construction type: 3 story wooden frame apartment building
- ☐ Will the sprinkler system provide complete or partial coverage of the building? partial
- ☐ Will covered exterior balconies, decks and ground floor patios be sprinklered? no
- ☐ Size of riser assembly: 2 sprinklers
- ☐ Fire department connection- number of 2 ½" inlets: 2
- ☐ Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: eastern fire
- ☐ Is the nearest fire hydrant within 100 ft. of the FDC? yes
- ☐ The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? yes

NFPA 13 sprinkler check list

- ☐ Is this check list applicable? no
- ☐ What edition of NFPA 13 is the designed to? _____
- ☐ Building construction type: _____
- ☐ Will the sprinkler system provide complete or partial coverage of the building? _____
- ☐ System type (See NFPA 13:3.4): _____
- ☐ NFPA 13 Occupancy Classification (Hazard): _____
- ☐ Is the structure high-rise (see NFPA 101:3.3.32.7)? _____
- ☐ Size of riser assembly: _____
- ☐ Fire department connection- number of 2 ½" inlets: _____
- ☐ Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: _____
- ☐ Is the nearest fire hydrant within 100 ft. of the FDC? _____
- ☐ The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? _____

NFPA 14 standpipe check list

- ☐ Is this check list applicable? no
- ☐ What edition of NFPA 14 is the designed to? _____

Building Inspections Division • 389 Congress Street • Portland, Maine 04101 • (207) 874-8703 • FACSIMILE (207) 874-8716 • TTY (207) 874-8936