1 Level 1 - Life Safety Plan
1/8" = 1'-0"

2 Level 2 - Life Safety Plan
1/8" = 1'-0"

Egress-Travel Path Schedule	
Travel Path ID	Travel Distance
	0"
Travel path #1	107' - 9 3/32"
Travel path #2	84' - 0 5/32"
Travel path #3	93' - 2 11/32"
Travel path #4	77' - 4 11/16"
Travel path #5	75' - 1 7/8"
Travel path #6	88' - 6"
Travel path #7	71' - 2 1/8"
Travel path #8	101' - 11 25/32"

O.L.140 O.C.145 — OCCUPANT LOAD / OCCUPANT CAPPACITY

EXIT

EGRESS TRAVEL LINE

AREA NOT IN CONTRACT

Summary
The building consists of an existing single occupant 4 story heavy timber and mass masonry structure served by 2 stairs and an elevator.

The project consists of the renovation of 4,632 sf of 1st floor business use space to reconfigure rooms, and the renovation of 5,533 sf of 2nd floor business use space to reconfigure rooms.

IBC 2009

OCCUPANCY CLASSIFICATION GROUPS:
Business per 304.1

CONSTRUCTION TYPE:
Type III

FIRE PROTECTION SYSTEMS:
Existing Sprinkler System with melt away ceiling tiles.

OCCUPANT LOAD:
Occupant Load of B Occupancy:
Level 1 - 8,858 GSF/100 = 89 Occupants
Level 2 - 8,262 GSF/100 = 83 Occupants
Level 3 - 8,262 GSF/100 = 83 Occupants
Level 4 - 8,262 GSF/100 = 83 Occupants

MEANS OF EGRESS:

Egress width: Corridors/doors @ 0.2"/person (min. 44" in Business occupancy)

Door width: Min. clear 32" Max leaf 48"
Common path of travel: Business IBC 1014.3 - Shall not exceed 100'

Number of exits: Two exits or exit access from any space with greater than 50 person occupancy or where common path of travel distance is exceeded.

Distance to an exit: Business 200 ft (without sprinkler)
Dead end: Business 20 ft

NFPA 101 2009

Partial renovation of an existing building with B Occupancy.

OCCUPANCY CLASSIFICATION GROUPS:
Business per 3.3.178.3

CONSTRUCTION TYPE:
Existing Construction - Type IV-2HH

FIRE PROTECTION SYSTEMS:
Existing Sprinkler System.

OCCUPANT LOAD:
Level 1 - 8,858 GSF/100 = 89 Occupants
Level 2 - 8,262 GSF/100 = 83 Occupants
Level 3 - 8,262 GSF/100 = 83 Occupants
Level 4 - 8,262 GSF/100 = 83 Occupants

NFPA CHAPETERS
Chapter 39 Existing Business Occupancy

MEANS OF EGRESS:
7.3.2.1(1) Exits - Existing to remain
7.2.1.6.2 Access - controlled egress doors - Doors shall be arranged to unlock in the direction of travel.

EXTINGUISHMENT REQUIREMENTS:
9.7.4.1 Manual extinguishing equipment -Class A Hazard - Light/low hazard
Occupancy - Table 6.2.1.1 Distance to fire extinguisher: 75ft

TRAVEL DISTANCE
39.2.5.2 Dead End Corrdiors - Limited to 50 ft.
39.2.5.3.1 Common path of travel - Limited to 100'
39.2.6.2 Travel distance - Limited to 200 ft.

PDT ARCHITECTS
49 DARTMOUTH STREET
PORTLAND, MAINE
04101
207-775-1059
www.pdtarchs.com

COPYRIGHT
PDT Architects
Reuse or reproduction of the contents of this document is not permitted without written permission of PDT Architects.

15 Lowell Street, Portland, Maine 04101

#	Date	Description

Revision Schedule

REGISTERED ARCHITECT DAVID C. WEBSTER No. 923 STATE OF MAINE

JOB NO. 16064

DRWN: Author CHK: Checker

SCALE:

ISSUE: Pricing Set
November 21, 2017

TITLE: Life Safety Plans & Code Summary - Levels 1 & 2

SHEET A003