FIRE ALARM RISER DIAGRAM
SCALE: N.T.S.

SYMBOL LEGEND			
ITEM NO.	SYMBOL	QTY. TOTAL	DESCRIPTION
1	○	10	STANDARD BASE (DB-11) – OCTAGON BOX
2		1	HEAT DETECTOR (HI921) – MOUNTS ON DB-11
3	I	3	LINE ISOLATOR (HLIM) – 4" SQUARE
4	DM	1	DUAL MONITOR MODULE (HTRI-D) – 4" SQUARE
5	M	3	MONITOR MODULE (HTRI-S) – 4" SQUARE
6	P	9	PULL STATION (MSM-KD/HTRI-M) – SINGLE GANG
7	RM	4	INPUT/OUTPUT MODULE (HTRI-R) – 4" SQUARE
8		9	SMOKE DETECTOR (OH921) – MOUNTS ON DB-11
9	XX	53	HORN/STROBE (2H-MC-R) – SINGLE GANG OR 4" SQUARE
10	XX	88	STROBE (2R-MC-R) – SINGLE GANG OR 4" SQUARE
11	ANN	1	ANNUNCIATOR (FT-2015)
12	FACP	1	FIRE ALARM CONTROL PANEL (FC-922)
13	NAC	3	NAC PANEL (PAD-4)

DEVICE WIRING DETAIL
SCALE: N.T.S.

DEVICE ELEVATION DETAIL
NOT TO SCALE

DATE	REVISIONS

REQUIRED APPROVALS
OWNER / ARCHITECT
STATE FIRE MARSHAL
LOCAL FIRE MARSHAL
OWNER'S INSURANCE CO.

DRAWN BY CRM
CHECKED BY
CONTRACTOR LICENSE #

MAINE EYE CARE
15 LOWELL ST PORTLAND, ME 04102

CONTRACT WITH: DEBLOIS ELECTRIC

EASTERN FIRE
FIRE PROTECTION CONTRACTORS AND ENGINEERS
Home Office: 170 Kittyhawk Ave. P.O. Box 1390 Auburn, ME 04210-1390 207-784-1507
www.easternfiregroup.com
Satellite Office: 480 Harlow St. Bangor, ME 04401 207-942-8014

FIRE ALARM SYSTEM
PLANS & DETAILS
DWG. NO. FA-1
JOB NUMBER 1-0583-FA-17
SCALE AS NOTED
DATE 8/24/17

Reviewed for Code Compliance Inspections Division
Date: 12/08/17