



Permitting and Inspections <buildinginspections@portlandmaine.gov>

10 Huntress Street

Jack McNerny <Jack@atlantichardwoods.com>

Wed, Nov 15, 2017 at 1:16 PM

To: Permitting and Inspections <buildinginspections@portlandmaine.gov>

Hi Tori,

The walls that need to be repaired are highlighted in orange. We were planning on using ½" moisture resistant drywall. The kitchen walls will then have a tile backsplash.

The 2nd floor walls were going to be paneled with ¾" t&g boards. Those walls were also stripped to be insulated. (pink)

Thanks,

Jack McNerny

Atlantic Hardwoods, Inc

1004 Congress Street

Portland, Maine 04102

[207-773-9663](tel:207-773-9663)

Portland, Maine. Yes!

Wood's good here.

From: Permitting and Inspections [mailto:buildinginspections@portlandmaine.gov]

Sent: Monday, November 13, 2017 2:35 PM

To: Jack McNerny <Jack@atlantichardwoods.com>

Subject: Re: General Building Permit Application

Good afternoon, Jack,

Please indicate on the drawings which walls are being repaired. The plan reviewer would like to know what kind of sheet rock is being installed.

Also, your heating unit will need to be applied for separately (along with electrical and plumbing permits). I have attached a copy of the application to this email.

Thank you,

Tori

On Wed, Nov 8, 2017 at 10:10 AM, Jack McInerny <Jack@atlantichardwoods.com> wrote:

Please see attached application and call with any questions and concerns.

Thanks!

Jack McInerny
Atlantic Hardwoods, Inc
1004 Congress Street
Portland, Maine 04102
[207-773-9663](tel:207-773-9663)

Portland, Maine. Yes!

Wood's good here.

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

 **walls 10 Huntress Street.pdf**
481K