SECTION 09650

RESILIENT FLOORING

1 PART 1 GENERAL

1.1 RELATED DOCUMENTS

A. Drawings and general provisions of Contract including General and Supplementary Conditions and Division 1 specification sections apply to Work of this section.

1.2 SECTION INCLUDES

A. Resilient sheet, tile flooring and base.

1.3 SYSTEM DESCRIPTION

A. Resilient Flooring: Conform to applicable code for flame/smoke rating requirements of 75/450 in accordance with ASTM E84 and critical radiant flux (CRF) of 0.45 per ASTM E648.

1.4 EXTRA MATERIAL

A. Provide 5% of resilient flooring of each type, color and pattern.

2 PART 2 PRODUCTS

2.1 SHEET MATERIALS

- A. Homogeneous Vinyl Sheet: Refer to Interior Finish Legend for schedule of materials.
 - 1. Total Thickness: 0.080 inch nominal.
 - 2. Sheet Width: 72 inch minimum.
 - 3. Heat welded seams.
 - Manufacturers:
 - a. Armstrong World Industries Inc.
 - b. Congoleum Corp.
 - c. Mannington Mills Inc.
 - d. Tarkett Inc.

2.2 TILE MATERIALS

- A. Vinyl Composition Tile: Refer to Interior Finish Legend for schedule of materials.
 - 1. Size: 12 x 12 inch.
 - 2. Thickness: 0.125 inch.
 - 3. Pattern: Marbleized
 - Manufacturers:

- a. Armstrong World Industries Inc.
- b. Azrock Industries Inc.
- c. Kentile Floors Inc.
- d. Mannington Mills Inc.
- e. Tarkett Inc.

2.3 ACCESSORIES

- A. Subfloor Filler: Type recommended by floor material manufacturer.
- B. Primers and Adhesives: Waterproof, type recommended by floor material manufacturer.
- C. Base: Vinyl top set coved and straight (see Interior Finish Legend):
 - 1. Height: 4 inch.
 - 2. Thickness: 0.080 inch thick.
 - 3. Finish: Satin
 - 4. Length: Roll.
 - 5. Manufacturers:
 - a. Armstrong World Industries Inc.
 - b. Azrock Industries Inc.
 - c. Johnsonite
 - d. Kentile Floors Inc.
 - e. Tarkett Inc.
- D. Stair Tread/Riser: Johnsonite one-piece Rubber Tread and Riser raised square pattern color pallet B.
- E. Moldings and Edge Strips: Vinyl, manufactured by Johnsonite.
- F. Sealer and Wax: Types recommended by floor material manufacturer.

3 PART 3 EXECUTION

3.1 EXAMINATION AND PREPARATION

- A. Verify that concrete floors are dry to maximum moisture content of 7 percent, and exhibit negative alkalinity, carbonization, and dusting.
- B. Fill minor low spots and other defects with subfloor filler.
- C. Clean substrate.
- D. Apply primer as required to prevent "bleed-thru" or interference with adhesion by substances that cannot be removed.

3.2 INSTALLATION - SHEET AND TILE MATERIAL

A. Install in accordance with manufacturer's instructions.

- B. Spread adhesive and set flooring in place. Press with heavy roller to attain full adhesion.
- C. Install tile flooring with joints and seams parallel to building lines, with grain running in one direction. Allow minimum 1/2 full size tile width at room or area perimeter.
- D. Install sheet flooring with seams parallel to width of room. Provide minimum of 1/3 full roll width. Double cut sheet and continuously seal with heat weld and butt joints hairline.
- E. Scribe flooring to produce tight joints at items that penetrate flooring.
- F. Where floor finishes are different on opposite sides of door, terminate flooring under centerline of door.
- G. Install edge strips at unprotected or exposed edges, where flooring terminates, and where indicated secure resilient strips by adhesive.

3.3 INSTALLATION - BASE MATERIAL

- A. Adhere base tight to wall and floor surfaces.
- B. Fit joints tightly and make vertical. Miter internal corners. At external corners, V cut back of base strip to 2/3 of its thickness and fold.

3.4 CLEANING

- A. Remove excess adhesive from surfaces without damage.
- B. Clean, seal, and wax surfaces in accordance with manufacturer's instructions.

...END OF SECTION