

CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400

NOTICE OF VIOLATION AND ORDER TO CORRECT

April 3, 2017

Responsible Party 1: PROSSER ALAN 195 ST JOHN ST PORTLAND, ME 04102		
Location 195 ST JOHN ST	CBL 068 A010001	Inspection Date 3/20/2017
Inspector Scott Corey	Inspection Type FP Permit	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 4/30/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 10- 7.1.1 FIRE EXTINGUISHERS NEED ANNUAL SERVICE; The owner or designated agent or occupant of a property in which fire extinguishers are located shall be responsible for inspection, maintenance, and recharging. All exstinguishers expired	
SPRAY AREAS TO BE PROTECTED WITH AUTO EXT SYSTEM; SPRAYING OF FLAMMABLE OR COMBUSTIBLE FINISHES SHALL BE ONLY IN APPROVED AREAS WITHIN A BUILDING ANDHAVE AN APPROVED AUTOMATIC FIRE SUPPRESSION SYSTEM. Spray booth	
FLAMMABLE FINISHES PERMIT REQUIRED; SPRAYING OR DIPPING OF FLAMMABLE OR COMBUSTIBLE MATERIAL REQUIRES AN APPLICATION OF FLAMMABLE FINISHES FIRE PERMIT. APPLICATION CAN BE MADE THROUGH THE CITY CLERK'S OFFICE. Spray Painting in spray booth	
FINAL DATE OF COMPLETED VIOLATION(S)	___/___/___
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	___/___/___

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

Date

Responsible Party

Date

Responsible Party

SEEN AND AGREED

Date

Fire Prevention Bureau