DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

FACTORS FINANCIAL FRC INC

Located at

172 ST JOHN ST

PERMIT ID: 2016-02862 **ISSUE DATE:** 11/22/2016

CBL: 068 D004002

has permission to For the removal of old pallet racking system and the installation of new pallet racking (49,708 SF) for "Ferguson Enterprises".

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED. A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

Fire Department

/s/ Keith Gautreau

/s/ Jeanie Bourke

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

wholesale distribution & warehouse with showroom

Building InspectionsUse Group:S-1/BType:N/AStorage Moderate HazardBusiness1st Floor rack systemMUBEC/IBC 2009

PERMIT ID: 2016-02862

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY) or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases 6 months.
- If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop W Order" and subsequent release to continue.

REQUIRED INSPECTIONS:

Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No:	Date Applied For:	CBL:
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716		2016-02862	11/09/2016	068 D004002
Proposed Use: Commercial - Warehouse/Distribution ("Ferguson Enterprises")	For the		llet racking system ar 8 SF) for "Ferguson l	
Dept: Zoning Status: Approved w/Conditions H	Reviewer:	Ann Machado	Approval Da	te: 11/21/2016
Note: I-Mb & B-2 zones - when building was built in 1986 the zone was I-2. - all work is within the interior of the building. Conditions:				Ok to Issue: 🗹
1) The use of this property shall remain as warehouse/wholesale distribution and showroom. Any change of use shall require a separate permit application for review and approval.				
2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti Status: Approved w/Conditions Note: Conditions:	Reviewer:	Jeanie Bourke	Approval Da	te: 11/22/2016 Ok to Issue: ☑
2) Periodic inspections and/or testing by the Structural Engineer of Record or Testing Agencies are required per Sec. 1704.3. At the completion of construction, a stamped letter shall be submitted verifying substantial compliance with the approved structural design and any applicable test results. This is required prior to the final inspection and occupancy or a Certificate of Occupancy.				
3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Engineering DPS Status: Not Applicable	Reviewer:	Rachel Smith	Approval Da	te: 11/18/2016
Note:			(Ok to Issue: 🗹
Conditions:				
 This approval is non-applicable to Engineering DPW as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Works for any other reason than FOG, please contact 874-8801. 				
Dept: Fire Status: Approved w/Conditions H	Reviewer:	Keith Gautreau	Approval Da	te: 11/21/2016
Note:				Ok to Issue: 🗹
 Conditions: 1) Fire extinguishers are required per NFPA 1 Table 13.6.2. Placement and Size of extinguishers shall follow NFPA 1 table 13.6.8.2.1.1. 				
2) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.				
3) Any cutting and welding done will require a Hot Work Permit from Fire Department.				

ŀ