Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/01/16

LEGEND

- Fire partition w/ 1-hr fire resistance rating (existing wall)
- Fire partition w/ 1-hr fire resistance rating (new wall)
- New wall
- Existing wall
- E100 — Existing door to remain
- 100 / E100 — Existing door (E100) to be reused in new door location
- 100 — New door
- Ex — Existing window to remain
- A — New window

0' 1' 2' 5' 10'

PERMIT SET
6.15.16

LICENSED ARCHITECT
STEPHEN PONDELIS
No. 2182
STATE OF MAINE

ATTARDO PONDELIS
ARCHITECTURE

81 Bridge Street
Suite 402
Yarmouth, Maine 04096
(207) 846-2042

May Residence
The Philip J. Deering House

100 Vaughan Street
Portland, Maine

Proposed Third Floor Plan

Scale: 1/4"=1'-0" Drawn by: PCA
Date: 6.15.16
Revisions:

A-1.3