

Laurie Leader - RE: Valdmanis 29 Bowdoin

From: "Gary" <Gary@douston.com>
To: "Laurie Leader" <LRL@portlandmaine.gov>
Date: 4/2/2015 2:34 PM
Subject: RE: Valdmanis 29 Bowdoin
CC: <dave@douston.com>

Laurie, see my responses below in **Blue & Bold**.
 Have a good afternoon, Gary

From: Laurie Leader [mailto:LRL@portlandmaine.gov]
Sent: Thursday, April 02, 2015 11:49 AM
To: Gary@douston.com
Subject: Re: Valdmanis 29 Bowdoin

Gary,

Can you confirm the following:

- Do the bulkhead stairs meet R311.7.9.2 Bulkhead Enclosure Stairways? **Yes – it is about 6’ 6” from the concrete floor up to the outside grade.**
- Clarify if the bathroom fixtures meet Figure R307.1 Minimum Fixture Clearances. **As drawn, it is hard to tell if all the clearance distances are met, but we will be sure to lay it out appropriately before we build.**

Once I receive these revisions, I will be signing off on the building portion of your permit.

Thanks,

Laurie

Laurie Leader
 Plan Review/Code Enforcement
 City of Portland, Maine
 Inspections Division
 389 Congress Street
 Portland, ME 04101

P: 207-874-8714

F: 207-874-8716

E: lrl@portlandmaine.gov

To view building permit status go to <http://www.portlandmaine.gov/792/Permit-Status>

>>> "Gary" <Gary@douston.com> 4/1/2015 12:11 PM >>>

Laurie, I see what you mean about having to zoom in to read the lettering. I fiddled with the settings, but didn't seem to be able to improve. Attached is the best I could do.

Have a good afternoon, Gary

Gary Dugas
 Estimator/Project Manager
 Douston Construction

Office 207-283-0110 Ext. 7
gary@douston.com

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.