

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 85 St James St Use of Building Big "A" No. Stories New Building Existing
 Name and address of owner of appliance William Goodman & Sons
 Installer's name and address C.D. Aceto P.O. Box 764 Portland, ME 04104 Telephone 775-2402

General Description of Work

To install Force Hot Air Oil Fired Heating System

IF HEATER, OR POWER BOILER

Location of appliance 1st fl Any burnable material in floor surface or beneath? NO
 If so, how protected? Kind of fuel? #2 Oil
 Minimum distance to burnable material, from top of appliance or casing top of furnace 20'
 From top of smoke pipe 5' 8" From front of appliance 20' From sides or back of appliance 20'
 Size of chimney flue 12" 6" Other connections to same flue no 1 - 185,000
 If gas fired, how vented? Rated maximum demand per hour 1 - 140,000
 Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Beckett Labelled by underwriters' laboratories? yes
 Will operator be always in attendance? NO Does oil supply line feed from top or bottom of tank? Bottom
 Type of floor beneath burner Concrete Size of vent pipe 1 1/2"
 Location of oil storage 1st floor Number and capacity of tanks 2-330
 Low water shut off n/a Make No.
 Will all tanks be more than five feet from any flame? yes How many tanks enclosed? none
 Total capacity of any existing storage tanks for furnace burners none

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
 If so, how protected? Height of Legs, if any
 Skirting at bottom of appliance? Distance to combustible material from top of appliance?
 From front of appliance From sides and back From top of smokepipe
 Size of chimney flue Other connections to same
 Is hood to be provided? If so, how vented? Forced or gravity?
 If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Charles D. Aceto Master Oil & Solid Fuel #1380

Cost of Work: 4,500.00 45.00 Permit Fee

Amount of fee enclosed?

APPROVED:

[Signature]

Will there be in charge of the above a person competent to see that the State and City requirements are observed? yes

Signature of Installer

INSPECTION FILE APPLICANT'S ASSESSOR'S COPY

1. 1 1/2" FILL PIPE
2. 1 1/4" VENT PIPE
3. Kind of heat
4. Burner rating & control
5. Name & Label
6. Remote control
7. High limit control
8. Main cutoff switch
9. Low water cutoff
10. High limit control
11. Piping support & protection
12. Valves in supply line
13. Capacity of tanks
14. Tank rating & support
15. Oil gauge
16. Oil gauge
17. Oil gauge
18. Oil gauge
19. Oil gauge
20. Oil gauge

