



SUBJECT: METHOD OF ANCHORING
TANK IN GROUND



August 19, 1958

Attn: near 601 Danforth Street

Portland Pump Company
321 Lincoln Street
South Portland, Maine
Goodall Petroleum Co.,
near 601 Danforth Street

cc to: Esso Standard Oil Co.
1 Lincoln St.
Portland, Maine
cc to: Fire Department

Re: Portland Pump Company

In regard to the application for a permit to install a 2000 gallon underground storage tank and an electric pump in connection therewith at the above named location, we have a memorandum from the Fire Chief outlining the conditions under which he will be able to approve the installation. He writes as follows:-

Because of the extra attention that must be given to gasoline tanks installed on wharves and other waterfront property additional information is needed:-

1. Detailed plans must be shown whereby this tank will be kept from "floating" in case it should be empty or nearly so in extra high tides or other flood conditions.
2. Also to be considered is the piping and pump installation. Piping between shore and wharves of timber construction shall be provided with swing joints or other approved means to permit the movement of the pier or wharf and shore piping without any strain on the pipe lines. Pipe line control valves shall be so marked as to designate their use.
3. Fire extinguishers of a type approved by this department must be provided, suitable for flammable liquid fires. Smoking must be forbidden on this wharf and "No Smoking" signs are to be posted in appropriate places".

We shall be unable to issue a permit for the proposed installation until information requested above satisfactory to the Fire Department has been furnished.

Very truly yours,

Albert J. Sears
Deputy Inspector of Buildings

AJS:ir

INTER-OFFICE CORRESPONDENCE

CITY OF PORTLAND, MAINE
FIRE DEPARTMENT

To: Mr. Warren McDonald, Inspector of Buildings
From: Carl P. Johnson, Chief of Fire Department
Subject: Rear of 601 Danforth Street

DATE: August 18, 1956

This application is approved subject to the following conditions:

Because of the extra attention that must be given to gasoline tanks installed on wharves and other waterfront property additional information is needed.

1. Detailed plans must be shown whereby this tank will be kept from "floating" in case it should be empty or nearly so in extreme high tides or other flood conditions.

2. Also to be considered is the piping and pump installation. Piping between shore and wharves of timber construction shall be provided with swing joints or other approved means to permit the movement of the pier or wharf and shore piping without any strain on the pipe lines. Pipe line control valves shall be so marked as to designate their use.


In cooperation with this department, will you please notify us when this tank and piping is ready for inspection.

Fire extinguishers of a type approved by this department must be provided, suitable for flammable liquid fires. Smoking must be forbidden on this wharf and "No Smoking" signs are to be posted in appropriate places.

Carl P. Johnson

LOCATION: GOODALL BOAT SERVICE
 161 DANFORTH STREET
 CONTRACTOR: PORTLAND PUMP CO
 SUBJECT: INSTALLATION OF
 1 - 2000 GAL TANK.
 12' LONG X 64" DIA.

VENT LINE: 2"
 VENT P.P.E: 15' ABOVE GROUND





APPLICATION FOR PERMIT

Class of Building or Type of Structure Installation
Portland, Maine, August 15, 1958

PERMIT ISSUED
19
AUG 21 1958
CITY of PORTLAND


To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, install the following building, structure, equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location R. 601 Danforth St Within Fire Limits? _____ Dist. No. _____
Owner's name and address Goodall Boat Sales, Danforth St. Telephone _____
Lessee's name and address Esse Standard Oil Co. 1 Lincoln St. So. Portland Telephone _____
Contractor's name and address Portland Pump Co. 321 Lincoln St. So. Portland Telephone 2-6335
Architect _____ Specifications _____ Plans Yes No. of sheets 2
Proposed use of building _____ No. families _____
Last use _____ No. families _____
Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ _____ Fee \$ 1.00

General Description of New Work

To install 1-2000 underground gasoline storage tank. Storage is for public use.
To install (1) Electric Pump
Tank will be buried 8' underground and painted with asphaltum. Tank bears Underwriters Label
Size of piping from tank to pump is 2".
Size of vent pipe 2".



5/15/58
1875 to Fire Dept.
1875 to Fire Dept.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** contractor

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? _____
Height average grade to top of site _____ Height average grade to highest point of roof _____
Size, front _____ dep _____ No. stories _____ solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing Lumber—Kind _____ Dressed or full size? _____ Corner posts _____ Sills _____
Size Girder _____ Columns under girders _____ Size _____ Max. on centers _____
Kind and thickness of outside sheathing of exterior walls? _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

Carl F. Johnson
CHIEF OF FIRE DEPT.

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Esse Standard Oil Co.
Portland Pump Co.

INSPECTION COPY

Signature of owner

by: Portland Pump Co. by Robert F. Johnson

9-9-47

Permit No. 58/1119
Location 16601 - Oakland St.
Owner James J. O'Connell
Date of permit 8/21/48
Notif. closing-in _____
Inspn. closing-in _____
Final Notif. _____
Final Inspn. _____
Cert. of Occupancy issued _____
Sinking Out Notice _____
Form Check Notice _____

NOTES

10-7-58 Completed
per Conf. Flacey

X

W. H. Smith Co.

CS MAINE PRINTING CO. PORTLAND

(COPY)



CITY OF PORTLAND, MAINE
Department of Building-Inspection

Certificate of Occupancy

LOCATION rear 569-597 Danforth St.

Issued to Goodall Boat Sales (Leonard C Goodall) Date of Iss. February, 26, 1958

This is to certify that the building, premises, or part thereof, at the above location, built—altered—changed as to use under Building Permit No. 58/131, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire

APPROVED OCCUPANCY

Boat Shed

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

(Date)

Inspector

Inspector of Buildings

This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

near 559 Sanford Street

February 7, 1958

A. H. Nelson, Jr.,
RFD #2
Scarboro, Maine

cc to Leonard C. Goodall
21 Plymouth Road
30, Portland, Maine
cc to Portland Terminal Co.
222 St. John Street

Dear Mr. Nelson:

Building permit for construction of a one story wood frame boat shed 24 feet by 50 feet at the above named location is issued herewith to contractor based on revised plans filed February 7, 1958, but subject to the following conditions:

1. The double 2x4 plates at eave line are to extend across the gable end walls of building.
2. Two rows of continuous ties extending lengthwise of the building and consisting of not less than 2x6 laid flat and securely spiked to double 2x4 plates of end walls and bottom chords of trusses are to be provided. These are to be located close to the panel points of the trusses.

Very truly yours,

Albert J. Sears
Deputy Inspector of Buildings

AJS/H

A. P. Bear 591-59' Danforth Street

January 29, 1958

A. M. Nelson Jr.
R.F.D. #2
Scarboro, Maine

cc: Portland Terminal Co.
222 St. John Street
cc: Leonard C. Goodall
21 Plymouth Road
South Portland, Maine

Dear Mr. Nelson:

Examination of plan with application for permit for construction of a one story wood frame boat shed 24 feet by 50 feet at the above named location discloses the following variances from and questions as to compliance with Zoning Ordinance and Building Code requirements.

1. A plot plan showing location of building as regards distance from street and lot lines and right of way need to be furnished.
2. In order to provide adequate stiffness for rear wall 4x6 posts similarly located as those shown in front wall are needed at location of trusses. Detail of how these are to be supported on concrete piers or wood sills needs to be furnished.
3. Longitudinal bracing for bottom chords of trusses and gable end walls is needed at about the third points of trusses.
4. What is gable end wall construction to be where trusses are located?
5. Studs are required to be spaced no more than 16 inches instead of 24 inches on centers—See Section 312-c-36 of Building Code.
6. For purpose of tying building together it appears that 2x2 nailer stop, if needed, should be at inside instead of outside edge of 6x10 header in front wall construction.
7. Size and thickness of aluminum roofing has not been indicated. However, information we have indicates that usual construction is to use not less than 1x4 strapping not over 12 inches on centers. The use of 1x6 spaced 16 inches on centers as indicated gives a little greater spacing between strapping than this.
8. Will plan maker please put his name and address on plan, as specified by Section 104-b-2 of the Building Code.
9. Covering indicated for walls does not meet requirements of Section 312-c-3.4 of Building Code.

Very truly yours,

Albert J. Sears
Deputy Inspector of Buildings

AJS/mg



APPLICATION FOR PERMIT

Class of Building or Type of Structure

Third Class

Portland, Maine, January 27, 1958

PERMIT ISSUED

FEB 7 1958

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect-~~alter~~-repair-demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Rear 551-577 Danforth St. Within Fire Limits? no Dist. No.
Owner's name and address Portland Terminal Company, 222 St. John St. Telephone
Lessee's name and address Goodall Boat Sales, Leonard C Goodall 21 Plymouth Rd. Telephone
Contractor's name and address A. H. Nelson, Jr., R.F.D #2 Scarborough Me. Telephone TU-3-2515
Architect Specifications Plans yes No. of sheets 2
Proposed use of building Boat Shed No. families
Last use with metal roof. No. families
Material frame No. stories 1 Heat Style of roof Roofing
Other building on same lot Storage Sheds Fee \$ 5.00
Estimated cost \$ 1800.

General Description of New Work

To construct "Boat Shed" 1-story frame structure with metal roof. 24' x 50' as per plan.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO contractor

Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land earth or rock?
Material of foundation Thickness, top bottom cellar
Material of underpinning Height Thickness
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Kind and thickness of outside sheathing of exterior walls?
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVED:

with letter by A.H.N.

Miscellaneous

Will work require disturbing of any tree on a public street?
Will there be in charge of the above work a person who
see that the State and City requirements pertain
observed? yes
Goodall Boat Sales
A. H. Nelson Jr.

Signature of owner

by: A.H.N.

INSPECTION COPY

Pertail No.

Location.

Owner

Dr. :

Notif. cloué, e-i

Inspn. clearing-in

Final Note.

Final 'Japan.

Cert. of Occupancy issued

Staking Out Notice

Form Check Notice

NOTES

NOTES



APPLICATION FOR PERMIT

Class of Building or Type of Structure

Portland, Maine

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location Within Fire Limits? Dist. No.
Owner's name and address Telephone
Lessee's name and address Telephone
Contractor's name and address Telephone
Architect Specifications Plans No. of sheets
Proposed use of building No. families
Last use No. families
Material No. stories Heat Style of roof Roofing
Other building on same lot
Estimated cost \$ Fee \$

General Description of New Work

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO

Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Material of underpinning Height Thickness
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Joints under girders Size Max. on centers
Kind and thickness of outside sheathing of exterior walls?
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVED:

Miscellaneous

Will work require disturbing of any tree on a public street?
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

Signature of owner

INSPECTION COPY

NOTES

2-18-58 Sonatubos in
place + rear + end walls
framed to plate

2-20-58 Completed

X

Permit No. 58/131
Location River Road 131/132
Owner Harold C. Baker
Date of permit 2/7/58
Notice closing-in
Inspection closing-in
Final Profit
Final Inspection
Certificate of Occupancy issued 2/20/58
Sinking Out Notice
Form Check Notice

2-25-58 2.14



APPLICATION FOR PERMIT

Class of Building or Type of Structure Sign
Portland, Maine, January 22, 1957

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 501 Danforth St. Within Fire Limits? Dist. No.
Owner's name and address Gulf Oil Corp., 501 Danforth St. Telephone
Lessee's name and address Telephone
Contractor's name and address United Neon Display, 74 Elm Street Telephone
Architect Specifications Plans yes No. of sheets 2
Proposed use of building No. families
Last use No. families
Material No. stories Heat Style of roof Roofing
Other buildings on same lot
Estimated cost \$ Fee \$ 2.00

General Description of New Work

To erect roof sign as per plans.

CERTIFICATE OF INSURANCE
REQUIREMENT WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO United Neon Display

Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Material of underpinning Height Thickness
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing lumber—Kind Dressed or full size?
Corner posts Sills Girt or ledger board? Size
Girders Size Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor , 2nd , 3rd , roof
On centers: 1st floor , 2nd , 3rd , roof
Maximum span: 1st floor , 2nd , 3rd , roof
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot , to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVED:

O.N. 4/5/57 - AJS

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
United Neon Display

Signature of owner By: J. L. Royle

INSPECTION COPY

NOTES

4-17-57 Not started
 5-3-57 Not star
 5-27-57 Hold for 100
 job
 6-27-57 Not started
 7-16-57
 9-12-57 Old sign
 removed from roof.
 9-23-57 New sign
 framing going up
 10-8-57 Completed

X

Permit No. 57422
 Location 601 Franklin St.
 Owner E. J. J. Corp.
 Date of permit 4/15/57
 Mobil. closing-in
 Ingn. closing-in
 Final Notif.
 Final Inspn.
 Cert. of Occupancy issued
 Sinking Out Notice
 Form Check Notice

6-27-57 4771 9-23
 10-2-57

File copy

January 25, 1957

AP 501 Danforth St.—Proposed roof sign for Gulf Oil Corp., designed and manufactured by Colonial Neon Northern Inc. and to be erected by United Neon Display

Mr. William H. Schaller
Colonial Neon Northern Inc.
466 Blue Hill Ave.
Boston, Mass.

Copies to Mr. J. E. Stewart
Mr. F. D. Henrierson
United Neon Display
Mr. Schaller

Dear Mr. Schaller,

Upon examination of your plan for the above sign a number of questions arise which require settlement before we can issue the building permit to United Neon Display, which company applied for it:

1. Section 104b3 of our Building Code requires that the competent person, who takes responsibility for the design of the sign^{and} the roof structure on which it will be supported, sign a statement of design. For your convenience a blank is enclosed which may be filled in to identify the job and signed by the party responsible for the design. Two blanks are enclosed in case one designer is responsible for the design of the sign itself and the other for the investigation of and supports upon the roof structure. If the plans do not need to be revised, these blanks may be properly signed and sent here for attachment to the plans we have. However, it seems that some additional plans will be needed and these statements may be attached to those when furnished. In any case the parties signing the statements should offer something definite by way of establishing their capacity as designers—perhaps a State Engineer's license. In case the designer should wonder what the requirements in the City of Portland are, they will be safe to figure that our designer requirements are the same for steel as The American Institute of Steel Construction and for lumber the usual data of National Lumber Manufacturers Association.

2. A small scale location plan is necessary to show clearly which building the sign is to be upon and the location of the sign upon that roof. United Neon says that the sign is to be on the warehouse, but for our record it is necessary to know which end of the warehouse (apparently it is at one end or the other).

3. While there is to be apparently one structure, it appears that there are really to be two signs—one with solid background and one with open background, merely the letters and the frame being exposed to wind load. Please confirm that and indicate which sign is on the higher side of the tents.

4. While we have not been able to follow the design figures with assurance, apparently investigation was first made to see if the existing roof joists or rafters would support the signs, and it was found that the rafters had no extra strength to carry much of anything. Accordingly it seems, a steel frame work was decided upon consisting of four 8-inch wide flange at 17 pound beams to run the same way as the roof

Mr. William Schaller-----2

January 25, 1957

joists and to be supported upon or by other 8-inch wide flange at 17 pound beams to run directly over the wooden girders under the existing roof joists. Still other 8-inch wide flange beams would be run under the faces of the bents to support the bents upon the four cross steel beams.

It is not clear upon what the 8-inch beams over and parallel to the wooden girders under the present roof would bear upon. On front and end views there is something which looks like a plate resting upon the built-up roof, but we are not certain about it.

Neither are we sure where the reactions of these beams paralleling the wooden girders are to be, or perhaps they are merely intended to spread the load over these girders.

We have the plans showing the framing of the roof of the warehouse when it was built. While we are not certain that it was built exactly as shown on the plans, the plans do show the rafters or roof joists to be 24 inches on centers instead of 20 inches shown on your plan, and it shows the existing roof beams to be 6x12 instead of the 12 by 12 shown on your plan, and it shows these wood beams to be on spans of 10 feet instead of the 12 feet on your plan. The original plan shows no post against the exterior brick wall, evidently the roof girders bearing upon the brick wall itself. Your plan indicates the beams parallel to the wooden girders as falling short of reaching the brick wall, indicating that no bearing is intended on the brick wall. Presumably the detail encircled at cross beam 6 shows the method of supporting the bents upon the new beams.

5. While we do not require that you furnish full detailed design figures, we would like to know the total weight of the signs so that they can be distributed to the bearing points, data which we have not discovered so far.

6. As I have been dictating this letter apparently it becomes clear which sign uses the higher bent. It appears to be the open area sign extending 23 feet above the bottom of the bents; but please confirm this.

7. If you are relying at all upon the wooden girders under the roof to support the sign please advise whether they are full size or dressed and what species.

8. Further examination of the plans seem to indicate that you probably intend to extend both of the steel beams over the wooden roof girders to the brick wall thus placing the beams on two spans of either 10 feet or twelve feet whichever is correct, the entire load then to be supported upon the exterior wall and four lines of wooden columns which are marked 8x8 on the plan. It is not clear, however, how the loads are to get down to a bearing on either brick wall or columns.

9. It is noted that the design plan was evidently made by Colonial Neon Co., Inc. of North Bergen, New Jersey, and presumably the bents of the sign were designed there. Perhaps investigation of the roof and the design of the frame work and its supports upon the roof were made in Boston. In that case please make sure that the new statements of design are signed by the proper parties, their qualifications as designers established, and the particular part of the work for which they are taking the responsibility is made clear also.

Very truly yours,

Warren McDonald
Inspector of Buildings

WCD/B

Enclosures: Copy of this letter and 2 blank statements of design

Gulf King Light on W anchorage

601 Danforth
1/25/57

$$m = \frac{3I}{L} = \frac{1}{8} WL$$

$$W = \frac{8 \times \frac{3I}{L}}{20} = \frac{8 \times 145 \times 48}{20} =$$

$$\begin{array}{r} 440 \\ + 8 \\ \hline 352 \\ + 76 \\ \hline 21120 \end{array}$$

December 20, 1956

AP 585 Danforth St.—Demolition of service station building and use of the land thus made vacant for storage of gasoline tanks

Gulf Oil Corporation
662 Danforth St.

Copies to Mr. Ernest Asselyn
106 William St.
Chief of the Fire Dept.

Gentlemen:

We are issuing a building permit to your demolition contractor for the demolition of the one-story brick service station at 585 Danforth St. The application indicates that possible use of the land thus made vacant, and perhaps land outside of the building to be demolished, for the storage of gasoline tanks.

While under normal circumstances, the use of the land for storage is allowable under the Zoning Ordinance because the property is in an Industrial Zone, the same Ordinance does require that a certificate of occupancy is required from this department before the new use is actually started on the open land.

That all may be in order and that we may be able to issue the certificate, please apply for the required certificate by letter, explaining the proposed use, and also furnishing a plan or sketch to scale showing the location of the particular area to be used for the new purpose, and all other arrangements of importance in connection with this use of the land. If the proposal involves additional approaches to the property from the public street, it is important that you take a copy of the proposed arrangement plan to the Traffic Engineer associated with the Public Works Department and get his approval upon the location, width and other details of the approaches over the public sidewalk—upon the plan. Then enclose that particular approved plan with your letter of application.

Very truly yours,

Warren McDonald
Inspector of Buildings

WMC/D

12/26
Land to be used for
driveway for trucks.
no parking or storage
P.H.

849B

CITY OF PORTLAND, MAINE
DEPARTMENT OF BUILDING INSPECTION

December 17, 1956

Gulf Oil Corp.
601 Danforth St.

Gentlemen:

With relation to permit applied for to demolish a building or portion of building at 585 Danforth St. it is unlawful to commence demolition work until a permit has been issued from this department.

Section 6 of the ordinance for rodent and vermin control provides: "It shall be unlawful to demolish any building or structure unless provision is made for rodent and vermin eradication. No permit for the demolition of a building or structure shall be issued by the Building Inspector until and unless provisions for rodent and vermin eradication have been carried out under supervision of a pest control operator registered with the Health Department.

The building permit for demolition cannot be issued until the provisions of this section have been satisfied. It is the obligation of owner or demolition contractor or both to take up with the Health Department the matter of complying with this section, being prepared to inform that department what registered pest control operator is to be employed.

Very truly yours,

Warren McDonald
Inspector of Buildings

WicD/H

Eradication of this building has been completed.

Edna L. Kelly

Health Officer

Date

19 Dec 56

J. M. W.



APPLICATION FOR PERMIT

Class of Building or Type of Structure Second Class
Portland, Maine, Dec. 17, 1956

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to ~~erect~~ ~~demolish~~ ~~the following building structure~~ ~~equipment~~ in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 585 Danforth St. Within Fire Limits? no Dist. No. _____
Owner's name and address Gulf Oil Corp., 601 Danforth St. Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address Ernest Asselyn, 106 William St. Telephone 2-1772
Architect _____ Specifications _____ Plans no No. of sheets _____
Proposed use of building _____ No. families _____
Last use service station No. families _____
Material brick No. stories 1 Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ _____ Fee \$ 50

General Description of New Work

To demolish 1-story brick service station approximately 20' x 24'.

Do you agree to tightly and permanently close all sewers or drains connecting with public or private sewers from this building or structure to be demolished, under the supervision and to the approval of the Department of Public Works of the City of Portland? YES

Land will be used for storage of gasoline tanks.

Permit Issued with Letter

On Dec. 17, 1956, letter sent 12/17/56

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** contractor

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? _____
Height average grade to top of plate _____ Height average grade to highest point of roof _____
Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing lumber—Kind _____ Dressed or full size? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Gulf Oil Corp.

Signature of owner by:

Ernest J. Asselyn

INSPECTION COPY

NOTES

1-18-57 Bldg. 5040

X

Permit No. 56/2235
 Location 580 S. Douglas St.
 Owner Lindy Q. L. Co.
 Date of permit 12/30/56
 Notif. closing-in
 Inspn. closing-in
 Final Notif.
 Final Inspn.
 Cert. of Occupancy issued
 Sinking Out Notice
 Form Check Notice

1-18-57

Form with multiple horizontal lines for notes and data entry.



APPLICATION FOR PERMIT

Class of Building or Type of Structure

Portland, Maine, June 1, 1956

00720

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 601 Danforth St. Within Fire Limits? Dist. No.
Owner's name and address Gulf Oil Corp., 601 Danforth St. Telephone
Lessee's name and address Telephone
Contractor's name and address Elton Frock, Waldoboro, Maine Telephone
Architect Specifications Plans No. of sheets
Proposed use of building No. families
Last use No. families
Material No. stories Heat Style of roof Roofing
Other building on same lot
Estimated cost \$ Fee \$ 1.00

General Description of New Work

To demolish approximately 210 feet of existing wharf and remove piling.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** Gulf Oil Corp.

Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Material of underpinning Height Thickness
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing lumber—Kind Dressed or full size?
Corner posts Sills Girt or ledger board? Size
Girders Size Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVED:

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes
Gulf Oil Corp.

INSPECTION COPY

Signature of owner

By:

C16-254-1M-Mark

Albert T. Bjorn

NOTES

6-18-56 Not started *NP*
 6-28-56 Barge starting
 in middle of canal *NP*
 6-13-56 Working *NP*
 7-27-56 " *NP*
 8-3-56 " *NP*
 8-14-56 Completed *NP*

X

Permit No. 56175-1
 Location 691 Danforth St.
 Owner Gulf Oil Corp.
 Date of permit 6/1/56
 Notif. closing-in
 Inspn. closing-in
 Final Notif.
 Final Inspn.
 Cert. of Occupancy issued
 Staking Out Notice
 Form Check Notice

8-14 11-1-56 6-22-56



APPLICATION FOR AMENDMENT TO PERMIT

Amendment No. 1

Portland, Maine, Nov. 19, 1954

PERMIT ISSUED

3 1954

CITY OF PORTLAND

To the INSPECTOR

INGOS, PORTLAND, MAINE

The undersigned applies for amendment to Permit No. 54/511 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, and specifications, if any, submitted herewith, and the following specifications:

Location 601 Commercial St. Within Fire Limit? No Dist. No. Telephone
Owner's name and address Gulf Oil Corp., 601 Commercial St. Telephone
Lessee's name and address Telephone
Contractor's name and address owners Plans filed Reg. No. of sheets 1
Architect No. families
Proposed use of building No. families
Last use Additional fee .50
Increased cost of work

Description of Proposed Work

Instead of work contemplated in original permit 54/511, to remove 4 5,000 barrel tanks used for storage of fuel oil and gas oil and to install in substantially same general location 2 tanks--1 for fuel oil and 1 for gasoline, each of 10,740 barrel capacity, thus increasing theoretical capacity by 11,480 barrels. The applicant states that existing dikes have capacity which, after change, will still equal capacity of larger dike within the dike plus 10 per cent of aggregate capacity of all other tanks within same dike.

Details of New Work

See City Fire Dept. 11/19/54

See City Fire Dept. 11/29/54

Is any plumbing involved in this work? Is any electrical work involved in this work?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Material of underpinning Height Thick ess
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining
Framing lumber--Kind Dressed or full size?
Corner posts Sills Girt or ledger board? Size
Girders Size Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor, 2nd, 3rd, roof
On centers: 1st floor, 2nd, 3rd, roof
Maximum span: 1st floor, 2nd, 3rd, roof
Gulf Oil Corp.

Approved:

INSPECTION COPY

Signature of Owner by: Albert E. B. B. B.

Approved: 11/23/54 WMD
Inspector of Buildings

C-10-154-SC-Marks



APPLICATION FOR PERMIT

Class of Building or Type of Structure

Portland, Maine, June 11, 1954

PERMIT ISSUED

00871
JUN 15 1954

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish or install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location _____ Within Fire Limits? ☒ Dist. No. _____
Owner's name and address _____ Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address _____ Telephone _____
Architect _____ Specifications _____ Plans _____ No. of sheets 1
Proposed use of building _____ No. families _____
Last use _____ No. families _____
Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ _____ Fee \$ 2.00

General Description of New Work

To replace 1-300 barrel tank or gasoline tank with 500 barrel tank to be located as per plan.

SENT TO FIRE DEPT. 6/14/54
REC'D FROM FIRE DEPT. 6/16/54

CENTRAL RECORDS
REQUIREMENT NO. 1013

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO _____

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? _____
Height average grade to top of plate _____ Height average grade to highest point of roof _____
Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing lumber—Kind _____ Dressed _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Girders _____ Size _____ Columns under girders _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in _____ roof span over 8 feet. _____
Joists and rafters: 1st floor _____, 2nd _____, _____ of _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____ to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs? _____ cars habitually stored in the proposed building? _____

APPROVED:

O.V. 6/16/54 - AC
H.W. Mark
act

Miscellaneous

Will work require disturbing of any tree on a public street? ☒ no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? ☒ yes
Self Oil Corp.

INSPECTION COPY

Signature of owner O.V.

Robert E. Brown

File: AP 601 Danforth St.

June 14, 1954

Harry W. Marr, Acting Chief of Fire Department

Warren McDonald, Inspector of Buildings

Replacement of gasoline storage tank at 601 Danforth St.

Attached herewith is application for permit for replacement of vertical storage tank at tank farm of Gulf Oil Company at 601 Danforth St. Please note that new tank is to have a capacity of 2000 barrels greater than the one to be replaced. We understand from Mr. Bjorn who signed application for permit that there is adequate volume inside the existing concrete dike walls to meet requirements. He also says that he has already secured permit from State for this work.

Have you any criticisms of or additional requirements for this installation?

Insptr. of Bldgs.

AJS/G



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, MAY 24, 1954

PERMIT ISSUED

MAY 25 1954

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 501 Sanforth St. Use of Building Boiler House No. Stories 1 New Building
Name and address of owner of appliance Gulf Oil Corp., 501 Sanforth St. Existing " "
Installer's name and address B. G. Pride Co., Inc., 543 Main St., Telephone

General Description of Work

To install oil burning equipment in connection with existing steam heat (replacement)

IF HEATER, OR POWER BOILER

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Kind of fuel?
Minimum distance to burnable material, from top of appliance or casing top of furnace
From top of smoke pipe From front of appliance From sides or back of appliance
Size of chimney flue Other connections to same flue
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

IF OIL BURNER

Name and type of burner WilliamsOMATIC Labeled by underwriter's laboratories? yes
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1"
Location of oil storage basement 1st floor Number and capacity of tanks 1-275
Low water shut off yes Make McCormell Miller No. 2"
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners none

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:

OK 5-25-54 JMB

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

B. G. Pride Co., Inc.

INSPECTION COPY

Signature of Installer

By: C. K. M. Lundy

1 Fuel Pipe _____

2 Vent Pipe _____

3 Kind of Heat _____

4 Burner Rigidity & Supports _____

5 Name & Label _____

6 Stack Condition _____

7 High Limit Control _____

8 Remote Control _____

9 Piping Support & Protection _____

10 Valves in Supply Line _____

11 Capacity of Tank _____

12 Tank Rigidity & Supports _____

13 Tank Distance _____

14 Oil Gauge _____

15 Instruction Card _____

16 Low Water Shut off _____

NOTES

6-8-54 Mr. [unclear]
 - 10-11-54
 remote control
 on cut side [unclear]
 1971

Approved _____

Date of Permit _____

Owner _____

Location _____

Permit No. 54/682

6-1
 6-1 Danforth St.
 5/25/54
 5/25/54



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, May 24, 1951

PERMIT ISSUED
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 601 Danforth St. Use of Building Office & warehouse No. Stories 2 New Building Existing " "
Name and address of owner of appliance Gulf Oil Corp., 601 Danforth St.
Installer's name and address B. G. Fride Co., Inc., 543 Main St., West Telephone

General Description of Work

To install oil burning equipment in connection with existing hot water heat replacement (conversion)

IF HEATER, OR POWER BOILER

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Kind of fuel?
Minimum distance to burnable material, from top of appliance or casing top of furnace
From top of smoke pipe From front of appliance From sides or back of appliance
Size of chimney flue Other connections to same flue
If gas fired, how vented? Rated maximum demand per h
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

IF OIL BURNER

Name and type of burner WilliamsOMATIC Labeled by underwriter's laboratories? yes
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1"
Location of oil storage basement Number and capacity of tanks 1-275 gal.
Low water shut off Make No.
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners none

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED

OK 5-24-51 mth.

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

B. G. Fride Co., Inc.

INSPECTION COPY

Signature of Installer By: C. K. McCall

- 1 Fill Pipe.....
- 2 Vent Pipe.....
- 3 End of Heat.....
- 4 Barrier Rigidity & Supports.....
- 5 Name & Label.....
- 6 Stack Control.....
- 7 High Limit Control.....
- 8 Remote Control.....
- 9 Piping Support & Protection.....
- 10 Valves in Supply Line.....
- 11 Capacity of Tanks.....
- 12 Tank Rigidity & Supports.....
- 13 Tank Insulation.....
- 14 Oil Storage.....
- 15 Instruction Card.....
- 16 Low Water Shut off.....

NOTES

Permit No. 54/671
 Location 691 Dwyer, Wash. D.C.
 Date of issue 5/24/64
 Approved

INDUSTRIAL ZONE

APPLICATION FOR PERMIT



Class of Building or Type of Structure concrete and brick

Portland, Maine, May 31, 1951

PERMIT ISSUED

JUL 17 1951

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to alter ~~repair~~ and ~~the following building~~ the following building in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 601 Danforth Street Within Fire Limits? no Dist. No. _____
 Owner's name and address Gulf Oil Corp., 601 Danforth Street Telephone _____
 Lessee's name and address _____ Telephone _____
 Contractor's name and address C. Galli & Son, 46 Portland Street Telephone _____
 Architect _____ Specifications _____ Plans yes No. of sheets 1
 Proposed use of building Garage and terminal No. families _____
 Last use _____ No. families _____
 Material brick & concrete No. stories 1 Heat _____ Style of roof _____ Roofing _____
 Other buildings on same lot office and warehouse and pump house
 Estimated cost \$ 700 Fee \$ 4.00

General Description of New Work

To widen two garage doors as shown on plan.

See permit 28/771

CERTIFICATE OF INSURANCE
REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** Gulf Oil Corp.

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
 Height average grade to top of plate _____ Height average grade to highest point of roof _____
 Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
 Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
 Material of underpinning _____ Height _____ thickness _____
 Kind of roof _____ Rise per foot _____ Roof covering _____
 No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
 Framing lumber—Kind _____ Dressed or full size? _____
 Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
 Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
 Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on site _____ lot _____, to be accommodated _____ number commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will work require disturbing of any tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Gulf Oil Corp.

APPROVED:

ON- 7/17/51 - agf

INSPECTION COPY

Signature of owner by: P.D. Henderson

Permit No. 511306
Location 6111 Highway 101
Owner 6111 Highway 101
Date of permit 7/17/51
Notif. closing in
Inspr. closing in
Final Notif.
Final Inspr.
Cert. of Occupancy issued

NOTES

Handwritten notes on lined paper.

601 Danforth Street-I

June 6, 1951

Gulf Oil Company
601 Danforth Street
Portland, Maine

Copy to: S. Gallison
46 Portland Street

Gentlemen:

More information is needed concerning the proposed widening of two large door openings in the existing garage at 601 Danforth Street before a permit may be issued. The chipping off of over 7" of the width of one of the reinforced concrete columns between two of the door openings thus reducing it from 12" to about 10" is a major operation as far as the carrying capacity of the column is concerned and one which requires careful investigation to make certain that adequate strength is to be left in the column after the work has been done. Maybe this has already been done, but we would like a design analysis indicating that the work contemplated can be done without reducing the carrying capacity of the columns below that required for adequately handling the loads involved and that sufficient concrete coverage of the steel reinforcement of the columns will remain. A statement of design (blank copy enclosed) should be filed with these figures.

Very truly yours,

Warren McDonald
Inspector of Buildings


AJS/G

Enclosure: Blank statement of design

PETROLEUM AND ITS PRODUCTS
GULF OIL CORPORATION
PARK SQUARE BUILDING - BOSTON, MASS
ENGINEERING AND
CONSTRUCTION DEPARTMENT
G. H. WESTBROOK

December 17, 1945

Mr. Warren McDonald,
Inspector of Buildings,
Department of Building Inspections,
Portland, Maine.



Dear Mr. McDonald:

Your letter of December 8th with permits
attached for doing certain work at our Portland, Me. Term.

Attached please find statement filled in
and signed as per request in the second paragraph of your
letter.

Referring to the third paragraph of your
letter we are returning the wall back to the building to
form a curb to prevent frost action.

We thank you for the permit.

Yours very truly,

G. H. Westbrook
SUPT. OF CONSTRUCTION

G. H. W.

601 Danforth St.-i
Warehouse

ATH
RMT
PH
AJS
HL
BS

December 8, 1945

Gulf Oil Corporation
31 St. James Avenue
Boston, Massachusetts

Subject: Building permit for alterations of entrance
to boiler room of warehouse at 601 Danforth Street
Attn: Mr. G. H. Westbrook

Gentlemen:

Because of the lateness of the season to do outside work, I am issuing the permit, subject to the following conditions, rather than delay issuance until every detail had been cleared up.

1. Please have your designer of the reinforced concrete fill in and sign the attached statement of design to be returned and attached to the plan in this office, as per Section 104b3 of the Building Code.

2. I take it that the reinforced concrete retaining wall enclosing the cellar way will be returned, full depth, to the outside face of the top step to prevent frost getting underneath the sloping slab of the stairs. Presumably you will rely on what appears to be a concrete walk or slab on grade outside of the bulkhead doors to accomplish the same purpose, or else return the wall back against the building beneath the top of the stairs.

Very truly yours,

Inspector of Buildings


WMC/S

CC: Gulf Oil Corporation
601 Danforth Street

Permit No 457 1735
Location 1001 Danforth St.
Owner Gulf Oil Corp
Date of permit 12/8/45
Notif. closing-in _____
Inspn. closing-in _____
Final Notif. _____
Final Inspn _____
Cert. of Occupancy issued _____

NOTES

5/22/46
WORK DONE
EXCEPT FOR DOOR
IN BASEMENT.
W.F.





(A INDUSTRIAL BUILDING)
APPLICATION FOR PERMIT

Class of Building or Type of Structure Second Class

Portland, Maine, December 2, 1945

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 601 Danforth Street Within Fire Limits? no Dist. No. _____
Owner's name and address Gulf Oil Corp., 601 Danforth Street Telephone 2-5656
Lessee's name and address " " " 31 St. James Ave Boston Telephone _____
Contractor's name and address Not let W. H. K. Westbrook Telephone _____
Architect _____ Specifications none Plans Yes No. of sheets 1
Proposed use of building Major Garage No. families _____
Last use " " No. families _____
Material brick No. stories 1 Heat hot water Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ 150. Fee \$ 1.00

General Description of New Work

To partition off room 9'x12' for sparking tools as per plan submitted.

CEILING HEIGHT OF OCCUPANCY
REQUIREMENT 7' 6" MIN.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? _____ Is any electrical work involved in this work? _____
Height average grade to top of plate _____ Height average grade to highest point of roof _____
Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing lumber—Kind _____ Dressed or full size? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

Gulf Oil Corp.

APPROVED:

by Chief Harbor 12/4/45

Signature of owner Ev: Lake & P

INSPECTION COPY

Permit No. 45/1754
Location 601 Danforth St.
Owner Gulf Oil Corp.
Date of permit 12/8/45
Notif. closing-in
Inspn. closing-in
Final Notif
Final Inspn. 5/23/46
Cert. of Occupancy issued NONE

NOTES

5/23/46
WORK DONE
AS PER PLAN
EJF

INQUIRY BLANK

ZONE I

FIRE DIST. no

CITY OF PORTLAND, MAINE
DEPARTMENT OF BUILDING INSPECTION

Verbal
By Telephone

DATE 3/10/44

LOCATION 601 S. Berforth St. OWNER Gulf Oil Company

MADE BY Paul Henderson TEL. 35456

ADDRESS 601 S. Berforth St.

PRESENT USE OF BUILDING Garage

CLASS OF CONSTRUCTION Mill NO. OF STORIES 1

REMARKS: Present storage of 1-275 gal. tank, oil for

oil burner (tank under no permit) present enough

to last over winter.

INQUIRY: Can 275 gal. tank, which has worn out and got to

be replaced, be replaced over a tank located

outside the building above ground?

2. Is permit needed?

ANSWER: 1- A 550 gal. tank cannot be used with this in-

stallation if the feed line is connected at the bottom

of the tank, but may be if the feed line is taken

from the top of the tank and an approved siphon

breaking device is provided in the line inside the

building, providing the Fire Chief will approve

the location; or 2- 275 gal. tanks with a three

way valve so arranged that only one tank may

DATE OF REPLY 3/10/44 REPLY BY A.J.S.

(over)

Permit No. 45/114

Location 601 Danforth St.

Owner Gulf Oil Corp

Date of permit 2/26/45

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn. 5/22/45

Cert. of Occupancy issued NONE

NOTES

3/42/41

WIRA LANE
AS PER PLAN
2R



INDUSTRIAL ZONE
APPLICATION FOR PERMIT **PERMIT ISSUED**
Class of Building or Type of Structure Metal Building

Portland, Maine, July 2, 1942 JUL 3 1942

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~also install~~ the following building ~~structure~~ equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 501 Danforth Street Ward no Within Fire Limits? no Dist. No. _____
Owner's or Lessee's name and address Gulf Oil Corp., 601 Danforth Street Telephone _____
Contractor's name and address 21 St. James Ave. Boston, Hancock 3700
Architect _____ Telephone _____
Proposed use of building House Plans filed yes No. of sheets 2
Other buildings on same lot garage, boiler house, pump house, tanks No. families _____
Estimated cost \$ 200 Fee \$ 1.00

Description of Present Building to be Altered

Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Last use _____ No. families _____

General Description of New Work

To erect one story ~~in~~ metal building 14' x 10' 1/2', angle iron frame

NOTIFICATION HEREBY MADE
THAT THE FOLLOWING
CERTIFICATE OF PERMIT
HAS BEEN ISSUED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Size, front _____ depth _____ No. stories _____ Height average grade to top of plate _____
To be erected on solid or filled land? filled Height average grade to highest point of roof 7' 1/2"
Material of foundation concrete slab earth or rock? earth
Material of underpinning _____ Thickness, top _____ bottom _____
Kind of Roof flat Rise per foot 1/4" Roof covering metal
No. of chimneys no Material of chimneys _____ Thickness _____
Kind of heat no Type of fuel _____ of lining _____
Corner posts _____ Sills angle bolted to slab Is gas fitting involved? _____
Material columns under girders _____ Girt or ledger board? _____ Size _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof
span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor concrete, 2nd _____, 3rd _____, roof as per plan
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY


Signature of owner

Gulf Oil Corp.

By Arthur T. O'Brien

Ward Permit No. 42/1720
Location 601 Danforth St.
Owner Gull Oil Corp.
Date of permit 7/3/42.
Notif. closing-in
Inspn. closing-in
Final Notif.
Final Inspn. 7/13/42
Cert. of Occupancy issued None

NOTES





(1) INDUSTRIAL ZONE
APPLICATION FOR PERMIT
Class of Building or Type of Structure Metal Building Permit No. 19-2553
Portland, Maine, July 3, 1942

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to ~~erect~~ alter install the following building structure—equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 601 Denforth Street Within Fire Limits? no Dist. No. _____
Owner's ~~or Lessee's~~ name and address Gulf Oil Corp. 601 Denforth St. Telephone _____
Contractor's name and address 31 St. James Ave. Boston, Telephone 3700
Architect _____ See Rose House location plan
Plans filed _____ No. of sheets _____
Proposed use of building Guard House No. families _____
Other buildings on same lot _____
Estimated cost \$ _____ Fee \$.50

Description of Present Building to be Altered

Material metal No. stories 1 Heat _____ Style of roof _____ Roofing _____
Last use Guard House No. families _____

General Description of New Work

To relocate one story metal building 6' x 2' on same property as shown on plat plan with new ~~xxxxxxxxxx~~ hose house application at this same time

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? _____
Is any electrical work involved in this work? _____ Height average grade to top of plate _____
Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____
To be erected on solid or filled land? filled earth or rock? earth
Material of foundation concrete piers Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____
Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
Framing lumber—Kind _____ Dressed or full size? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner Gulf Oil Corp.


INSPECTION COPY

By

Albert T. Bjorn

Permit No. 42/729
Location 601. Danforth St.
Owner Gulf Oil Corp
Date of permit 7/3/42
Notif. closing-in
Inspn. closing-in
Final Notif.
Final Inspn. 7/13/42
Cert. of Occupancy issued None

8/4/42 NOTES
Work not to be done





INDUSTRIAL ZONE
APPLICATION FOR PERMIT

PERMIT ISSUED

Class of Building or Type of Structure Gasoline Installation

Permit No. 177

SEP 11 1941

Portland, Maine, September 5, 1941

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 335 Denforth Street Within Fire Limits? no Dist. No. _____
Owner's or Lessee's name and address Gulf Oil Corp. 501 Denforth St. Telephone _____
Contractor's name and address M. J. Erskine, 24 Bishop Ave. So. Portland Telephone 2-7304
Architect _____ Plans filed yes No. of sheets 1
Proposed use of building Service Station No. families _____
Other buildings on same lot _____
Estimated cost \$ 350. Fee \$ 1.00

Description of Present Building to be Altered

Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Last use _____ No. families _____

General Description of New Work

To install one 2,000 gallon tank and one electric pump for gasoline, additional installation, tank will bear Underwriters' Label, coated with asphaltum, will be at least 3' below grade, minimum diameter of piping tank to pump $1\frac{1}{2}$ "

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Storage to be applied for

Details of New Work

Is any plumbing work involved in this work? _____
Is any electrical work involved in this work? _____
Size, front _____ depth _____ No. stories _____
To be erected on solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____
Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
Framing lumber—Kind _____ Dressed or full size? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

ORIGINAL

9/5/41
Sent to Fire Dept.
Recd from Fire Dept.
9/6/41

Signature of owner
By Frank D. Johnson
Gulf Oil Corp.

1837

Permit No. 41/1307
Location 569-597 Danforth Street
Owner Gulf Oil Corp.
Date of permit 9/8/41
Notif. closing-in
In: ng-in
Final Notif.
Final Inspn.
Cert. of Occupancy issued

NOTES



(1) INDUSTRIAL ZONE
APPLICATION FOR PERMIT

Permit No. 1-1-1

SEP 4 1960

Class of Building or Type of Structure

Portland, Maine,---

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~also install~~ the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Ward 7 Within Fire Limits? no Dist. No. _____

Telephone 3-5656

The undersigned hereby certifies that the above is a true and correct copy of the plans and specifications filed with the Laws of the State of Maine, the Building Code of the City of Portland, and the following specifications:

Location 601 Denforth Street Ward 7 Within Fire Limits? no Dist. No. _____
Owner's ~~or lessee's~~ name and address Gulf Oil Corp. 601 Denforth St. Telephone 3-5656
Contractor's name and address Owner Telephone _____ see other permit
Architect _____ Plans filed _____ No. of sheets _____
Proposed use of building Gate House No. families _____
Other buildings on same lot _____ Fee \$ 50
Estimated cost \$100. Description of Present Building to be Altered _____
Roofing _____

Estimated cost \$100. _____

Description of Present Building to be Altered

Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____

Last use _____ No. families _____

General Description of New Work

General Description of New Work

To erect one story metal building 6' x 8', angle iron frame

It is understood that this permit does not include installation of heating apparatus which is to be taken
the heating contractor.

Details of New Work

Height average grade to top of

Details of New Work

It is understood that this permit is not to be used for the heating contractor.

Details of New Work

Height average grade to top of plate _____

Height average grade to highest point of roof **10'**

Size, front _____ depth _____ No. stories _____

To be erected on solid or filled land? _____ earth or rock? _____

Material of foundation **on wharf** Thickness, top _____ bottom _____

Material of underpinning _____ Height _____ Thickness _____

Kind of Roof **pitch** Rise per foot _____ Roof covering **metal**

No. of chimneys **no** Material of chimneys _____ of lining _____

Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____

Corner posts _____ Sills **4x6** Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) **2x4-16" O. C.** Girders **6x8 or larger.** Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____

On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____

Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____ height? _____

If one story building with masonry walls, thickness of walls? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____

Total number commercial cars to be accommodated _____

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous _____

Miscellaneous

Will above work require removal or distu. ing of any shade tree on a public street? no


Will above work require removal or distu. ing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Signature of owner Gulf Oil Corp.
H. D. Johnson

INSPECTION COPY

Signature of owner By Frank D. Johnson Gulf Oil Corp.

Ward 7 Permit No. 41/1280
Location 601 Danforth St.
Owner Gulf Refining Corp
Date of permit 9/4/41
Notif. closing-in _____
Inspn. closing-in _____
Final Notif. _____
Final Inspn. 7/12/42
Cer* of Occupancy issued None

NOTES





(1) INDUSTRIAL ZONE
APPLICATION FOR PERMIT

PERMIT ISSUED
PERMIT ASSURED

Class of Building or Type of Structure Metal Frame Const.
Portland, Maine. Sept. 4, 1941 SEP 4 1941

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~alter~~ install the following building ~~structure~~ equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 601 Danforth Street Ward 7 Within Fire Limits? no Dist. No. _____
Owner's or lessee's name and address Gulf Oil Corporation 601 Danforth St. Telephone 2-5656
Contractor's name and address Owner Telephone _____
Architect _____ Plans filed _____ No. of sheets _____
Proposed use of building Auto House No. families _____
Other buildings on same lot _____ Fee \$.50
Estimated cost \$ 102.

Description of Present Building to be Altered

Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Last use _____ No. families _____

General Description of New Work

To erect one story metal building 6' x 2' angle iron frame

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Size, front _____ depth _____ No. stories _____ Height average grade to top of plate _____
To be erected on solid or filled land? filled earth or rock? _____
Material of foundation concrete piers Thickness, top _____ bottom _____
Material of underpinning _____ Height _____ Thickness _____
Kind of Roof metal pitch Rise per foot _____ Roof covering _____
No. of chimneys no Material of chimneys _____ of lining _____
Kind of heat no Type of fuel _____ Is gas fitting involved? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous


Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner Gulf Oil Corp.
Frank D. Johnson

Ward 7 Per. it No. 41/1279
Location 601 Danforth St.
Owner Gulf Refining Corp
Date of permit 9/4/41
Notif. closing-in
Inspn. closing-in
Final Notif.
Final Inspn. 7/13/42
Cert. of Occupancy issued None

NOTES



007 12/1 115



INDUSTRIAL ZONE
APPLICATION FOR PERMIT

Permit No. _____

Class of Building or Type of Structure Metal frame construction

Portland, Maine, September 4, 1941 P 4 1941

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect ~~alter~~ install the following building ~~structure~~ equipment in accordance with the Laws of the Sta. of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 601 Danforth Street Ward 7 Within Fire Limits? no Dist. No. _____
Owner's ~~or lessee's~~ name and address Gulf Oil Corporation, 601 Danforth St. Telephone _____
Contractor's name and address Owner Telephone _____
Architect _____
Proposed use of building Gate Plans filed yes No. of sheets 2
~~Small Houses (3)~~ No. families 10
Other buildings on same lot _____
Estimated cost \$ 100 Fee \$ _____

Description of Present Building to be Altered

Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Last use _____ No. families _____

General Description of New Work

To erect ~~one story gate house~~ gate house 6' x 8', metal, angle iron frame

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately and in the name of the heating contractor.

Details of New Work

Size, front _____ depth _____ No. stories _____ Height average grade to top of plate _____
To be erected on solid or filled land? filled earth or rock? earth
Material of foundation concrete Thickness, top _____ bottom _____
Material of underpinning _____ Height _____ Thickness _____
Kind of Roof pitch Rise per foot _____ Roof covering metal
No. of chimneys no Material of chimneys _____ of lining _____
Kind of heat no Type of fuel _____ Is gas fitting involved? _____
Corner posts _____ Sills 4x6 Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor 2x4, 2nd _____, 3rd _____, roof _____
On centers: 1st floor 16", 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor 4'-0", 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner By _____

Gulf Oil Corp.

Frank D. Johnson

108D

Ward 7 Permit No. 41/1278
Location 601 Danforth St.
Owner Gulf Oil Corp
Date of permit 9/4/41

Notif. closing-in


Inspn. closing-in

Final Notif.

Final Inspn. 7/12/42

Cert. of Occupancy issued None

NOTES





APPLICATION FOR PERMIT

Permit No. **1212 P**

Class of Building or Type of Structure

Structure

Portland, Maine, October 25, 1940

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 595 Danforth Street Ward 7 Within Fire Limits? no Dist. No. Hancock
Owner's or Lessee's name and address Gulf Oil Corporation 31 St. James Ave. Boston Telephone 3700
Contractor's name and address Not let Att. Mr. D. H. Vestbrook Telephone _____
Architect _____ Plans filed yes No. of sheets 4
Proposed use of building Loading rack No. families _____
Other buildings on same lot _____
Estimated cost \$ 1,000. Fee \$1.00

Description of Present Building to be Altered

Material _____ No. stories _____ Heat _____ Style of roof _____ Roofing _____
Last use _____ No. families _____

General Description of New Work

To erect open loading rack 50' x 27', all metal construction except floor as per plans

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Height average grade to top of plate _____
Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____
To be erected on solid or filled land? filled earth or rock? _____
Material of foundation concrete Thickness, top _____ bottom _____
Material of underpinning _____ Height _____ Thickness _____
Kind of Roof _____ Rise per foot _____ Roof covering metal corrugated
No. of chimneys _____ Material of chimneys _____ of lining _____
Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner

Gulf Oil Corp.

By H. B. Johnson

Ward 7 Permit No. 40/1714

Location 595 Danforth St

Owner Gulf Oil Corp

Date of permit 10/28/40

Notif. closing-in

Inspn. closing-in

Final Notif.


Final Inspn. 12/11/40

Cert. of Occupancy issued None

NOTES

11/4/40 - No work started
A.C.C.

11/14/40 - Same as
12/11/40 - Work about
completed - A.C.C.





INDUSTRIAL CODE

PERMIT ISSUED
Permit No. 0539

APPLICATION FOR PERMIT TO ERECT SIGN
OVER PUBLIC SIDEWALK OR STREET

Portland, Maine, Apr. 28, 1939

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect the following described sign extending over a public sidewalk or street in accordance with the Building Code of the City of Portland, and the following specifications:

Location 601 Danforth St. Ward 7 Within Fire Limits? No Dist. No. _____

Owner of building to which sign is to be attached Gulf Oil Co.

Name and address of owner of sign Same

Contractor's name and address J. H. Middlebrook, 457 1/2 Congress St. Telephone 3-2312

When does contractor's bond expire? Jan. 18, 1940

Information Concerning Building

No. stories ---- Material of wall to which sign is to be attached -----

Details of Sign and Connections

Electric? No Vertical dimension after erection 5-6 Dia. Horizontal 5-6 Dia.

Weight 75 lbs., Will there be any hollow spaces? No Any rigid frame? Yes

Material of frame Pipe No. advertising faces 2 material Poro. Enam. Steel

No. rigid connections 4 Are they fastened directly to frame of sign? Yes

No. through bolts ---- Size _____, Location, top or bottom _____

No. guys None material _____, Size _____

Minimum clear height above sidewalk or street 12-0

Maximum projection into street 23 inches

Fee \$ _____

Signature of contractor J. H. Middlebrook
CHIEF OF FIRE DEPT. Over. L. M. M.

INSPECTION COPY