

569-617 DANFORTH STREET
THRU 1967 1

**CERTIFICATE OF APPROVAL
FOR INTERNAL PLUMBING**

THE TOWN/CITY OF Portland

TOWN/CITY CODE 15170 LPI NUMBER 00123 DATE ISSUED N 23 82 620811C

Installer's Name WASCORP Last Name W F I M I R D Installer Code 2

Owner Marion Industries Address 579 Danforth St St/Lot Number 579 Street, Road Name Danforth St Subdivision

(Location where plumbing was done and inspected)

- Certificate of App. Number
- 1 Owner
 - 2 Licensed Master Plumber
 - 3 Licensed Oil Burnerman
 - 4 Employee of Public Utility
 - 5 Manufactured Housing Dealer
 - 6 Manufactured Housing Mechanic
 - 7 Limited License

THE INTERNAL PLUMBING INSTALLED PURSUANT TO THE ABOVE CERTIFICATE OF APPROVAL NUMBER HAS BEEN TESTED IN MY PRESENCE, FOUND TO BE FREE FROM LEAKS, AND WAS INSTALLED IN COMPLIANCE WITH THE MUNICIPAL AND STATE PLUMBING RULES.

OWNER'S COPY

Signature of Carol D. Goodwin
Date Inspected MAY 1 1982

INTERNAL PLUMBING PERMIT FOR THE TOWN/CITY OF

Town/City Code 15170 LPI Number 00123 Date Issued 4 28 82 INSTALLER'S 1015 IP

Address of Where Plumbing is Done 579 DANFORTH STREET St/Lot Number 579 Street, Road Name DANFORTH STREET Subdivision

Name of Owner WASCORP Last Name W F I M I R D Mailing Address Zip Code

Type of Construction	1 New	3 Addition	5 Replacement of Hot Water Heater	7 Hook-up of Modular Home
	2 Remodeling	4 Remodeling & Addition	6 Hook-up of Mobile Home	8 Other (Specify) <u></u>
Plumbing To Serve	1 Single (Res)	3 Mobile Home	5 Commercial	7 Other (Specify) <u></u>
	2 Multi-Fam Res	4 Modular Home	6 School	
Number of Fixtures or Hook-Ups	Sink(s) <u>1</u>	Toilet(s) <u>1</u>	Bath(s) <u>1</u>	Laundry(s) <u>1</u>
	Clothes Washers <u>1</u>	Dish Washers <u>1</u>	Hot Water Heaters <u>1</u>	Floor Drains <u>1</u>
				Hook Up(s) <u>1</u>
				Shower(s) <u>1</u>
				Urinal(s) <u>1</u>

TOWN'S COPY

APR 23 1982

IMPORTANT Note the following conditions:
1. This Permit is non-transferable to another person or party.
2. If construction has not started within 6 months from the Date of Issue, this Permit becomes invalid.

Dept. of Human Services
Div. of Health Engineering

Signature of LPI

Fixture Fee
Hook Up Fee 0.0
Total Fee
If Double Fee Check Box ☐

INSPECTIONS Service

Service called in

Closing-in

by *Libby*
P-2-82
by *Libby*
6-8-82

PROGRESS INSPECTIONS

7-27-82
8-5-82
8-11-82
9-24-82

CODE
COMPLIANCE
RECEIVED
DATE <i>7-24-82</i>

DATE

REMARKS

Existing service changed to 3phase by
adding wire.

ELECTRICAL INSTALLATIONS—

Permit Number

Location

Owner

Date of Permit

Final Inspection

By Inspector

Permit Application Register Page No

77691

601 Dec. 16, 81

St. Paul, Minn.

5-11-82

9-24-82

Libby

117



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date Feb. 26, 19 82
Receipt and Permit number A 88137

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 601 Danforth Street

OWNER'S NAME Merrill Industries Inc. ADDRESS Allen Avenue

				FEES	
OUTLETS:					
Receptacles	Switches	Plugmold	ft. TOTAL		
FIXTURES (number of)					
Incandescent	Flourescent	(not strip) TOTAL			
Strip Flourescent	ft.				
SERVICES:					
Overhead	☒ Underground	Temporary	TOTAL amperes	100	3.00
METERS: (number of)					.50
MOTORS: (number of)					
Fractional					
1 HP or over					
RESIDENTIAL HEATING:					
Oil or Gas (number of units)					
Electric (number of rooms)					
COMMERCIAL OR INDUSTRIAL HEATING:					
Oil or Gas (by a main boiler)					
Oil or Gas (by separate units)					
Electric Under 20 kws	Over 20 kws				
APPLIANCES (number of)					
Ranges		Water Heaters			
Cook Tops		Disposals			
Wall Ovens		Dishwashers			
Driers		Compressors			
Fans		Others (denote)			
TOTAL					
MISCELLANEOUS (number of)					
Branch Panels					
Transformers					
Air Conditioners Central Unit					
Separate Units (windows)					
Signs 20 sq. ft. and under					
Over 20 sq. ft.					
Swimming Pools Above Ground					
In Ground					
Fire/Burglar Alarms Residential					
Commercial					
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under					
over 30 amps					
Circus, Fairs, etc.					
Alterations to wires					
Repairs after fire					
Emergency Lights, battery					
Emergency Generators					
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT				INSTALLATION FEE DUE:	
FOR REMOVAL OF A "STOP ORDER" (304-16.b)				DOUBLE FEE DUE:	
				TOTAL AMOUNT DUE:	3.50

INSPECTION:

Will be ready on _____, 19____; or Will Call ☒ XX
CONTRACTOR'S NAME: Kenneth B. Wilson
ADDRESS: Ward Acres, Bridgton, Me.
TEL: 647-8877 or 797-2026
MASTER LICENSE NO.: 3274 SIGNATURE OF CONTRACTOR: Kenneth B. Wilson
LIMITED LICENSE NO.: _____

INSPECTOR'S COPY — WHITE
OFFICE COPY — CANARY
CONTRACTOR'S COPY — GREEN

INSPECTIONS: Service *✓*
Service called in *3-3-82* by *Kelly*
Closing-in *3-3-82* by *Kelly*
PROGRESS INSPECTIONS *3-3-82*

CODE
COMPLIANCE
COMPLETED
DATE *3-3-82*
DATE

REMARKS

ELECTRICAL INSULATIONS—
Permit Number *88137*
Location *601 Du Pont St.*
Owner *Therrell Bank*
Date of Permit *2-26-82*
Final Inspection *3-3-82*
By Inspector *Kelly*
Permit Application Register Page No. *111*



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date Dec. 22, 1978
Receipt and Permit number A15943

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine.

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 571 Danforth St.

OWNER'S NAME: R.B. Harris

ADDRESS: _____

	FEES
OUTLETS:	
Receptacles <u>50</u> Switches _____ Plugmold _____ ft. TOTAL <u>50</u>	<u>5.00</u>
FIXTURES: (number of)	
Incandescent _____ Fluorescent _____ (not strip) TOTAL _____	
Strip Fluorescent _____ ft. _____	
SERVICES:	
Overhead <u>100</u> Underground _____ Temporary _____ TOTAL amperes _____	<u>3.00</u>
METERS: (number of) _____	
MOTORS: (number of)	
Fractional _____	
1 HP or over _____	
RESIDENTIAL HEATING:	
Oil or Gas (number of unit) _____	
Electric (number of rooms) _____	
COMMERCIAL OR INDUSTRIAL HEATING:	
Oil or Gas (by a main boiler) _____	
Oil or Gas (by separate unit) _____	
Electric Under 20 kws _____ Over 20 kws _____	
APPLIANCES: (number of)	
Ranges _____ Water Heaters _____	
Cook Tops _____ Disposals _____	
Wall Ovens _____ Dishwashers _____	
Dryers _____ Compactors _____	
Fans _____ Others (denote) _____	
TOTAL _____	
MISCELLANEOUS: (number of)	
Branch Panels _____	
Transformers _____	
Air Conditioners Central Unit _____	
Separate Units (windows) _____	
Signs 20 sq. ft. and under _____	
Over 20 sq. ft. _____	
Swimming Pools Above Ground _____	
In Ground _____	
Fire/Burglar Alarms Residential _____	
Commercial _____	
Heavy Duty Outlets, 220 volt (such as welders) 30 amps and under _____	
over 30 amps _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Emergency Lights, battery _____	
Emergency Generators _____	
INSTALLATION FEE DUE:	<u>8.00</u>
FOR REMOVAL OF A "STOP ORDER" (304-16.b) _____	
DOUBLE FEE DUE:	
TOTAL AMOUNT DUE:	<u>8.00</u>

INSPECTION:

Will be ready on _____, 19____; or Will Call _____

CONTRACTOR'S NAME: Louis Cavalaro

ADDRESS: 125 Sherwood St.

TEL.: 774-3813

MASTER LICENSE NO.: 1703

LIMITED LICENSE NO.: _____

SIGNATURE OF CONTRACTOR: _____

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date Oct. 3, 19 78
Receipt and Permit number _____

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of
Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 571 Danforth Street

OWNER'S NAME Goodall Trailer Sales ADDRESS: same FEES _____

OUTLETS:	Receptacles _____	Switches _____	Plugmold _____	ft. TOTAL _____
FIXTURES (number of)	Incandescent _____	Flourescent _____	(not strip) TOTAL _____	
	Strip Flourescent _____	ft. _____		
SERVICES:	Overhead _____	Underground _____	Temporary _____	TOTAL amperes _____
METERS (number of) _____				
MOTORS (number of) _____				
	Fractional _____			
	1 HP or over _____			
RESIDENTIAL HEATING:				
	Oil or Gas (number of units) _____			
	Electric (number of rooms) _____			
COMMERCIAL OR INDUSTRIAL HEATING:				
	Oil or Gas (by a main boiler) _____			
	Oil or Gas (by separate units) _____			
	Electric Under 20 kws _____	Over 20 kws _____		
APPLIANCES (number of)				
	Ranges _____	Water Heaters _____		
	Cook Tops _____	Disposals _____		
	Wall Ovens _____	Dishwashers _____		
	Dryers _____	Compressors _____		
	Fans _____	Others (denote) _____		
	TOTAL _____			
MISCELLANEOUS (number of)				
	Branch Panels _____			
	Transformers _____			
	Air Conditioners Central Unit _____			
		Separate Units (windows) _____		
	Signs 20 sq. ft. and under _____			
		Over 20 sq. ft. _____		
	Swimming Pools Above Ground _____			
		In Ground _____		
	Fire/Burglar Alarms Residential _____			
		Commercial _____		
	Heavy Duty Outlets, 220 Vc't (such as welders) 30 amps and under _____			
		over 30 amps _____		
	Circus, Fairs, etc. _____			
	Alterations to wires _____			3.00
	Repairs after fire <u>XX</u> _____			
	Emergency Lights, battery _____			
	Emergency Generators _____			

INSTALLATION FEE DUE: _____

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT _____ DOUBLE FEE DUE: _____

FOR REMOVAL OF A "STOP ORDER" (304-16.b) _____

TOTAL AMOUNT DUE: 3.00

INSPECTION:

Will be ready on done, 19 78; or Will Call _____

CONTRACTOR'S NAME: Mancini Electric

ADDRESS: 179 Sheridan Street

TEL.: _____

MASTER LICENSE NO.: _____

LIMITED LICENSE NO.: _____

SIGNATURE OF CONTRACTOR: _____

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date Oct. 26, 1978, 19
Receipt and Permit number A 13091

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine
The undersigned hereby applies for a permit to make electrical installations in accordance with the law of
Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 601 Danforth Street
OWNER'S NAME: Paul Merrill ADDRESS: _____

		FEES
OUTLETS:		
Receptacles	Switches _____ Plugmold _____ ft. TOTAL _____	
FIXTURES: (number of)		
Incandescent _____	Flourescent _____ (not strip) TOTAL _____	
Strip Flourescent _____ ft. _____		
SERVICES:		
Overhead xx _____	Underground _____ Temporary _____ TOTAL amperes <u>200</u>	3.00
METERS (number of) <u>1</u>		.50
MOTORS (number of)		
Fractional _____		
1 HP or over _____		
RESIDENTIAL HEATING:		
Oil or Gas (number of units) _____		
Electric (number of rooms) _____		
COMMERCIAL OR INDUSTRIAL HEATING:		
Oil or Gas (by a main boiler) _____		
Oil or Gas (by separate units) _____		
Electric Under 20 kws _____ Over 20 kws _____		
APPLIANCES (number of)		
Ranges _____	Water Heaters _____	
Cook Tops _____	Disposals _____	
Wall Ovens _____	Dishwashers _____	
Dryers _____	Compactors _____	
Fans _____	Others (denote) _____	
TOTAL _____		
MISCELLANEOUS: (number of)		
Branch Panels _____		
Transformers _____		
Air Conditioners Central Unit _____		
Separate Units (windows) _____		
Signs 20 sq. ft. and under _____		
Over 20 sq. ft. _____		
Swimming Pools Above Ground _____		
In Ground _____		
Fire/Burglar Alarms Residential _____		
Commercial _____		
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____		
over 30 amps _____		
Circus, Fairs, etc. _____		
Alterations to wires _____		
Repairs after fire _____		
Emergency Lights, battery _____		
Emergency Generators _____		

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT INSTALLATION FEE DUE: _____
FOR REMOVAL OF A "STOP ORDER" (304-16.b) DOUBLE FEE DUE: _____
TOTAL AMOUNT DUE: 3.50

INSPECTION:
Will be ready on ready, 1978; or Will Call _____
CONTRACTOR'S NAME: Curran Electric
ADDRESS: 49 Dartmouth St.
TEL: 722-4241
MASTER LICENSE NO.: 2219
LIMITED LICENSE NO.: _____

SIGNATURE OF CONTRACTOR:

Douglas Day

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN

INSPECTIONS: Service ☒
Service called in ☐
Closing-in ☐

by *Lilly*
11-8-78

PROGRESS INSPECTIONS.

10-26-78 AM
10-26-78 PM not done
11-7-78 not done
11-6-78 not done

CODE
COMPLIANCE
COMPLETED
11-8-78

ELECTRICAL INSTALLATIONS—
Permit Number: 13091
Location: 601 Dauphin St.
Owner: Paul Merrill
Date of Permit: 10-26-78
Final Inspection: 11-8-78
By Inspector: *Lilly*
Permit Application Register Page No. 6

DATE: REMARKS:

10-26-78 No gr bushing on mast.
gr wire inside needs ~~more~~ PVC.
How seal cabinet?
11-6-78 GR. WIRE RUN IN EMT.

OK

CITY OF PORTLAND, MAINE Application for Permit to Install Wires

Permit No. 57537
Issued January 29, 1967
1/29, 1967

Portland, Maine

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out - Minimum Fee, \$1.00)

Owner's Name and Address *Harrell Boat Sales* Tel. *774-0604*
Contractor's Name and Address *Al Ames* Tel. *774-0604*
Location *Campana St.* Use of Building
Number of Families Apartments Stores Number of Stories
Description of Wiring: New Work Additions Alterations ☒

Pipe Cable Metal Molding BX Cable Plug Molding No. of feet
No. Light Outlets Plugs Light Circuits Plug Circuits
FIXTURES: No Fluor. or Strip Lighting (No. feet)
☒ SERVICE: Pipe ☒ Cable Underground No. of Wires *3* Size *100A*
METERS: Relocated Added Total No. Meters
MOTORS: Number Phase H. P. Amps Volts Starter
HEATING UNITS: Domestic (Oil) No. Motors Phase H.P.
Commercial (Oil) No. Motors Phase H.P.
Electric Heat (No. of Rooms)
APPLIANCES: No. Ranges Watts Brand Feeds (Size and No.)
Elec. Heaters Watts
Miscellaneous Watts Extra Cabinets or Panels
Transformers Air Conditioners (No. Units) Units (No. Units)
Will commence *1/30* 19*68* Ready to cover in 19 Inspection *19*
Amount of fee \$ *2.00*

Signed *Al Ames*

DO NOT WRITE BELOW THIS LINE

SERVICE ☒ METER GROUND ☒
VISITS: 1 2 3 4 5 6
7 8 9 10 11 12
REMARKS:

INSPECTED BY

William
(OVER)

Inside wiring by owner!

LOCATION *Danforth ST 571*
 INSPECTION DATE *2/3/69*
 WORK COMPLETED *2/3/69*
 TOTAL NO. INSPECTIONS
 REMARKS:

FEEs FOR WIRING PERMITS EFFECTIVE JULY 31, 1968

WIRING	
1 to 30 Outlets	\$ 2.00
31 to 60 Outlets	3.00
Over 60 Outlets, each Outlet	.05
(Each twelve feet or fraction thereof of fluorescent lighting or any type of plug molding will be classed as one outlet).	
SERVICES	
Single Phase	2.00
Three Phase	4.00
MOTORS	
Not exceeding 50 H.P.	3.00
Over 50 H.P.	4.00
HEATING UNITS	
Domestic (Oil)	2.00
Commercial (Oil)	4.00
Electric Heat (Each Room)	.75
APPLIANCES	
Ranges, Cooking Tops, Ovens, Water Heaters, Disposals, Built-in Dishwashers, Dryers, and any permanent built-in appliance — each unit	1.50
MISCELLANEOUS	
Temporary Service, Single Phase	1.00

A.P.- 571 Danforth St.

Dec. 13, 1918

Goodall Boat Sales
571 Danforth Street

Gentlemen:


Permit is being issued to construct a 24'x32' 1-story
frame addition on existing building at the above named location,
subject to the following Building Code requirements:

1. At least a 4x6 inch header is to be used over
the side door.
2. The concrete slab is to support the side post
only and not cover them, the slab is also to be
held back from going under the sill.

Very truly yours,

Edwin W. Locke, Jr.
Inspector II

EWL:m



4x6" sills

4x4 up rights over sonotube

2x4 studding between on 16" centers


4x6 header along front of building

double 2x4 on end and back

boarding in with $\frac{1}{2}$ " plywood + shingles on side and back
metal on front

Goodell Boat Sales, Inc.

521 Danforth St. Portland, Maine



Goodall Best Sales, Inc.
 571 Danforth St.
 Portland, Maine



36 INDUSTRIAL ZONE
APPLICATION FOR PERMIT
Class of Building or Type of Structure Third Class
Portland, Maine December 3 1968

PERMIT ISSUED
1299
DEC 13 1968
CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE:

The undersigned hereby applies for a permit to erect alter, repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 571 Danforth St. Within Fire Limits? Dist. No.
Owner's name and address Goodall Boat Sales, 571 Danforth St. Telephone
Lessee's name and address Telephone
Contractor's name and address owners Telephone 773-1113
Architect Specifications Plans yes No. of sheets 2
Proposed use of building Display for Outboard Motors No. families
Last use " " " No. families
Material frame No. stories 1 Heat Style of roof Roofing
Other buildings on same lot Fee \$ 6.00
Estimated cost \$ 2000.00

General Description of New Work

To erect 24' x 32' frame 1-story addition(shell) on left side of building
long wide

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owners

Details of New Work

Is any plumbing involved in this work? no Is any electrical work involved in this work? yes
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent? yes
Height average grade to top of plate 10 1/2' Height average grade to highest point of roof 11'
Size, front 32' depth 24' No. stories 1 solid or filled land? solid earth or rock? earth
Material of foundation 4" concrete tubes at least 4' below grade Thickness, top bottom cellar
Kind of roof flat see plan Rise per foot 1/2" Roof covering Asphalt Class C Und Label
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind hemlock Dressed or full size? dressed Corner posts 4x4 Sills 4x6
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor concrete 2nd 3rd roof 12"
On centers: 1st floor 2nd 3rd roof 12"
Maximum span: 1st floor 2nd 3rd roof 12'
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot, to be accommodated, number commercial cars to be accommodated.
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Goodall Boat Sales

APPROVED:

OK 12/13/68 FUK

CS 301

INSPECTION COPY

Signature of owner

by: Leonard C. Goodall

Permit No. 68/1299
Location 571 Highland St
Owner Alvin W. McCarty
Date of permit 12/13/68
Notif. closing-in _____
Inspn. closing-in _____
Final Notif. _____
Final Inspn. _____
Cert. of Occupancy issued _____
Sinking Out Notice _____
Form Check Notice _____

NOTES

12-24-68 Wall framing
up.
3-24-69 Completed

CITY OF PORTLAND, MAINE Application for Permit to Install Wires

Permit No. 56797
Issued July 19, 1968
Portland, Maine

To the City Electrician, Portland, Maine:

The undersigned hereby applies for a permit to install wires for the purpose of conducting electric current, in accordance with the laws of Maine, the Electrical Ordinance of the City of Portland, and the following specifications:

(This form must be completely filled out - Minimum Fee, \$1.00)

Owner's Name and Address - *Jackell Best Sales* Tel. *774-0604*

Contractor's Name and Address - *Ed Ames*

Location - *571 Cascofort St.* Use of Building
Number of Families Apartments Stores Number of Stories
Description of Wiring: New Work Additions Alterations

Pipe Cable Metal Molding BX Cable Plug Molding (No. of feet)
No. Light Outlets Plugs Light Circuits Plug Circuits
FIXTURES: No. Light Switches Fluor. or Strip Lighting (No. feet)
✓ SERVICE: Pipe Cable ✓ Undergound No. of Wires *3/2 + 1/4 Size 60A*
METERS: Relocated Added Total No. Meters
MOTORS: Number Phase H. P. Amps Volts Starter
HEATING UNITS: Domestic (Oil) No. Motors Phase H. P.
Commercial (Oil) No. Motors Phase H. P.
Electric Heat (No. of Rooms)

APPLIANCES: No. Ranges Watts Brand Feeds (Size and No.)
Elec. Heaters Watts
Miscellaneous Watts Extra Cabinets or Panels

Transformers Air-Conditioners (No. Units) Signs (No. Units)
Will commence 19 Ready to cover in *7/19 1968* Inspection 19.
Amount of Fee \$ *2.00* Signed *Ed Ames*

DO NOT WRITE BELOW THIS LINE

SERVICE ✓
VISITS: 1 *7/19/68* 2
7 8
METER 3 4 5 6
10 11 12
GROUND

REMARKS:

INSPECTED BY *J. H. H. H.*

LOCATION 571 Danforth St
 INSPECTION DATE 7/19/68
 WORK COMPLETED 7/19/68
 TOTAL NO. INSPECTIONS 1
 REMARKS:

FEE FOR WIRING PERMITS EFFECTIVE JULY 31, 1963

WIRING	
1 to 30 Outlets	(including switches) \$ 2.00
31 to 60 Outlets	(including switches) 3.00
Over 60 Outlets, each Outlet	(including switches) .05
(Each twelve feet or fraction thereof of fluorescent lighting or any type of plug molding will be classed as one outlet).	
SERVICES	
Single Phase	2.00
Three Phase	4.00
MOTORS	
Not exceeding 50 H.P.	3.00
Over 50 H.P.	4.00
HEATING UNITS	
Domestic (Oil)	2.00
Commercial (Oil)	4.00
Electric Heat (Each Room)	.75
APPLIANCES	
Ranges, Cooking Tops, Ovens, Water Heaters, Disposals, Dishwashers, etc. — Each Unit	1.50
TEMPORARY WORK (limited to 6 months from date of permit)	
Service, Single Phase	1.00
Service, Three Phase	2.00

571
A.P.-51 Danforth St.

May 28, 1965

Edward Willette
7 Bowdoin Ave
So. Portland

cc to: Goodall Boat Sales
571 Danforth Street

Dear Mr. Willette:

Permit to construct a 1-story frame addition 10'x23' to the existing building at the above address is being issued subject to plan received with application and in compliance with Building Code restrictions as follows:

1. The Rest Rooms will each need to have an operating window to supply ventilation or a mechanical system that is approved by the Health Department.
2. The sills will need to be at least of a 6x8 inch solid member.
3. The floor joists will need to be not less than 2x8 inch, spaced 12 inches on centers or 2x10 inch spaced not more than 18 inches on centers.
4. Any rough openings in the outside walls larger than 30 inches wide will need structural headers. The size of such headers will need to be given to this office before a form inspection is called for.
5. Section 205-1-1. On every floor used for workshops and storage purposes, signs of permanent character shall be displayed in conspicuous places, stating the maximum superimposed or live load which such floor is designed to support.

Very truly yours,

Archie L. Jenkins
Deputy Building Inspection Director

Sim

571
A.P.-51 Danforth St.

May 28, 1965

Edward Willette
7 Bowdoin Ave
So. Portland

cc to: Goodall Boat Sales
571 Danforth Street

Dear Mr. Willette:

Permit to construct a 1-story frame addition 10'x23' to the existing building at the above address is being issued subject to plan received with application and in compliance with Building Code restrictions as follows:

1. The rest rooms will each need to have an operating window to supply ventilation or a mechanical system that is approved by the Health Department.
2. The sills will need to be at least of a 6x8 inch solid member.
3. The floor joists will need to be not less than 2x8 inch, spaced 12 inches on centers or 2x10 inch spaced not more than 18 inches on centers.
4. Any rough openings in the outside walls larger than 30 inches wide will need structural headers. The size of such headers will need to be given to this office before a form inspection is called for.
5. Section 205-1-1. On every floor used for workshops and storage purposes, signs of permanent character shall be displayed in conspicuous places, stating the maximum superimposed or live load which such floor is designed to support.

Very truly yours,

Archie L. Jenkins
Deputy Building Inspection Director

A:Sim



APPLICATION FOR PERMIT

Class of Building or Type of Structure

Third Class

Portland, Maine, MAY 21, 1965

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, Plans and specifications, if any, submitted herewith and the following specifications

Location 571 Danforth St. Within Fire Limits? Dist. No.
Owner's name and address Goodall Boat Sales, 571 Danforth St. Telephone
Lessee's name and address Telephone
Contractor's name and address Edward Willette Jr. 7 Bowdoin Ave. So. Portland Telephone 773-8677
Architect Specifications Plans yes No. of sheets 1
Proposed use of building Boat Sales No. families
Last use No. families
Material frame No. stories 1 Heat Style of roof Roofing
Other buildings on same lot
Estimated cost \$ 600.00

General Description of New Work

To construct 1-story frame addition 10' x 23' on side of existing building.

Permit issued with Letters

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO contractor

Details of New Work

Is any plumbing involved in this work? yes Is any electrical work involved in this work? yes
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate 7'6" Height average grade to highest point of roof 9'
Size, front 10' depth 23' No. stories 1 solid or filled land? solid earth or rock? earth
Material of foundation cedar posts at least 4' below grade concrete Thickness, top bottom cellar
Kind of roof shed Rise per foot 2" Roof covering Asphalt Class C Und Label.
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber-Kind 2x8 Dressed or full size? Corner posts 4x4 Sills 6x6
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2x8, 2nd, 3rd, roof 2x6
On centers: 1st floor 16", 2nd, 3rd, roof 16"
Maximum span: 1st floor 10', 2nd, 3rd, roof 10'
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVED:

Handwritten signature

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Goodall Boat Sales
Edward Willette Jr.

CS 301

INSPECTION COPY


Signature of owner

by:

Handwritten signature

6-11-65 Work found
slighting
7-15-65 Sills only on
7-28-65 Sander the
8-26-65 " the
9-27-65 Wood & roof
Examining up the
11-2-65 About done
the

Septic tank & leach line
bed on fire



601 Danforth St



PERMIT ZONE

APPLICATION FOR PERMIT

Class of Building or Type of Structure 2nd Class

Portland, Maine, January 23, 1964

PERMIT ISSUED

JAN 23 1964

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 601 Danforth St. Within Fire Limits? Dist. No.
Owner's name and address Gulf Oil Corp., 601 Danforth St. Telephone
Lessee's name and address Telephone
Contractor's name and address Robert Moulton, 122 E. Main Street Telephone
Architect Specifications Plans no. No. of sheets
Proposed use of building Warehouse No. families
Last use " No. families
Material masonry No. stories 2 Heat Style of roof Roofing
Other buildings on same lot
Estimated cost \$ 1000. Fee \$ 5.00

General Description of New Work

for rest room
To partition off room 9'8" x 12' in warehouse/- 2x4 studs, 16" O.C., sheathing 3/4" thick
To provide new ceiling in room, sheetrock

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO Moulton

Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimney of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor, 2nd, 3rd, roof
On centers: 1st floor, 2nd, 3rd, roof
Maximum span: 1st floor, 2nd, 3rd, roof
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Gulf Oil Corp.

APPROVED:

OR-1/23/64-aj.s.

CS 301

INSPECTION COPY

Signature of owner

By:

Robert H. Moulton

174

Permit No. 641/77

Location 601 Roubidoux St

Owner Steel Drilling Co

Date of permit 11/23/64

Notif. class

Inspn. closing

Final Notif.

Final Inspn.

Cert. of Occupancy issued

Stake Out Notice

Form Check Notice

NOTES

2-6-64 Completed
12
X



APPLICATION FOR PERMIT

Class of Building or Type of Structure
Portland, Maine,

2nd class
December 4, 1963

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 601 Lanforth St. Within Fire Limits? Dist. No.
Owner's name and address Gulf Oil Corp. 601 Lanforth St. Telephone
Lessee's name and address Telephone
Contractor's name and address C. Galli & Sons, 53 Portland St. Telephone 772-839
Architect Specifications Plans Yes No. of sheets 2
Proposed use of building Warehouse No families
Last use No. families
Material brick No. stories 1 Heat Style of roof Roofing
Other buildings on same lot
Estimated cost \$ 4000.00 Fee \$ 8.00

General Description of New Work

To install new overhead door on side of building (near end of eave) 2' x 11' as per plans.

Permit Issued

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** contractor

Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4 16" O. C. Bridge and flat roof span over 8
Joists and rafters: 1st floor 2nd roof
On centers: 1st floor 2nd roof
Maximum span: 1st floor 2nd roof
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot to be accommodated number commercial cars to be
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed

APPROVED:

G. E. McW. / owner

Miscellaneous

Will work require disturbing of any tree on?
Will there be in charge of the above work?
see that the State and City requirements
observed? yes

Gulf Oil Corp.
C. Galli & Sons

CS 301

INSPECTION COPY


Signature of owner by:

James H. G.

NOTES

12-31-63 opening made
ready for stock. *RL*

1-24-64 2" of cement
plaster going on steel *RL*



Permit No. *123/1604*
 Location *601 N. 4th St. St. Paul, Minn.*
 Owner *Ed. J. O'Brien*
 Date of permit *12/1/63*
 Notif. closing-in _____
 Inspn. closing-in _____
 Final Notif. _____
 Final Inspn. _____
 Cert. of Occupancy issued _____
 Staking Out Notice _____
 Form Check Notice _____



APPLICATION FOR PERMIT

Class of Building or Type of Structure

Third Class

Portland, Maine, November 8, 1961

PERMIT ISSUED

NOV 9 1961

CITY OF PORTLAND, MAINE

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location R. 601 Lanforth St. Within Fire Limits? _____ Dist. No. _____
Owner's name and address Goodall Boat Sales, R. 601 Lanforth St. Telephone _____
Lessee's name and address _____ Telephone _____
Contractor's name and address owner Telephone 3-1113
Architect _____ Specifications _____ Plans no No. of sheets _____
Proposed use of building Outboard Repair Shop No. families _____
Last use _____ No. families _____
Material frame No. stories 1 Heat _____ Style of roof _____ Roofing _____
Other buildings on same lot _____
Estimated cost \$ 100.00 Fee \$ 2.00

General Description of New Work

To erect "prefab chimney"

Type of heat and fuel—hot air—oil
Make of chimney—Van Facker-7" type K
Supported on frame of building.
Cleanout fitting to be used.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO owner

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
Has septic tank notice been sent? _____ Form notice sent? _____
Height average grade to top of plate _____ Height average grade to highest point of roof _____
Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
Framing Lumber—Kind _____ Dressed or full size? _____ Corner posts _____ Sills _____
Size Girder _____ Column under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED

OK-11/9/61-ags

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Goodall Boat Sales

CS 101

INSPECTION COPY

Signature of owner

Edward E. Goodall

12-1

Permit No. 611567
Location 2601 Van Ness St
Owner Samuel M. Smith
Date of permit 11/9/61
Notif. closing-in
Inspn. closing-in
Final Notif.
Final Inspn
Cert. of Occupancy issued
Taking Out Notice
Form Check Notice

NOTES

12-7-61 Completed
CC

X



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, November 7, 1961

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Rear 601 Danforth St. Use of Building Storage No. Stories 1 New Building Existing "
Name and address of owner of appliance Goodell Boat Sales, R 601 Danforth St.
Installer's name and address Harris Oil Company, 202 Commercial St. Telephone 2-8314

General Description of Work

To install forced warm air heating system and oil burning equipment in place of stove heat.
General Electric 14-11218 Permit Issued with Letter

IF HEATER, OR POWER BOILER

Location of appliance First floor Any burnable material in floor surface or beneath? none
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 2'
From top of smoke pipe thru roof From front of appliance over 4' From sides or back of appliance over 2'
Size of chimney flue thru Van Facker Chimney Other connections to same flue none
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner General Electric-gumtype Labelled by underwriters' laboratories? yes
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner cement Size of vent pipe 1 1/2"
Location of oil storage outside on cement slab. Number and capacity of tanks 275
Low water cut off steel Make No.
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc. 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Harris Oil Company

by:

Signature of Installer

INSPECTION COPY

7m

air No

Location in Box 11 - 11/11/11

Owner Donald R. Dea

Date of permit 11/18/61

Approved

NOTES

1	File #	
2	Vent Type	
3	Kind of Mass	
4	Location of Sample	
5	Name of Locality	
6	Sketch of Locality	
7	Sketch of Plant	
8	Number of Samples	
9	Field Notes	
10	Notes on Locality	
11	Notes on Plant	
12	Notes on Soil	
13	Notes on Water	
14	Notes on Air	
15	Notes on Other	

Land on blocks
4 short chapters

At-Rear 601 Danforth Street

November 14, 1961

Harris Oil Company
202 Commercial Street

cc to: Goodall Boat Sales
Rear 601 Danforth Street

Gentlemen:


Permit for installation of oil-burning forced warm air heating system in storage shed at the above named location is issued herewith subject to the condition that the outside above ground fuel storage tank is either to be supported on a single reinforced concrete slab at least 4 inches thick or shall have individual foundations for the supporting legs extending at least 4 feet below grade, as required by the Building Code.

Very truly yours,

Albert J. Sears
Building Inspection Director

AJS:m

Goodall Boat Sales (Outboard Repair Shop)
 571 Canford St.
 Portland, Maine



Length 72'0"
 Width 12'3"

RECEIVED
 NOV 8 1961
 DEPT. OF BLD'G INSP.
 CITY OF PORTLAND

freuen sich sehr

DE 35 68

15792

Address 571 Danforth Street

PERMIT NUMBER

Issued

Installation For. Goodall Boat Sale

Portland Plumbing

Owner of Bldg	Goodall Boat Sale
---------------	-------------------

Inspector

Plumber: William E. Miles

Date: 11-19-65

App. First Insp.

New	Rep'd	No.	Fee
-----	-------	-----	-----

Date 7/11/63

2	✓	SINKS			
		LAVATORIES			

9/9/2009

2	✓	SINKS		
2	✓	LAVATORIES	2	2

App. Final Insp.

TOILETS	2	4.00
BATH TUBS		

JUL 12 1966

	BATH TUBS		
	SHOWERS		

ERNOLD R. GOODWIN

1	DRAINS		

BY PLUMBING INSPECTOR
TYPE OF P.I.D. _____

0	DRAINS		
	HOT WATER TANKS		

~~CRF PLUMBING INSPECTOR~~
Type of Bldg.

	TANKLESS WATER HEATERS		
	GARBAGE GRINDERS		

☒ Commercial

		GARBAGE GRINDERS		
--	--	------------------	--	--

☐ Residential
☐ Single

	SEPTIC TANKS		
--	--------------	--	--

☐ Multi Family

	SEPTIC TANKS		
	HOUSE SEWERS		

☐ New Construction
☐ Remodeling

		HOUSE SEWERS		
--	--	--------------	--	--

TOTAL	\$8.72
-------	--------

PORTLAND HEALTH DEPT. PLUMBING INSPECTION

1-2 INDUSTRIAL ZONE



APPLICATION FOR PERMIT

Class of Building or Type of Structure 2nd class
Portland, Maine, August 18, 1961

PERMIT ISSUED
 01049
 AUG 22 1961
 CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 601 Sanford St. Within Fire Limits? _____ Dist. No. _____
 Owner's name and address Gulf Oil Corp. 601 Sanford St. Telephone _____
 Lessee's name and address _____ Telephone _____
 Contractor's name and address Lloyd N. White, Inc. 220 Commercial St. Telephone 2-3167
 Architect _____ Specifications _____ Plans yes No. of sheets 1
 Proposed use of building Loading Building No. families _____
 Last use _____ No. families _____
 Material _____ No. stories 1 Heat _____ Style of roof _____ Roofing _____
 Other buildings on same lot _____
 Estimated cost \$ 3,000.00 Fee \$ 7.00

General Description of New Work

To erect barclite plastic curtain as per plan.

Permit Issued with Letter

Sent to Fire Dept 8/18/61
 Rec'd from Fire Dept 8/22/61

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. **PERMIT TO BE ISSUED TO** contractor

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
 Is connection to be made to public sewer? _____ If not, what is proposed for sewage? _____
 Has septic tank notice been sent? _____ Form notice sent? _____
 Height average grade to top of plate _____ Height average grade to highest point of roof _____
 Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
 Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
 Kind of roof _____ Rise per foot _____ Roof covering _____
 No. of chimneys _____ Material of chimneys _____ of lining _____ Kind of heat _____ fuel _____
 Framing Lumber—Kind _____ Dressed or full size? _____ Corner posts _____ Sills _____
 Size Girder _____ Columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
 Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
 If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____ number commercial cars to be accommodated _____
 Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

APPROVED:

with letter by AGJ
Chief of Fire Dept.
 CHIEF OF FIRE DEPT.

Miscellaneous

Will work require disturbing of any tree on a public street? no
 Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Gulf Oil Corp.
 Lloyd N. White Inc.

CS 301

INSPECTION COPY

Signature of owner

b1:

9-21-61

Permit No. 61/1049
Location 601 Danforth St.
Owner Buck/Will Corp.
Date of permit 8/22/61
Notif. closing-in
Inspn. closing-in
Final Notif.
Final Inspn.
Cert. of Occupancy issued
Sinking Out Notice
Form Check Notice

NOTES

9-18-61 Steel frame
going up
9-26-61 (completed)
CP

X

AP-601 Danforth Street

August 22, 1961

Lloyd M. White, Inc.
326 Commercial Street

cc to: Gulf Oil Company
601 Danforth Street

Gentlemen:

Permit for erecting plastic wall around edges of canopy over loading rack at the above named location extending about five feet below the surface of the roof is issued herewith. It is understood that at the corners some sort of an incombustible corrugated material extending at least four feet each way from the corner is to be installed in place of the corrugated plastic, or else that some other arrangement will be used whereby there will not be more than a 100 foot run of continuous plastic without at least an 8-foot separation of incombustible material between it and the next section of plastic. Permit is issued on this basis.

Very truly yours,

AJS/jg

Albert J. Sears
Building Inspection Director

Carl P. Johnson, Chief of Fire Department

August 18, 1961

Albert J. Sears, Building Inspector Director

Approval of permit for installation of plastic curtain walls
below roof of loading rack in bulk gasoline storage yard of
Gulf Oil Company at 601 Danforth Street

Attached herewith is permit application for this work. Panels of Barclite reinforced thermosetting plastic are to be erected around the edge of the roof of this loading rack, suspended on an angle iron frame and extending only to a point 5 feet 6 inches below the roof surface. This plastic is of a slow burning type approved by the Underwriters. The B.O.C.A. Code, to which the Building Code refers in regard to the use of plastics, limits a continuous run of this type of plastic to 100 feet with at least 8 feet of incombustible material between runs of plastic. To comply with this requirement, they propose to use corrugated metal siding for at least 4 feet each side of all corners with plastic the rest of the way.

In view of the hazards involved in storage plants for inflammable liquids, it seems best to have you review the situation and, if you deem advisable, approve the permit before issuance. I understand that the plastic does not support combustion but merely melts if enough heat is applied. While this plastic certainly cannot be termed incombustible, I doubt if it presents any particular hazard from a conflagration standpoint. They tell me that several of the oil companies have installed similar construction on their loading racks in plants in South Portland. They are anxious to get the work done right away so that as quick action as possible will be appreciated.

AJS/H

Director of Building Inspection

1-2 INDUSTRIAL ZONE
APPLICATION FOR PERMIT



Class of Building or Type of Structure

Portland, Maine, June 23, 1960

PERMIT ISSUED

JUN 29 1960

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 601 Danforth Street Within Fire Limits? Dist. No.
Owner's name and address Gulf Oil Corp., 601 Danforth St. Telephone
Lessee's name and address Telephone
Contractor's name and address Commercial Welding Co., 18 Ocean St., So. Portland, Telephone 9-2388
Architect Specifications Plans Yes No. of sheets 4
Proposed use of building Loading platforms and dike for tank No. families
Last use No. families
Material No. stories Heat Style of roof Roofing
Other buildings on same lot tanks and office
Estimated cost \$ 30,000 Fee \$ 30.00

General Description of New Work

To construct 3-steel loading platforms as per plans
To relocate portion of one loading platform "
To demolish existing dike for tank and construct new dike as per plans

Sent to Fire Dept. 6/24/60
from Fire Dept. 6/25/60

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO Commercial Welding Co.

Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Material of underpinning Height Thickness
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber-Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Kind and thickness of outside sheathing of exterior walls?
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor, 2nd, 3rd, roof
On centers: 1st floor, 2nd, 3rd, roof
Maximum span: 1st floor, 2nd, 3rd, roof
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVED:

C.N.-6/29/60-00V
Carl P. Johnson
CHIEF OF FIRE DEPT.

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Gulf Oil Co.
Commercial Welding Co.

INSPECTION COPY

Signature of owner B.

Donald Jensen

P. H.

NOTES

2-12-60 Excavation in
quarters area for
pipe lines. (C)

7-26-60 Located the
main pump in. (C)

8-29-60 Steel work
center section of
in. pump foundation. (C)

9-23-60 Platforms
about done starting
grading & fencing. (C)

11-1-60 Fence posts
up. Dem. of old
platforms not done. (C)

12-1-60 Section of
old loading platform
going on new location. (C)

12-23-60 Completed
except removal of
old tank section. (C)

1-31-61 Completed. (C)

1801
 1667 in 160
 closing-in
 closing-in
 Fall Notif.
 final Inspn.
 Cert. of Occupancy issued
 Staking Out Notice
 Form Check Notice

At- 601 Danforth St.

June 24, 1960

Gulf Oil Corporation
601 Danforth Street

cc to: Commercial Welding Company
18 Ocean St., S. Portland

Gentlemen:

Application for permit for erection of three steel loading platforms and alterations in dike at your bulk storage plant at the above named location has been filed by the Commercial Welding Company. Before a permit can be issued it is necessary that we have a statement of design (blank copy enclosed) covering the design of the structural steel and reinforced concrete involved. Will you please have this statement filled out and signed by a competent person who is taking responsibility for the design and return to this office as soon as possible so that there may be no unnecessary delay in issuance of the permit. Meanwhile we will send the plan and application to the Fire Department for the approval required before issuance of permit.

Very truly yours,

Albert V. Sears
Inspector of Buildings

JS:m

AP-601 Danforth Street

June 28, 1960

Commercial Welding Co.
18 Ocean Street
South Portland, Maine
Gulf Oil Corporation
601 Danforth Street

Gentlemen:

Before a permit for erection of three loading platforms and construction of a new concrete dike wall at the above named location can be issued, it is necessary that we have for affixing to the plans already filed a statement of design (blank copy enclosed) covering the design of the reinforced concrete and structural steel involved. We note that the plans indicate a change from 22 feet to 30 feet between H columns supporting roof of racks without any change in size of main steel beams supporting the roof structure. Are the beams indicated adequate to support the required live load of 40 pounds per square foot on the larger span? The statement of design needs to be signed by some qualified person taking responsibility for the design and to be returned to this office.

Very truly yours,

AJS/jg
Encl.

Albert J. Sears
Inspector of Buildings



PETROLEUM AND ITS PRODUCTS

GULF OIL CORPORATION

BOSTON SALES DIVISION

PARK SQUARE BUILDING - BOSTON 17, MASS.

June 28, 1960

D. W. FERRIS
J. M. STAMBAUGH JR.
A. A. STAMBAUGH JR.
J. A. MILLARD
J. M. STEWART
E. A. WIGLAND

City of Portland
Department of Building Inspection
110 City Hall
Portland, Maine

Attention Mr. Albert J. Sears, Inspector of Buildings

PORTLAND, MAINE TERMINAL
Improvement of Loading Facilities


Gentlemen:

In reply to your letter of June 24, 1960, we are returning
to you statement of design executed as directed.

Yours very truly,

M. Stewart
Division Manager, Supply & Operation

RWH:CMcM
Encl.





1-2 INDUSTRIAL ZONE

APPLICATION FOR PERMIT

Class of Building or Type of Structure Inflammable storage tanks

Portland, Maine, June 23, 1960

PERMIT ISSUED

JUN 24 1960

CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 601 Danforth Street Within Fire Limits? Dist. No.
Owner's name and address Gulf Oil Co., 601 Danforth St. Telephone
Lessee's name and address Telephone
Contractor's name and address Commercial Welding Co., 18 Ocean St., Portland Telephone
Architect Specifications Plans No. of sheets
Proposed use of building No. families
Last use No. families
Material No. stories Heat Style of roof Roofing
Other buildings on same lot Fee \$ 1.00
Estimated cost \$

General Description of New Work

To remove (4) waste oil and fuel oil tanks.

6/24/60-Capt. Flaherty says that these tanks have already been removed. - ajs

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO Commercial Welding Co.

Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Material of underpinning Height Thickness
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber-Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Kind and thickness of outside sheathing of exterior walls?
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor, 2nd, 3rd, roof
On centers: 1st floor, 2nd, 3rd, roof
Maximum span: 1st floor, 2nd, 3rd, roof
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Gulf Oil Co.
Commercial Welding Co.

APPROVED:

INSPECTION COPY


Signature of owner

By:

David Jensen

Permit No. 601785
Location 601 West 1st St.
Owner Acad. Dist. Center
Date of permit 6/24/60
Notif. closing-in _____
Inspn. closing-in _____
Final Notif. _____
Final Inspn. _____
Cert. of Occupancy issued _____
Staking Out Notice _____
Form Check Notice _____

NOTES



OR 569.597-18/60

~~Mell.~~

Please check -

AGJ
long copy given
to N.F. B. in permit
not secured because
so much of the
work has been
done without
permit

1 MTR

4/20/60



I-30111111111111111111

APPLICATION FOR PERMIT

Class of Building or Type of Structure Third Class

Portland, Maine, April 18, 1960

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location d. 569-597 Danforth St. Within Fire Limits? Dist. No.
Owner's name and address Goodall Boat Sales (Leonard C. Goodall), Telephone 3-1113
R. 569 Danforth St.
Lessee's name and address Telephone
Contractor's name and address owner Telephone
Architect Specifications Plans no yes No. of sheets 1
Proposed use of building Boat Sales & office No. families
Last use No. families
Material frame No. stories 1 Heat Style of roof Roofing
Other buildings on same lot
Estimated cost \$ 500. Fee \$ 2.00

General Description of New Work

To install Metalbestos chimney to serve oil burning furnace, this ~~structure~~ ^{chimney} to be suitably supported on the existing roof structure.

To construct two interior partitions and to support upon them and the exterior walls a ceiling over the 20' section on the left as one faces the building, ceiling to be of fibre tile, and partitions and ceiling to be framed in compliance with the Building Code.

To construct an 8" thick foundation wall of concrete the entire length of the front of the building incorporating in it the existing concrete piers between the large openings, this wall to extend no less than 4' below grade and about 6" above. Originally there were 5 large openings in the front wall. To close 2 of them permanently using 4x6 sill bolted down. The other 3 openings are to be closed permanently using 4x6 sill, or be equipped with ~~It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.~~ PERMIT TO BE ISSUED TO doors suitably hinged.

8/15/61 - Permit never issued
Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Material of underpinning Height Thickness
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Kind and thickness of outside sheathing of exterior walls?
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor , 2nd , 3rd , roof
On centers: 1st floor , 2nd , 3rd , roof
Maximum span: 1st floor , 2nd , 3rd , roof
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot , to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVED:

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Goodall Boat Service

Leonard C. Goodall

Signature of owner By:

INSPECTION COPY

P.H.

NOTES

4-28-60 Not started

5-10-60 " " "

5-25-60 Foundation

not started

Goodall want to know

why we are picking

on him. Are we

trying to drive him

out of business.

Will cost him 300.

What good will it

do. Can't he use

a 4x6" wood beam

across some tables.

How about cement

blocks? What will

it take to let him

alone?

7-13-60 Nothing

To complete

10-18-60 Same

11-1-60 To start

after his vacation

Dec 1, 1960

12-1-60 Back tomorrow

8/15/61

Decided to press these

matters no farther

Permit No.	601
Location	5569-5971 Dumbuck St.
Owner	Lee Lee B. B. B.
Date of permit	4/1/60
Notif. closing-in	
Inspn. closing-in	
Final Notif.	
Final Inspn.	
Cert. of Occupancy issued	
Staking Out Notice	
Form Check Notice	

← Complaint →
Permit not issued.

NOTES

4-25-60 Not started

5-10-60

5-25-60 Foundation
not started
Goodall want to know
why we are picking
on him. Are we
trying to drive him
out of business.

Will cost him \$300.
What good will it
do. Can't he use
a 4x6" wood beam
across son's legs.
How about cement
blocks? What will
it take to let him
alone?

7-13-60 Nothing done.
To come up & see sons

10-18-60 Same

11-1-60 To start
after his vacation
Dec. 1, 1960

12-1-60 Back tomorrow

8/15/61
Decided to press these
matters no farther

Permit No. 601
Location 1569-5971 (Baptist)
Owner The Lee & B. H. H. H.
Date of permit 4/1/60
Notif. closing-in
Inspn. closing-in
Final Notif.
Final Inspn.
Cert. of Occupancy issued
Sinking Out Notice
Form Check Notice

Complaint
Permit not issued.



CITY OF PORTLAND, MAINE
DEPARTMENT OF BUILDING INSPECTION
COMPLAINT

Location:

INSPECTION COPY

COMPLAINT NO. 59/89

Date Received December 23, 1959

Location Rear 569-597 Danforth Street Use of Building _____

Owner's name and address Goodall Boat Sales (Leonard C. Goodall) Telephone 3-1113

Tenant's name and address _____ Telephone _____

Complainant's name and address NFC & Wied. Telephone _____

Description: A Metalbestos chimney has been erected; two of the five 10 foot wide openings in the boat house have been permanently closed without a suitable sill and without proper foundations; two interior partitions have been built and ceiling constructed over the 20 foot length of the building toward town—all without securing a building permit. The NOTES: other three of the five openings have been temporarily closed with wood studs covered by masonite, one of the panels on hinges and all of these panels get their support on the concrete floor slab.

Because of the cold weather, Mr. Goodall understands that he will not be required to secure a building permit for this work and to make good the deficiencies of ~~the~~ sills and foundations until April 15, 1960. In the meantime he is to run all risk as to damage from heaving by frost. He understands that he is not to proceed with any change of the sills and supports without applying for a permit and clearing up how it is to be done. If he should decide to do this work of correction now, he will first apply for a permit to do it, coming to an agreement as to how it shall be done, and then he will be expected to go ahead and do it while the permit is still handled in this department.

4-14-60 Mr. Goodall to come in for permit to alter above work Wied

4/18/60 - Permit applied for by Mr. Goodall, up to sill in the foundation, but should not do the other work
Wied

FU - 12/29/59 AJS

Complete
AP-Rear 569-597 Danforth Street

December 21, 1959

Leonard C. Goodall
21 Plymouth Road
South Portland, Maine

cc to: Harris Oil Company
202 Commercial Street

Dear Mr. Goodall:

An inspector from this department reports that considerable alteration work has been done on building constructed for a boat shed at the above location without a permit first having been secured to cover such work. Alterations include erection of a pre-fabricated chimney, construction of enclosing front walls for one or more bays, erection of several partitions, provision of a concrete slab floor and installation of heating equipment.

According to our records the building is supported on concrete piers with no sills between piers across the front. Thus, if new front wall is supported directly on the concrete slab, it does not have a foundation extending at least four feet below grade. The new heater is very close to combustible material at sides, front and back and unless it can be established it is of such a type as to permit such clearances, provision must be made to provide compliance with requirements. Support of pre-fabricated chimney is also in question. It is necessary that all of these violations of the Building Code be corrected without delay. I shall expect you to come to this office before December 29, 1959 with full information as to what the actual conditions are and as to how you propose to correct them. Failure to do so will make it necessary for me to report the violations to the Corporation Counsel for whatever action he may deem appropriate.


Very truly yours,

Albert J. Sears
Inspector of Buildings

AJS/jg

RECEIVED
 DEC 22 1959
 DEPT. OF ELDG. & HSE.
 CITY OF PORTLAND


7X10X10= 710
 2X6 on 10' dia 1401



Handwritten note:
 2' x 2' x 10' dia

Handwritten note:
 2' x 2' x 10' dia

Handwritten note:
 4' x 10' dia



RECEIVED
 DEC 22 1959
 DEPT. OF BLD'G. INSP.
 CITY OF PORTLAND

7x10x10 = 750
 4x6 on 10' span = 1401



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, October 21, 1959

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location R. 601 Danforth St. Use of Building Boat Shop No. Stories 1 ☒ New Building
Name and address of owner of appliance Goodall Boat Sales, R. 601 Danforth St. ☐ Existing
Installer's name and address Harris Oil Co., 302 Commercial St. Telephone 2-0304

General Description of Work

To install Forced warm air heating system and oil burning equipment.

IF HEATER, OR POWER BOILER

Location of appliance First floor Any burnable material in floor surface or beneath? none
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 3'
From top of smoke pipe prefab. From front of appliance over 4' From sides or back of appliance 6"
Size of chimney flue chimney to be constructed 6" x 8"
Other connections to same flue
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Lennox, guntype Labelled by underwriters' laboratories? yes
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1"
Location of oil storage first floor Number and capacity of tanks 1-275 gal.
Low water shut off Make No.
Will all tanks be more than five feet from any flame? yes How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners none

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

This is a Lennox OH6-105, 0.2 Btu/hr minimum clearances of 2" at sides and 1" at rear, 20" in front. (initials)

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:

O.K. 12-23-59 (initials)

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Harris Oil Company

Signature of Installer by:

(Signature)

CS 300

INSPECTION COPY

12-23-54 Am. Soc. Lecl. (112)

12-23-54 Am. J. C. Lee (12)

Permit No. 59/1884
Location 1601 Duane Street St
Owner 4 The Eagle Hotel
Date of permit 12/23/19
Approved _____



CITY OF PORTLAND, MAINE
DEPARTMENT OF BUILDING INSPECTION
COMPLAINT

CS-66

Location: R. 601 Danforth St.

INSPECTION COPY

COMPLAINT NO. 58/87

Date Received September 11, 1958

Location R. 601 Danforth Street Use of Building _____
Owner's name and address Goodall Boat Sales, 601 Danforth Street Telephone SP. 3-1113
Tenant's name and address _____ Telephone _____
Complainant's name and address _____ Telephone _____

Description: Metal frame canvas covered structure set on lot illegally used for boat storage. Canvas covering is fire hazard in area adjoining gas storage tanks. NFC.

NOTES: 9/16/58 - Letter ordering removal sent to-day - AGJ

9/25/58 In tel. conversation with Mr. Goodall averred that he had phoned Mr. Sears after receiving his letter of 9/16, and AJS had told him he could remove the canvas roof from the structures of which there are two, until such time as he could make plans to secure the required permits. He admitted that he not only did not remove the canvas, but that he was sheltering one or more boats under the structures.

He was told that he must either remove both structures from the premises before Tuesday night, 9/30/58, or file at this office before that time application for the two temporary structures (one permit), including a site plan showing location of the structures with relation to the property lines and other structures on the property. Of course the application must show the size and height of the structures and in general how they are built and foundations if any.

wncd 9/25/58

9/30/58 - Mr. Goodall called and said he had decided to demolish these two structures and promised faithfully to have them down on or before Oct. 7, 1958. AGJ

10-15-58 Complete pipe & canvas structure removed from premises MR

FU - 9/25/58 WFC

September 16, 1958

Cplt.-58/87-R, 601 Danforth Street

Goodall Boat Sales
601 Danforth Street

Gentlemen:

An inspector from this department reports that a canvas covered structure for boat storage has been erected without a permit at the above named location. Since such construction does not comply with Building Code requirements, you are in violation of the Building Code both as regards the construction and for work done without a permit. It is therefore necessary that this structure be completely removed at once so that these violations of the Code will be corrected. We shall expect this to be done before September 25, 1958.

Very truly yours,

AJS/jg

Albert J. Sears
Deputy Inspector of Buildings

August 21, 1958

AP-Rear 601 Danforth Street

Portland Pump Company
321 Lincoln Street
So. Portland, Maine
Goodall Boat Sales
Rear 601 Danforth Street

cc to: Fire Department

Gentlemen:

Permit for installation of tank and pump at the above location is issued herewith. We understand that the anchorage of tank is to be provided in a somewhat different manner than shown on plan which has been filed and that the changes have been approved by Capt. Flaherty of the Fire Department, who is to inspect the work before it is covered from view. Permit is issued on this basis.

Very truly yours,

AJS/jg

Albert J. Sears
Deputy Inspector of Buildings

Memorandum from Department of Building Inspection, Portland, Maine

August 19, 1958

Location: 8,001 Danforth St.

Before tank and piping is covered from view, installer is required to notify Fire Dept. Headquarters of readiness for inspection and to refrain from covering up until approved by Fire Dept. Headquarters.

This tank of 2000 gallon capacity is required to be of steel or wrought iron no less in thickness than 7th gauge; and before installation is required to be protected against corrosion, even though galvanized by two coats of tar, asphaltum, or other suitable rust-resisting paint, and special protection therein corrosive soil such as cinders or the like.

Pipe lines connected to underground tanks, other than tubing and except fill lines and test wells, must be provided with double swing joints arranged to permit the tank to settle without impairing the efficiency of the pipe connections.

Owner and installer will have to bear the responsibility for the structural capacity of the tank to support loads from above such as heavy motor trucks.

If tank will be so located as to be subjected to the action of tide water or "ground" water, adequate anchorage or weighting must be provided to prevent "floating" when tank is empty or nearly so.

Sept 7, 1964

SUBJECT: PIPING ON
2000 GAL TANK

LOCATION: GOODALL BOAT
SERVICE

