#### DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# **CITY OF PORTLAND**



# **BUILDING PERMIT**

This is to certify that

Job ID: 2011-01-260-ELEC-RR

Located At 501 DANFORTH LLC

CBL: 070 - - C - 002 - 001 - - - -

has permission to Install a 14K Payne furnace

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be

**Fire Prevention Officer** 

Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY.
PENALTY FOR REMOVING THIS CAR

## City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, FAX: (207) 8716

Job No: 2011-01-260-ELEC-RR/2011- 1903 HVAC	Date Applied: 03/15/2011		CBL: 070 C - 002 - 00	01		
Location of Construction: 501 DANFORTH ST	Owner Name: 501 DANFORTH IIc		Owner Address: 53 Lisbon Street Suite 2400 LEWISTON, ME - MAINE 04243			Phone:
Business Name:	Contractor Name: HVAC SERVICES		Contractor Address: 73 Bradley Drive, Westbrook, ME 04092			Phone:
Lessee/Buyer's Name;	Phone:		Permit Type: ELEC - Electrical Permit			Zone: B-2b
Past Use:	Proposed Use:  SAME: Accessory Building to the Offices for Development and management of Real Estate – to add suspended heating system		Cost of Work:	CEO District:		
Accessory Building to the Offices for Development and Management of Real Estate			Fire Dept:	Approved when a Denied N/A	Inspection: Use Group: Type: AVA Signature:	
Proposed Project Description 501 Danforth: HVAC			Pedestrian Activ	vities District (P.A.D.)		(a)
Permit Taken By: Gayle				Zoning Approval		
This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.     Building Permits do not include plumbing, septic or electrial work.     Building permits are void if work is not started within six (6) months of the date of issuance. False informatin may invalidate a building permit and stop all work.  Hereby certify that I am the owner of record of the named property, are owner to make this application as his authorized agent and I agree application is issued, I certify that the code official's authorized regenforce the provision of the code(s) applicable to such permit.		to conform to all applicable laws of t		this jurisdiction. In addition,	if a permit for work described in	
GNATURE OF APPLICANT		DDRESS		DATE		



## **APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT**

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Tk	ne undersigne	d hereby a	applies for	a permit	to install	the fol	lowing	heating,	cooking of	or power	equipment	in
accordan	ce with the La	ws of Ma	ine, the Bi	ilding Co	de of the	City of	Portla	nd, and	the follow	ing speci	fications:	

Location / CBL 501 Danforth Accessory Build	PHA Use of Building Date
Name and address of owner of appliance 501 Dentol	46LLC
Suite 2400 55 USBONST 10	WISTON IN CHARGO
Installer's name and address HVAC SERVICES  OYOGO  OYOGO	73 Bradley Drive Telephone 2078544822
Location of appliance:	Type of Chimney:
☐ Basement ☐ Floor	☐ Masonry Lined
☐ Attic ☑ Roof Susspended	Factory built
Type of Fuel:	☐ Metal
Gas Oil Solid	Factory Built U.L. Listing #
Appliance Name: Paywe 140k Purvice	Direct Vent RECEIVED
U.L. Approved ☑ Yes □ No	Type <u>Puc 90+</u> UL#
Will appliance be installed in accordance with the manufacture's	Type of Fuel Tank
installation instructions?  Yes	O' Oil Dept. of Building Inspection
	Gas City of Portland Maine
IF NO Explain:	Size of Tank 500
The Type of License of Installer:	Number of Tanks
☐ Master Plumber #	
□ Solid Fuel #	Distance from Tank to Center of Flame feet.
Oil #	Cost of Work: S 9.500
(a) Gas # PNT 1058	
Other	Permit Fee: S 120,00
Approved	Approved with Conditions
Fire:	☐ See attached letter or requirement
Ele.:	
Bldg.:	7.00
Signature of Installer	Inspector's Signature Date Approved
	rink - Applicant's Gold - Assessor's Copy

#### **BUILDING PERMIT INSPECTION PROCEDURES**

Please call 874-8703 or 874-8693 (ONLY)

or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.



#### 22 Oakmont Drive

Old Orchard Beach, ME 04064-4121

Phone: (207) 934-8038 Fax: (207) 934-8039

#### **MEMORANDUM**

Date: March 14, 2011
Project: 501 Danforth Street

To: David Lloyd, Archetype, P.A.


From: David Tetreault
Subject: New Roof Top Units

#### David,

I have reviewed the load-carrying capacity of the roof joists at the subject building. The purpose of the review was to determine whether the roof joists have sufficient load-carrying to support the heating unit suspended from the joists. The heating units is a Payne Model PG9MAB weighing 261 pounds

I conducted a visual inspection after the unit had been installed and found that support points are adequate and that the joists do not require reinforcement.

Please let me know if there is any question.



copy to:



Original Receipt arch 152011

, · ·						
Received from Brand Graso						
Location of Work 501 Dangold	-					
Cost of Construction \$ Building Fee \$						
Permit Fee         \$         Site Fee \$						
Certificate of Occupancy Fee \$						
Total:						
Building (IL) / Plumbing (I5) Electrical (I2) Site Plan (U2)						
Other JWA						
CBL: 070 (002						
Check #: Total Collected 130.00	/_					
No work is to be started until permit issued.						
Please keep original receipt for you records	<u>.</u>					
Taken by:	-					
0						

CITY OF PURTLAND, ME INSPECTION DIVISION 389 CONGRESS ST ROOM 315 PORTLAND. ME 04101 (207)874-8701

Merchant ID: 161000146545

Term 10: 001

Ref II: 004

Sale

XXXXXXXXXXXXXX7179

VISA

Entry Method: Swiped

03/15/11

12:00:11

Inv #: 000004

Appr Code: 054886

Approd: Online

Batch#: 000193

Total:

120.00

I agree to pay above total amount according to card issuer agreement (Merchant agreement if credit voucher)

GRASS-BRENT

Merchant Copy THANK YOU!

#### **Job Summary Report** Job ID: 2011-01-260-ELEC-RR

2011-1903

Report generated on Mar 16, 2011 12:18:32 PM

Page 1

Job Type:

Electrical-Repair/Replace/

Upgrade

**Job Description:** 

501 Danforth - 60' x 100' permit#100664

2011

**Building Job Status Code:** 

Permit Issued

Pin Value:

448

**Tenant Name:** 

Job Year:

**Job Application Date:** 

Public Building Flag: N **Tenant Number:** 

**Estimated Value:** 

Square Footage:

Property Owner

Related Parties:

501 Danforth LLC

ELECTRICAL CONTRACTOR

ANTHONY MANCINI

HVAC Services Inc. - HVAC Services Inc. HVAC Services

MECHANICAL CONTRACTOR

Inc.

**Job Charges** 

Fee Code Description

Charge Amount **Permit Charge** Adjustment

**Net Charge** Amount

**Payment** Date

Receipt Number **Payment Amount** 

**Payment Adjustment** Amount

**Net Payment** Amount

Outstanding Balance

Location ID: 11214

**Location Details** 

Alternate Id **Parcel Number**  Census Tract GIS X GIS Y GIS Z GIS Reference Longitude Latitude

976300

070 C 002 001

U

-70.276165 43.644217

Location Type Subdivision Code Subdivision Sub Code Related Persons

Address(es) 501 DANFORTH STREET WEST

**Location Use Code** 

Variance Code

**Use Zone Code** 

Fire Zone Code

Code

**Inside Outside** 

District Code

**General Location** Code

**Inspection Area** Code

Jurisdiction Code

BENEVOLENT & CHARITABLE

Historic District

DISTRICT 3 WEST END

**Structure Details** 

Structure: Sweetser School - 100664

Occupancy Type Code:

Structure Type Code

Structure Status Type Square Footage Estimated Value

**Address** 

Schools and Other Educational Buildings 0

501 DANFORTH STREET WEST

Longitude Latitude GIS X GIS Y GIS Z GIS Reference

User Defined Property Value

Permit #: 20111903



# PORTLAND MAINE

Strengthening a Remarkable City, Building a Community for Life . www.portlandmaine.gov

Director of Planning and Urban Development Penny St. Louis

Job ID: <u>2011-01-260-ELEC-RR</u>

Located At: 501 DANFORTH

CBL: <u>070 - - C - 002 - 001 - - - - -</u>

### **Conditions of Approval:**

#### Fire

Installation shall comply with City Code Chapter 10.

Installation shall comply with NFPA 211, Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances; NFPA 54, National Fuel Gas Code; NFPA 70, National Electrical Code; and the manufacturer's published instructions.

#### Zoning

- 1. This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.
- 2. ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.

#### Fire

The fire alarm system shall comply with the City of Portland Standard for Signaling Systems for the Protection of Life and Property. All fire alarm installation and servicing companies shall have a Certificate of Fitness from the Fire Department.

In field installation shall be installed per code as conditions dictate.

Records cabinet, FACP, annunciator(s), and pull stations shall be keyed alike.

Central Station monitoring for addressable fire alarm systems shall be by point.

All fire alarm records required by NFPA 72 should be stored in an approved cabinet located at the FACP labeled "FIRE ALARM RECORDS".

Installation of a Fire Alarm system requires a Knox Box to be installed per city ordinance.

System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.

Fire Alarm system shall be maintained. If system is to be off line over 4 hours a fire watch shall be in place. Dispatch notification required 874-8576.

**Building**The installation must comply with the State of Maine gas regulations.



Installation shall comply with City Code Chapter 10.

Installation shall comply with NFPA 211, Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances; NFPA 54, National Fuel Gas Code; NFPA 70, National Electrical Code; and the manufacturer's published instructions.

