Protection 1 Branch 11660	System Outputs			
10 Manual Drive, Portland, ME 04103 PH# 1-800-310-5011	Control Unit Annunciation	Notification	Safety Control	

System Inputs

	Actuate common alarm signal indicator	Actuate audible alarm system	Actuate common supervisory signal indicator	Actuate audible supervisory signal	Actuate common trouble signal indicator	Actuate evacuation signals	Transmit fire alarm signal to supervising station	Transmit supervisory signal to supervising	Transmit trouble signal to supervising station
System Pull Stations	X	X				X	X		
System Smoke Detectors	X	X				X	X		
System Heat Detectors	X	X				X	X		
Sprinkler Water Flow	X	X				X	X		
Sprinkler Gate Valve Tamper			X	X				X	
Sprinkler Air Pressure			X	X				X	
FACP AC Loss					X	X			X
FACP Low Battery					X	X			X
FACP Ground Fault					X	X			X
Phone Line #1 Fail					X	X			X
Phone Line #2 Fail					X	X			X
Cianbro, Corporation									
60 Cassidy Point Drive									