
# MERCY HOSPTIAL


# SUITE 390 FIT-UP

FORE RIVER M.O.B.

# **PERMIT SET**



LEVEL 3 FLOOR PLAN



2 LIFE SAFETLY PLAN

### LIFE SAFETY LEGEND

— н2—	2 HOUR RATED HORIZONTAL EXIT & SMOKE BARRIER
O2	2 HOUR RATED OCCUPANCY SEPARATION & SMOKE BARRIER
— F2 —	2 HOUR RATED FIRE BARRIER
F1	1 HOUR RATED FIRE BARRIER
<del></del>	2 HOUR RATED SMOKE BARRIER
— s1 —	1 HOUR RATED SMOKE BARRIER
so	SMOKE PARTITION
	EXIT DISCHARGE
(S)	SMOKE CONTAINMENT BARRIER
172'	TRAVEL DISTANCE
FEC	FIRE EXTINGUISHER CABINET
FE .	FIRE EXTINGUISHER WALL HUNG
EXIT	► EGRESS DOOR
F	FIRE ALARM VISIBLE ONLY
F	FIRE ALARM AUDIBLE/VISIBLE NOTIFICATION APPLIANCLE (GENERAL EVACUATION)
	EXIT SIGN
L	ACCESSIBLE ENTRY/EGRESS

NOTE: 1. REUSE EXISITNG EXIT SIGNS AND DEVICES

2. MEET REQUIREMENTS FOR FOOTCANDLE

3. REUSE EXISITING FIRE EXTINGUISHER CABINETS

### CODE AND STANDARD APPLICABLE TO SCOPE OF PROFESSIONAL SERVICES REQUESTED

LIFE SAFETY CODE: NFPA, INCLUDING 101 LIFE SAFETY CODE, 2012 EDITION INCLUDING 101 LIFE SAFETY CODE, 2012 EDITION AUTHORITY HAVING JURISDICTION: MAINE DEPARTMENT OF PUBLIC SAFETY FIRE MARSHAL'S OFFICE 45 COMMERCE DRIVE, SUITE 1 AUGUSTA, ME 04330 207-626-3884

BUILDING CODE:
INTERNATIONAL BUILDING CODE (IBC) 2009
AUTHORITY HAVING JURISDICITION:
CITY OF PORTLAND
PLANNING & URBAN DEVELOPMENT DEPARTMENT
389 CONGRESS STREET
PORTLAND, ME 04101

# HANDICAPPED ACCESSIBILITY STANDARD: AMERICANS WITH DISABILITIES ACT ACCESSIBILITY GUIDELINES AUTHORITY HAVING JURISDICITION:

FIRE MARSHAL'S OFFICE 45 COMMERCE DRIVE, SUITE 1 AUGUSTA, ME 04330 207-626-3884

### BASIC LIFE SAFETY AND BUILDING CODE CRITERIA

DESCRIPTION OF BUILDING FUNCTION
EXISTING, FOUR STORY COMMERCIAL OFFICE BUILDING (DOCTORS OFFICE)

# OCCUPANCY CLASSIFICATION IBC: EXISTING BUSINESS (CHAPTER 39)

SPECIFIC OCCUPANCY AREAS (BOCA TABLE 302.1.1)

DESCRIPTION
WASTE & SOILED COLLECTION LINEN ROOM

SEPARATION SPRINKLERS + 1 HOUR SPRINKLERS + SMOKE PARTITIONS SPRINKLERS + SMOKE PARTITIONS STORAGE ROOMS >50 SF AND <100 SF STORAGE ROOMS GREATER THAN 100 SF

### ACCESSORY USE AREA (BOCA, 302.1.2) NONE IDENTIFIED

SPECIAL USE AND OCCUPANCY NONE IDENTIFIED

NFPA: TYPE II (III) PROTECTED NON-COMBUSTIBLE IBC: TYPE 2B

BUILDING IS PROTECTED THROUGHOUT BY AUTOMATIC FIRE SPRINKLER SYSTEM IN CONFORMANCE WITH NFPA 13

### MEANS OF EGRESS OCCUPANT LOAD:

PANT LOAD: BUSINESS = 100 SF / OCCUPANT PAT NURSE: 630 SF / 100 = 7 MED RECORDS: 470 SF / 100 = 5 BIO STOR: 98/100 = 1 1225 SF / 100 SF = 13 OCCUPANTS

### MINIMUM NUMBER OF EXITS 13 < 50 OCCUPANTS = 1 EXIT

CORRIDORS
DOORS, MINIMUM CLEAR WIDTH
DEAD END CORRIDORS
COMMON PATH OF TRAVEL MAXIMUM
TRAVEL DISTANCE MAXIMUM

44 INCHES (60" PER FGI GUIDELINES FOR HEALTHCARE) 32 INCHES 50 FT. 100 FT. 300 FT.

## ILLUMINATION OF MEANS OF EGRESS EGRESS WILL BE ILLUMINATED BY BATTERY TYPE LIGHT FIXTURES.

PROTECTION FROM HAZARDS
WATER BASED AUTOMATIC FIRE PROTECTION SYSTEM CONFORMING WITH NFPA 13, TYPICAL THROUGHOUT
THE BUILDING UNLESS NOTED OTHERWISE SPECIFIC OCCUPANCY AREAS AREAS WILL BE FIRE OR SMOKE
SEPARATED AS IDENTIFIED ABOVE

### EXTINGUISHMENT PORTABLE FIRE EXTINGUISHERS IN ACCORDANCE WITH NFPA 101, SECTION 9.7.4.1.

DETECTION, ALARM AND COMMUNICATION SYSTEMS FIRE ALARM SYSTEM REQUIRED IN ACCORDANCE WITH NFPA-101, SECTION 906

EACH TRADE TO PROVIDE SMOKE OR FIRE SEALANT AT PENETRATIONS AS REQUIRED FOR WALL TYPE. ALL FIRE SEALANT, FIRE STOPPING ASSEMBLIES SHALL BE U.L. RATED.









PERMIT SET 07/28/14

A/E OF RECORD:

PROJECT INFO & LIFE

SAFETY

AE-100