Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 09/06/16

Portland Maine Yes. Google's good here.

Laurie Leader <lrl@portlandmaine

RE: Miller Drug follow up

1 message

Kristen Damuth <KDamuth@smrtinc.com> Tue, Sep 6, 2016 at 2:46 PM
To: Laurie Leader <lrl@portlandmaine.gov>

Hi Laurie-

Yes the check-out area/counter will comply with the height and clear floor space requirements of 904.

Thanks.

Kristen Damuth AIA, CSI
Senior Architect
A Maine Licensed Architect (FL, MA, NH, VT)

SMRT Architects and Engineers
p: 877.700.7678
smrtinc.com

From: Laurie Leader [mailto:lrl@portlandmaine.gov]
Sent: Tuesday, September 06, 2016 2:38 PM
To: Kristen Damuth
Subject: Re: Miller Drug follow up

Kristen,

Thanks for forwarding the entire first floor plan.

Can you clarify that the furniture and equipment by others meets Section 904 of the 2010 ADA Standards for Accessible Design? Once I receive this confirmation, I will be signing off on this permit.

Laurie

On Tue, Sep 6, 2016 at 1:03 PM, Kristen Damuth <KDamuth@smrtinc.com> wrote:

Hi Laurie-

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 09/06/16

Here is what I found for the existing first floor. (We did not do any of the fit up nor the original shell so ou drawing files are somewhat limited). There are public restrooms in the middle of the building.

Please let me know if you have any other questions.

Thanks.

Kristen Damuth AIA, CSI
Senior Architect
A Maine Licensed Architect (FL, MA, NH, VT)

SMRT Architects and Engineers
p: 877.700.7678
smrtinc.com

--

Laurie Leader
Plan Review/Code Enforcement
City of Portland, Maine
Inspections Division
389 Congress Street
Portland, ME 04101

P: 207-874-8714
F: 207-874-8716
E: lrl@portlandmaine.gov

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.