

Record of Completion

Presented To

Mercy Fore River Administration Building

195 Fore River Parkway
Portland ME 04102
USA

This site has been inspected and tested in compliance with applicable standards.

Completed
Thursday, June 27, 2019

Test Session: 06/25/19

ACCEPTED BY

Mercy Fore River Administration Building
195 Fore River Parkway
Portland ME 04102
USA

TESTED BY

Norris Inc.
Norris Inc
2257 Broadway
South Portland ME 4106
USA

Norris Inc



Advancing security, life safety and communications.

Inspection Location and Organizations

Building Information

PROPERTY	Mercy Fore River Administration Building	CONTACT
ADDRESS	195 Fore River Parkway	PHONE
CITY/STATE/ZIP	Portland, ME 04102	MOBILE
COUNTRY	USA	EMAIL

Installer Information

NAME	Norris Inc
ADDRESS	2257 Broadway South Portland ME 4106
PHONE	(207) 883-3473
EMAIL	NICentralOperations@norrisinc.com

Service Company Information

NAME	Norris Inc
ADDRESS	2257 Broadway South Portland ME 4106
PHONE	(207) 883-3473
EMAIL	NICentralOperations@norrisinc.com

Testing Company Information

NAME	Norris Inc
ADDRESS	2257 Broadway South Portland ME 4106
PHONE	(207) 883-3473
EMAIL	NICentralOperations@norrisinc.com
CONTRACT DATE	

Description of Service

This is an existing system.

Permit #

NFPA72 Edition:

Number of devices participating in Alarm Verification: 0

Initiating Device Summary

EQUIPMENT TYPE	TOTAL
Alarm Notification Appliance	40
Initiating Device	5
Fire Control Panel	3

Notification Device Summary

EQUIPMENT TYPE	TOTAL
Alarm Notification Appliance	40
Initiating Device	5
Fire Control Panel	3

Device Summary

EQUIPMENT TYPE	TOTAL
Alarm Notification Appliance	40
Initiating Device	5
Fire Control Panel	3


Norris Inc

Certification Information

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Thursday, June 27, 2019

INSTALLED BY 
6/27/2019
Norris Inc.
Installer

TESTED BY 
6/27/2019
Norris Inc.
Technician

ACCEPTED BY
6/27/2019
Building Representative

ACCEPTED BY
6/27/2019
AHJ

Testing Details

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Speaker And Visible		SUITE 210 OS AUDIOLOGY RM 1	Manual	6/27/2019 7:29 AM
		Visual Inspection		
		Functional Inspection		
		Candela Rating	0	
		Ambient Sound Pressure	0	
		Active Sound Pressure	0	
		STI	0	
Speaker And Visible		SUITE 210 OS AVG/ABR ROOM	Manual	6/27/2019 7:29 AM
		Visual Inspection		
		Functional Inspection		
		Candela Rating	0	
		Ambient Sound Pressure	0	
		Active Sound Pressure	0	
		STI	0	
Speaker And Visible		SUITE 210 OS AUDIOLOGY ROOM 2	Manual	6/27/2019 7:29 AM
		Visual Inspection		
		Functional Inspection		
		Candela Rating	0	
		Ambient Sound Pressure	0	
		Active Sound Pressure	0	
		STI	0	
Speaker And Visible		SUITE 210 OS KITCHEN BREAKROOM	Manual	6/27/2019 7:29 AM
		Visual Inspection		
		Functional Inspection		
		Candela Rating	0	
		Ambient Sound Pressure	0	
		Active Sound Pressure	0	
		STI	0	
Visible		SUITE 210 IS AUDIOLOGY ROOM 1	Manual	6/27/2019 7:29 AM
		Manufacturer	Wheelock	
		Visual Inspection		
		Functional Inspection		
		Candela Rating	0	
Visible		SUITE 210 IS AVG/ABR ROOM	Manual	6/27/2019 7:29 AM
		Manufacturer	Wheelock	
		Visual Inspection		
		Functional Inspection		
		Candela Rating	0	
Visible		SUITE 210 IS AUDIOLOGY ROOM 2	Manual	6/27/2019 7:29 AM
		Manufacturer	Wheelock	
		Visual Inspection		
		Functional Inspection		
		Candela Rating	0	
Visible		SUITE 210 IS KITCHEN BREAKROOM	Manual	6/27/2019 7:29 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
		Manufacturer	Wheelock	
		Visual Inspection		
		Functional Inspection		
		Candela Rating	0	

Device/Equipment Details

Fire Control Panel

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
FCPS					
4-2	4th FL Tel/Com Electrical Closet by Elevators	Notifier	24S8		5/15/2019
FCPS Batteries					
	FCPS 4-2 Batteries	Sigmas Tek	12V-7AH		5/15/2019
Fire Alarm Panel					
	1st FL Electrical Room FACP	Notifier	NFS2-640		5/15/2019

Initiating Device

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Smoke Detector - General					
	4th FL Suite 410 Corridor East by Exam 120				5/15/2019
	4th FL Suite 410 Corridor West by Checkout				5/15/2019
	4th FL Suite 410 Corridor West by Office 100				5/15/2019
	4th FL Suite 410 Corridor East by Exam 113				5/15/2019
	4th FL Suite 410 Corridor East by Exam 123				5/15/2019

Alarm Notification Appliance

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Speaker And Visible					
	Suite 410 Waiting Room				5/15/2019
	Suite 410 Work Area				5/15/2019
	Suite 410 Corridor by Bathroom 117				5/15/2019
	Suite 410 Corridor by Exit				5/15/2019
	Suite 410 Breakroom				5/15/2019
	Suite 410 Corridor by Breakroom				5/15/2019
	Suite 410 Exam by Middle Nurse Station				5/15/2019
	SUITE 210 OS AUDIOLOGY RM 1				6/25/2019
	SUITE 210 OS AVG/ABR ROOM				6/25/2019
	SUITE 210 OS KITCHEN BREAKROOM				6/25/2019
	SUITE 210 OS AUDIOLOGY ROOM 2				6/25/2019
Visible					
	Suite 410 Exam by Breakroom				5/15/2019
	Suite 410 Exam 123				5/15/2019
	Suite 410 Exam by Work Area				5/15/2019
	Suite 410 Reception				5/15/2019
	Suite 410 Exam by Breakroom				5/15/2019
	Suite 410 Exam 115				5/15/2019
	Suite 410 Exam 124				5/15/2019
	Suite 410 Bathroom 117				5/15/2019
	Suite 410 Exam 116				5/15/2019
	Suite 410 Workroom by Reception EOLR				5/15/2019

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
	PS 4.2 Nac 2				
	Suite 410 Exam 112 EOLR 4.2 Nac 1				5/15/2019
	Suite 410 Bathroom by Breakroom				5/15/2019
	Suite 410 Exam by Work Area				5/15/2019
	Suite 410 Exam by Bathroom				5/15/2019
	Suite 410 Corridor by Nurse Station				5/15/2019
	Suite 410 Exam 121				5/15/2019
	Suite 410 Exam 120				5/15/2019
	Suite 410 Exam 113				5/15/2019
	Suite 410 Bathroom by Work Area				5/15/2019
	Suite 410 Exam by Bathroom				5/15/2019
	Suite 410 Exam by Bathroom End of Hall				5/15/2019
	Suite 410 Exam by Breakroom				5/15/2019
	Suite 410 Exam by Bathroom End of Hall				5/15/2019
	Suite 410 Exam by Breakroom				5/15/2019
	Suite 410 Exam 125				5/15/2019
	SUITE 210 IS AUDIOLOGY ROOM 1	Wheelock			6/25/2019
	SUITE 210 IS KITCHEN BREAKROOM	Wheelock			6/25/2019
	SUITE 210 IS AVG/ABR ROOM	Wheelock			6/25/2019
	SUITE 210 IS AUDIOLOGY ROOM 2	Wheelock			6/25/2019



PO Box 2551
2257 West Broadway
South Portland, ME 04106

1.800.370.3473
fax 207.879.0540

www.norrisinc.com

August 5, 2019

Mercy Hospital
195 Fore River Parkway
Suite 210
Portland, Maine 04102

Subject: Suite 210 Fire Alarm System Addition

To Whom it may concern,

As requested, I am writing to confirm the fire alarm system for the above mentioned subject, was inspected and tested and at the time of inspection the system was found to be operational and to the best of our knowledge, met or exceeded all of the requirements as established by the plans and specifications for the project and all applicable codes including NFPA 72.

It was a pleasure working with you on this project. Should you have any questions or need additional information please do not hesitate to contact me.

Sincerely,

Jon R. Portwine

Jon R. Portwine
Operations Manager