

Record of Completion

Presented To

Mercy Fore River Administration Building

195 Fore River Parkway

Portland ME 04102

USA

This site has been inspected and tested in compliance with applicable standards.

Completed

Wednesday, May 15, 2019

Test Session: 05/15/19

ACCEPTED BY

Mercy Hospital

Mercy Fore River Administration Building

195 Fore River Parkway

Portland ME 04102

USA

TESTED BY

Anthony Morris

Norris Inc

2257 Broadway

South Portland ME 4106

USA



Advancing security, life safety and communications.

Inspection Location and Organizations

Building Information

PROPERTY	Mercy Fore River Administration Building	CONTACT
ADDRESS	195 Fore River Parkway	PHONE
CITY/STATE/ZIP	Portland, ME 04102	MOBILE
COUNTRY	USA	EMAIL

Installer Information

NAME	Norris Inc
ADDRESS	2257 Broadway South Portland ME 4106
PHONE	(207) 883-3473
EMAIL	NICentralOperations@norrisinc.com

Service Company Information

NAME	Norris Inc
ADDRESS	2257 Broadway South Portland ME 4106
PHONE	(207) 883-3473
EMAIL	NICentralOperations@norrisinc.com

Testing Company Information

NAME	Norris Inc
ADDRESS	2257 Broadway South Portland ME 4106
PHONE	(207) 883-3473
EMAIL	NICentralOperations@norrisinc.com
CONTRACT DATE	

Description of Service

This is an existing system.

Permit #

NFPA72 Edition:

Number of devices participating in Alarm Verification: 0

Initiating Device Summary

EQUIPMENT TYPE	TOTAL
Alarm Notification Appliance	32
Initiating Device	5
Fire Control Panel	3

Notification Device Summary

EQUIPMENT TYPE	TOTAL
Alarm Notification Appliance	32
Initiating Device	5
Fire Control Panel	3

Device Summary

EQUIPMENT TYPE	TOTAL
Alarm Notification Appliance	32
Initiating Device	5
Fire Control Panel	3

Norris Inc

Certification Information

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, May 15, 2019

INSTALLED BY

5/15/2019
Darren Spear BH Milliken
Installer

TESTED BY



5/15/2019
Anthony Morris
Technician

ACCEPTED BY

5/15/2019
Mercy Hospital
Building Representative


ACCEPTED BY

5/15/2019
PFD
AHJ

Testing Details

Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
FCPS	4-2	4th FL Tel/Com Electrical Closet by Elevators	Manual	5/15/2019 8:50 AM
	Comment:			
				
FCPS Batteries		FCPS 4-2 Batteries	Manual	5/15/2019 8:51 AM
	Comment:	New 5-15-19		
Fire Alarm Panel		1st FL Electrical Room FACP	Manual	5/15/2019 8:52 AM

Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General		4th FL Suite 410 Corridor West by Office 100	Manual	5/15/2019 9:14 AM
Smoke Detector - General		4th FL Suite 410 Corridor West by Checkout	Manual	5/15/2019 9:14 AM
Smoke Detector - General		4th FL Suite 410 Corridor East by Exam 123	Manual	5/15/2019 9:14 AM
Smoke Detector - General		4th FL Suite 410 Corridor East by Exam 113	Manual	5/15/2019 9:14 AM
Smoke Detector - General		4th FL Suite 410 Corridor East by Exam 120	Manual	5/15/2019 9:14 AM

Alarm Notification Appliance

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Visible		Suite 410 Bathroom 117	Manual	5/15/2019 9:09 AM
Visible		Suite 410 Exam 116	Manual	5/15/2019 9:09 AM
Visible		Suite 410 Exam 120	Manual	5/15/2019 9:09 AM
Visible		Suite 410 Corridor by Nurse Station	Manual	5/15/2019 9:10 AM
Visible		Suite 410 Exam 115	Manual	5/15/2019 9:10 AM
Visible		Suite 410 Exam 121	Manual	5/15/2019 9:10 AM
Visible		Suite 410 Exam 113	Manual	5/15/2019 9:10 AM
Speaker And Visible		Suite 410 Corridor by Bathroom 117	Manual	5/15/2019 9:10 AM

Norris Inc

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Speaker And Visible		Suite 410 Exam by Middle Nurse Station	Manual	5/15/2019 9:10 AM
Visible		Suite 410 Exam 123	Manual	5/15/2019 9:10 AM
Visible		Suite 410 Exam 124	Manual	5/15/2019 9:10 AM
Visible		Suite 410 Exam 112 EOLR 4.2 Nac 1	Manual	5/15/2019 9:10 AM
Speaker And Visible		Suite 410 Waiting Room	Manual	5/15/2019 9:10 AM
Visible		Suite 410 Reception	Manual	5/15/2019 9:10 AM
Visible		Suite 410 Workroom by Reception EOLR PS 4.2 Nac 2	Manual	5/15/2019 9:10 AM
Speaker And Visible		Suite 410 Breakroom	Manual	5/15/2019 9:10 AM
Speaker And Visible		Suite 410 Corridor by Breakroom	Manual	5/15/2019 9:10 AM
Visible		Suite 410 Exam by Breakroom	Manual	5/15/2019 9:10 AM
Visible		Suite 410 Exam by Breakroom	Manual	5/15/2019 9:11 AM
Visible		Suite 410 Exam by Breakroom	Manual	5/15/2019 9:11 AM
Visible		Suite 410 Bathroom by Breakroom	Manual	5/15/2019 9:11 AM
Visible		Suite 410 Exam by Breakroom	Manual	5/15/2019 9:11 AM
Speaker And Visible		Suite 410 Work Area	Manual	5/15/2019 9:11 AM
Visible		Suite 410 Exam by Work Area	Manual	5/15/2019 9:11 AM
Visible		Suite 410 Exam by Work Area	Manual	5/15/2019 9:11 AM
Visible		Suite 410 Exam by Bathroom	Manual	5/15/2019 9:11 AM
Visible		Suite 410 Bathroom by Work Area	Manual	5/15/2019 9:11 AM
Visible		Suite 410 Exam by Bathroom	Manual	5/15/2019 9:11 AM
Visible		Suite 410 Exam by Bathroom End of Hall	Manual	5/15/2019 9:11 AM
Visible		Suite 410 Exam by Bathroom End of Hall	Manual	5/15/2019 9:11 AM
Speaker And Visible		Suite 410 Corridor by Exit	Manual	5/15/2019 9:11 AM
Visible		Suite 410 Exam 125	Manual	5/15/2019 9:11 AM

Device/Equipment Details

Fire Control Panel

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
FCPS					
4-2	4th FL Tel/Com Electrical Closet by Elevators	Notifier	24S8		5/15/2019
FCPS Batteries					
	FCPS 4-2 Batteries	Sigmas Tek	12V-7AH		5/15/2019
Fire Alarm Panel					
	1st FL Electrical Room FACP	Notifier	NFS2-640		5/15/2019

Initiating Device

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Smoke Detector - General					
	4th FL Suite 410 Corridor East by Exam 120				5/15/2019
	4th FL Suite 410 Corridor West by Checkout				5/15/2019
	4th FL Suite 410 Corridor West by Office 100				5/15/2019
	4th FL Suite 410 Corridor East by Exam 113				5/15/2019
	4th FL Suite 410 Corridor East by Exam 123				5/15/2019

Alarm Notification Appliance

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Speaker And Visible					
	Suite 410 Waiting Room				5/15/2019
	Suite 410 Work Area				5/15/2019
	Suite 410 Corridor by Bathroom 117				5/15/2019
	Suite 410 Breakroom				5/15/2019
	Suite 410 Corridor by Breakroom				5/15/2019
	Suite 410 Exam by Middle Nurse Station				5/15/2019
	Suite 410 Corridor by Exit				5/15/2019
Visible					
	Suite 410 Exam by Breakroom				5/15/2019
	Suite 410 Exam 123				5/15/2019
	Suite 410 Reception				5/15/2019
	Suite 410 Exam by Breakroom				5/15/2019
	Suite 410 Exam 112 EOLR 4.2 Nac 1				5/15/2019
	Suite 410 Bathroom by Breakroom				5/15/2019
	Suite 410 Exam 115				5/15/2019
	Suite 410 Exam 124				5/15/2019
	Suite 410 Exam by Work Area				5/15/2019
	Suite 410 Corridor by Nurse Station				5/15/2019
	Suite 410 Exam 121				5/15/2019
	Suite 410 Exam by Work Area				5/15/2019
	Suite 410 Exam by Bathroom				5/15/2019
	Suite 410 Exam by Bathroom				5/15/2019

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
	Suite 410 Exam by Bathroom End of Hall				5/15/2019
	Suite 410 Exam by Breakroom				5/15/2019
	Suite 410 Exam 125				5/15/2019
	Suite 410 Exam by Breakroom				5/15/2019
	Suite 410 Exam by Bathroom End of Hall				5/15/2019
	Suite 410 Exam 120				5/15/2019
	Suite 410 Exam 113				5/15/2019
	Suite 410 Bathroom by Work Area				5/15/2019
	Suite 410 Bathroom 117				5/15/2019
	Suite 410 Exam 116				5/15/2019
	Suite 410 Workroom by Reception EOLR PS 4.2 Nac 2				5/15/2019

Supplementary Information