

PROJECT: LOGAN PLACE PORTLAND, MAINE		THREE PHASE PANELBOARD SCHEDULE			PANEL DESIGNATION: HP - LEFT SIDE		
SURFACE MOUNTED							
KVA LOAD	MAIN LUGS: 600A	VOLTS: 208/120	PHASE: 3	WIRE: 4	KVA LOAD		
1.0	OUTLETS - RMS 116, 120 & WH-1	1	20	20	2	OUTLET - RM 116	1.5
.50	ELEV. CAB LTG	3	20	20	4	OUTLETS - RM 114, SF-1, UH-1	1.0
.50	OUTLET - RM 121, EF-9, WH-2	5	20	20	6	AUTOMATIC DOOR OPENERS	1.0
1.5	OUTLETS - RM 104, 122, SF-3, SF-4, EF-3, CUH-3, WH-3, FLD	7	20	20	8	OUTLETS CUH-10 - 3RD FLR CORR.	1.0
1.6	OUTLETS - RM 123, 105, 130, CUH-2, CUH-4	9	20	20	10	OUTLETS CUH-9 - 3RD FLR CORR.	.80
.60	OUTLETS - RM 101, CUH-5	11	20	20	12	EF-7, EF-8, CP-4, UH-2	1.5
.50	F.A. PANEL W/ HANDLE LOCK	13	20	20	14	LIGHTING - RMS 120, 124, 118, 117, 113, 114, 115	.90
1.2	OUTLETS - RM 216, CUH-7, CUH-8	15	20	20	16	LIGHTING - RMS 202, 216, 203	.50
1.0	OUTLETS - RMS 202, 216, 201, 109, CUH-6	17	20	20	18	LIGHTING - RMS 202, 216	.25
.50	LIGHTING - STAIR #1	19	20	20	20	LIGHTING - RMS 123, 104, 122	.30
.50	LIGHTING - STAIR #2	21	20	20	22	LIGHTING - RMS 123, 104, 106, 122, 119, 101, 102	1.1
.50	LIGHTING - BLDG EXTERIOR	23	20	20	24	LIGHTING - 3RD FLR CORR.	.50
1.0	LIGHTING - ATTIC	25	20	20	26	LIGHTING - 3RD FLR CORR.	.50
1.0	INTERCOM SYSTEM	27	20	20	28	ELEVATOR SUMP PUMP	1.2
1.0	LIGHTING	29	20	20	30	SPARE	
1.0	LIGHTING	31	20	20	32		
	SPARE	33	20	20	34		
		35	20	20	36	SPACE	
		37	20	20	38		
	SPACE	39	20	20	40		
		41	20	20	42		
SUB FEED LUGS							
TOTAL CONN. LOAD: 128.9 KVA		TOTAL DEM. LOAD: _____					

PROJECT: LOGAN PLACE PORTLAND, MAINE		THREE PHASE PANELBOARD SCHEDULE			PANEL DESIGNATION: HP - DOUBLE PANEL HP - RIGHT SIDE		
SURFACE MOUNTED							
KVA LOAD	MAIN LUGS: 600A	VOLTS: 208/120	PHASE: 3	WIRE: 4	KVA LOAD		
1.2	CU-2	43	20	20	44	CP-1	2.0
1.2		45	20	20	46		2.0
1.7	CU-3	47	20	20	48	CP-2	2.0
1.7		49	20	20	50		2.0
2.4	CU-1	51	20	20	52		2.0
2.4		53	20	20	54		2.0
2.4		55	20	20	56	CP-6	.60
4.0	ERV-1	57	20	20	58		.60
4.0		59	20	20	60		.60
4.0		61	20	20	62	CP-7	.60
15.0	ELEVATOR MACHINE	63	20	20	64		.60
15.0	SHUNT TRIP BREAKER	65	20	20	66		.60
15.0		67	20	20	68	TEMP. CONTROL PANEL	.50
.86	SUMP PUMP	69	20	20	70	BOILER B-1	.86
.30	SAC-1	71	20	20	72	BOILER B-2	.86
.30	SAC-2	73	20	20	74	UV-1	.70
12.4	PANEL CP	75	20	20	76	SITE LIGHTING VIA CONTACTOR "LC"	.70
12.4		77	20	20	78		.70
12.4		79	20	20	80	WALL PACKS VIA CONTACTOR "LC"	.50
	SPACE	81	20	20	82	SPACE	
		83	20	20	84		
TOTAL CONN. LOAD: 128.9 KVA		TOTAL DEM. LOAD: _____					

PROJECT: LOGAN PLACE PORTLAND, MAINE		THREE PHASE PANELBOARD SCHEDULE			PANEL DESIGNATION: CP		
RECESSED							
KVA LOAD	MAIN LUGS: 225A	VOLTS: 208/120	PHASE: 3	WIRE: 4	KVA LOAD		
1.5	OUTLET - RM 108	1	20	20	2	OUTLETS - RM 110, WH-3, WH-4	1.5
1.5	OUTLET - RM 108	3	20	20	4	WASHER	1.0
1.5	OUTLET - RM 108	5	20	20	6	WASHER	1.0
1.5	OUTLET - RM 108	7	20	20	8	DRYER	1.0
1.5	OUTLET - RM 108	9	20	20	10	DRYER	1.0
1.5	OUTLET - RM 108	11	20	20	12	OUTLETS - RM 118	.80
1.5	OUTLET - RM 108	13	20	20	14	OUTLETS - RM 117	.80
1.5	OUTLET - RM 108	15	20	20	16	OUTLETS - RM 113	1.2
1.5	OUTLET - RM 108	17	20	20	18	OUTLET - RM 112	1.5
1.5	OUTLET - RM 108	19	20	20	20	OUTLETS - RM 106	1.5
1.5	OUTLET - RM 108	21	20	20	22	OUTLETS - RM 102, EF-4	.80
1.5	REFRIGERATOR - RM 108	23	20	20	24	OUTLETS - RM 203	1.0
1.0	RANGE - RM 10	25	20	20	26	OUTLETS - RM 302	1.0
1.2	OUTLETS - RM 107	27	20	20	28	OUTLETS - RM 301, EF-6	1.0
1.5	LIGHTING - RMS 107, 108	29	20	20	30	LIGHTING - RMS 302, 301	.50
	SPARE	31	20	20	32	LIGHTING	
		33	20	20	34	SPARE	
		35	20	20	36		
	SPACE	37	20	20	38		
		39	20	20	40	SPACE	
		41	20	20	42		
TOTAL CONN. LOAD: 37.3 KVA		TOTAL DEM. LOAD: _____					

LOGAN PLACE

PORTLAND, MAINE

Project No: 01409 SRO

Drawing Title:  
**PANEL SCHEDULES**

Scale: AS NOTED

Date: JANUARY 14, 2004

Revisions:

- △
- △
- △
- △
- △
- △

Drawing Number:

**E4.2**