
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager MORGENSTERN MICHAEL		Inspector Suzanne Hunt	Inspection Date 8/5/2009
Locatation 26 FREDERIC ST	CBL 076 A013001	Status Re-Inspect 5 Days	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-108.(f)	Interior				
Violation:	Required equipment and utilities				
Notes:	All supplied utilites must work. The furnace is not operating to produce hot water.				
Comments:	All supplied utilites must work, Tenants are without hot water.				
