Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 12/22/17

Protection 1 Branch 11660
10 Manual Drive, Portland, ME 04103 PH# 1-800-310-5011

System Inputs

	System Outputs																																									
	Control Unit Annunciation																Notification																				Safety Control					
	Actuate common alarm signal indicator	Actuate audible alarm system	Actuate common supervisory signal indicator	Actuate audible supervisory signal	Actuate common trouble signal indicator			Actuate building evacuation signals									Transmit fire alarm signal to supervising station	Transmit supervisory signal to supervising station	Transmit trouble signal to supervising station																						
System Pull Stations		X	X						X								X																									
System Smoke Detectors		X	X						X								X																									
System Heat Detectors		X	X						X								X																									
Sprinkler Water Flow		X	X						X								X																									
Sprinkler Gate Valve Tamper				X	X	X												X																								
Sprinkler Air Pressure																																										
FACP AC Loss					X	X													X																							
FACP Low Battery					X	X													X																							
FACP Ground Fault					X	X													X																							
Phone Line #1 Fail					X	X													X																							
Phone Line #2 Fail					X	X													X																							

A.F. Fitzgerald, Inc
12 Westfield Street
Portland, Maine 04104